

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11943056	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 09/27/2023
NAME OF PROVIDER OR SUPPLIER SUNSHINE LIVING ALF CORP		STREET ADDRESS, CITY, STATE, ZIP CODE 676 UNION STREET DUNEDIN, FL 34698		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
CZ830 SS=D	408.821 FS Emergency Management Planning 408.821 Emergency management planning; emergency operations; inactive license.- (1) A licensee required by authorizing statutes and agency rule to have a comprehensive emergency management plan must designate a safety liaison to serve as the primary contact for emergency operations. Such licensee shall submit its comprehensive emergency management plan to the local emergency management agency, county health department, or Department of Health as follows: (a) Submit the plan within 30 days after initial licensure and change of ownership, and notify the agency within 30 days after submission of the plan. (b) Submit the plan annually and within 30 days after any significant modification, as defined by agency rule, to a previously approved plan. (c) Submit necessary plan revisions within 30 days after notification that plan revisions are required. (d) Notify the agency within 30 days after approval of its plan by the local emergency management agency, county health department, or Department of Health. (2) An entity subject to this part may temporarily exceed its licensed capacity to act as a receiving provider in accordance with an approved comprehensive emergency management plan for up to 15 days. While in an overcapacity status, each provider must furnish or arrange for appropriate care and services to all clients. In addition, the agency may approve requests for overcapacity in excess of 15 days, which approvals may be based upon satisfactory justification and need as provided by the receiving and sending providers. (3)(a) An inactive license may be issued to a licensee subject to this section when the provider	CZ830		

AHCA Form 3020-0001

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11943056	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 09/27/2023
NAME OF PROVIDER OR SUPPLIER SUNSHINE LIVING ALF CORP		STREET ADDRESS, CITY, STATE, ZIP CODE 676 UNION STREET DUNEDIN, FL 34698		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
CZ830	Continued From page 1 is located in a geographic area in which a state of emergency was declared by the Governor if the provider: 1. Suffered damage to its operation during the state of emergency. 2. Is currently licensed. 3. Does not have a provisional license. 4. Will be temporarily unable to provide services but is reasonably expected to resume services within 12 months. (b) An inactive license may be issued for a period not to exceed 12 months but may be renewed by the agency for up to 12 additional months upon demonstration to the agency of progress toward reopening. A request by a licensee for an inactive license or to extend the previously approved inactive period must be submitted in writing to the agency, accompanied by written justification for the inactive license, which states the beginning and ending dates of inactivity and includes a plan for the transfer of any clients to other providers and appropriate licensure fees. Upon agency approval, the licensee shall notify clients of any necessary discharge or transfer as required by authorizing statutes or applicable rules. The beginning of the inactive licensure period shall be the date the provider ceases operations. The end of the inactive period shall become the license expiration date, and all licensure fees must be current, must be paid in full, and may be prorated. Reactivation of an inactive license requires the prior approval by the agency of a renewal application, including payment of licensure fees and agency inspections indicating compliance with all requirements of this part and applicable rules and statutes. (4) . . . Licensees providing residential or inpatient services must utilize an online database	CZ830		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11943056	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 09/27/2023
NAME OF PROVIDER OR SUPPLIER SUNSHINE LIVING ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 676 UNION STREET DUNEDIN, FL 34698		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
CZ830	Continued From page 2 approved by the agency to report information to the agency regarding the provider's emergency status, planning, or operations. This Statute or Rule is not met as evidenced by: Based on record review and interview the facility failed to provide evidence of an approved Comprehensive Emergency Management Plan. (CEMP) Findings included: A review of the facility records on revealed no evidence of an approved or recent submission of a Comprehensive Emergency Management Plan (CEMP). An interview with the Administrator on at 1:18pm stated that CEMP was not submitted yet, because the fire inspection wasn't approved. Class III	CZ830			
A 000	Initial Comments A change of ownership and complaint survey (2023012770) was conducted at Sunshine Living ALF Corp. on Deficiencies were identified at the time of survey.	A 000			
A 055 SS=D	59A-36.008(6) FAC Medication - Storage and Disposal (6) MEDICATION STORAGE AND DISPOSAL. (a) In order to accommodate the needs and preferences of residents and to encourage residents to remain as independent as possible, residents may keep their medications, both	A 055			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11943056	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 09/27/2023
NAME OF PROVIDER OR SUPPLIER SUNSHINE LIVING ALF CORP		STREET ADDRESS, CITY, STATE, ZIP CODE 676 UNION STREET DUNEDIN, FL 34698		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 055	Continued From page 3 prescription and over-the-counter, in their possession both on or off the facility premises. Residents may also store their medication in their rooms or apartments if either the room is kept locked when residents are absent or the medication is stored in a secure place that is out of sight of other residents. (b) Both prescription and over-the-counter medications for residents must be centrally stored if: 1. The facility administers the medication; 2. The resident requests central storage. The facility must maintain a list of all medications being stored pursuant to such a request; 3. The medication is determined and documented by the health care provider to be hazardous if kept in the personal possession of the person for whom it is prescribed; 4. The resident fails to maintain the medication in a safe manner as described in this paragraph; 5. The facility determines that, because of physical arrangements and the conditions or habits of residents, the personal possession of medication by a resident poses a safety hazard to other residents, or 6. The facility's rules and regulations require central storage of medication and that policy has been provided to the resident before admission as required in Rule 59A-36.006, F.A.C. (c) Centrally stored medications must be: 1. Kept in a locked cabinet; locked cart; or other locked storage receptacle, room, or area at all times; 2. Located in an area free of dampness and abnormal temperature, except that a medication requiring refrigeration must be kept refrigerated. Refrigerated medications must be secured by being kept in a locked container within the refrigerator, by keeping the refrigerator locked, or	A 055		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11943056	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 09/27/2023
NAME OF PROVIDER OR SUPPLIER SUNSHINE LIVING ALF CORP		STREET ADDRESS, CITY, STATE, ZIP CODE 676 UNION STREET DUNEDIN, FL 34698			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 055	Continued From page 4 by keeping the area in which the refrigerator is located locked; 3. Accessible to staff responsible for filling pill-organizers, assisting with self-administration of medication, or administering medication. Such staff must have ready access to keys or codes to the medication storage areas at all times; and, 4. Kept separately from the medications of other residents and properly closed or sealed. (d) Medication that has been discontinued but has not expired must be returned to the resident or the resident's representative, as appropriate, or may be centrally stored by the facility for future use by the resident at the resident's request. If centrally stored by the facility, the discontinued medication must be stored separately from medication in current use, and the area in which it is stored must be marked "discontinued medication." Such medication may be reused if prescribed by the resident's health care provider. (e) When a resident's stay in the facility has ended, the administrator must return all medications to the resident, the resident's family, or the resident's guardian unless otherwise prohibited by law. If, after notification and waiting at least 15 days, the resident's medications are still at the facility, the medications are considered abandoned and may be disposed of in accordance with paragraph (f). (f) Medications that have been abandoned or have expired must be disposed of within 30 days of being determined abandoned or expired and the disposal must be documented in the resident's record. The medication may be taken to a pharmacist for disposal or may be destroyed by the administrator or designee with one witness. (g) Facilities that hold a Special-ALF permit issued by the Board of Pharmacy may return	A 055			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11943056	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 09/27/2023
NAME OF PROVIDER OR SUPPLIER SUNSHINE LIVING ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 676 UNION STREET DUNEDIN, FL 34698		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 055	Continued From page 5 dispensed medicinal drugs to the dispensing pharmacy pursuant to Rule 64B16-28.870, F.A.C. This Statute or Rule is not met as evidenced by: Based on observation and interview, the facility failed to ensure the medication cart containing medication was locked and secured for 1 of 1 medication carts observed. Findings included: On at 9:45am the medication cart was observed in the facility dining room with no locking mechanism to secure medications inside belonging to residents. During the interview with the Administrator on at 12:22pm, she agreed the cart should have had a lock on it. (Photographic evidence obtained) Class III	A 055			
A 200 SS=D	59A-36.025 FAC Emergency Environmental Control 59A-36.025 Emergency Environmental Control for Assisted Living Facilities. (1) DETAILED EMERGENCY ENVIRONMENTAL CONTROL PLAN. Each assisted living facility shall prepare a detailed plan ("plan") to serve as a supplement to its Comprehensive Emergency Management Plan, to address emergency environmental control in the event of the loss of primary electrical power in that assisted living facility which includes the following information: (a) The acquisition of a sufficient alternate power source such as a generator(s), maintained at the	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11943056	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 09/27/2023
NAME OF PROVIDER OR SUPPLIER SUNSHINE LIVING ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 676 UNION STREET DUNEDIN, FL 34698		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 6 assisted living facility, to ensure that current licensees of assisted living facilities will be equipped to ensure air temperatures will be maintained at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. 1. The required temperature must be maintained in an area or areas, determined by the assisted living facility, of sufficient size to maintain residents safely at all times and that is appropriate for resident care needs and life safety requirements. For planning purposes, no less than twenty (20) net square . . . per resident must be provided. The assisted living facility may use eighty percent (80%) of its licensed bed capacity as the number of residents to be used in the to determine the required square footage. This may include areas that are less than the entire assisted living facility if the assisted living facility's comprehensive emergency management plan includes allowing a resident to congregate when he or she desires in portions of the building where temperatures will be maintained and includes procedures for monitoring residents for signs of heat related injury as required by this rule. This rule does not prohibit a facility from acting as a receiving provider for evacuees when the conditions stated in section 408.821, F.S. and subsection 59A-36.019(5), F.A.C., are met. The plan shall include information regarding the area(s) within the assisted living facility where the required temperature will be maintained. 2. The alternate power source and fuel supply shall be located in an area(s) in accordance with local zoning and the Florida Building Code. 3. Each assisted living facility is unique in size; the types of care provided; the physical and mental capabilities and needs of residents; the	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11943056	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 09/27/2023
NAME OF PROVIDER OR SUPPLIER SUNSHINE LIVING ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 676 UNION STREET DUNEDIN, FL 34698		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 7 type, frequency, and amount of services and care offered; and staffing characteristics. Accordingly, this rule does not limit the types of systems or equipment that may be used to achieve temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. The plan shall include information regarding the systems and equipment that will be used by the assisted living facility and the fuel required to operate the systems and equipment. a. An assisted living facility in an evacuation zone pursuant to chapter 252, F. S. must maintain an alternative power source and fuel as required by this subsection at all times when the assisted living facility is occupied but is permitted to utilize a mobile generator(s) to enable portability if evacuation is necessary. b. Assisted living facilities located on a single campus with other facilities under common ownership, may share fuel, alternative power resources, and resident space available on the campus if such resources are sufficient to support the requirements of each facility's residents, as specified in this rule. Details regarding how resources will be shared and any necessary movement of residents must be clearly described in the emergency power plan. c. A multistory facility, whose comprehensive emergency management plan is to move residents to a higher floor during a flood or surge event, must place its alternative power source and all necessary additional equipment so it can safely operate in a location protected from flooding or storm surge damage. (b) The acquisition of sufficient fuel, and safe maintenance of that fuel at the facility, to ensure that in the event of the loss of primary electrical power there is sufficient fuel available for the	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11943056	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 09/27/2023
NAME OF PROVIDER OR SUPPLIER SUNSHINE LIVING ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 676 UNION STREET DUNEDIN, FL 34698		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 8 alternate power source to maintain temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours after the loss of primary electrical power during a declared state of emergency. The plan must include information regarding fuel source and fuel storage. 1. Facilities must store minimum amounts of fuel onsite as follows: a. A facility with a licensed capacity of 16 beds or less must store 48 hours of fuel onsite. b. A facility with a licensed capacity of 17 or more beds must store 72 hours of fuel onsite. 2. An assisted living facility located in an area in a declared state of emergency area pursuant to section 252.36, F.S. that may impact primary power delivery must secure ninety-six (96) hours of fuel. The assisted living facility may utilize portable fuel storage containers for the remaining fuel necessary for ninety-six (96) hours during the period of a declared state of emergency. 3. Piped natural gas is an allowable fuel source and meets the onsite fuel supply requirements under this rule. 4. If local ordinances or other regulations limit the amount of onsite fuel storage for the assisted living facility's location, then the assisted living facility must develop a plan that includes maximum onsite fuel storage allowable by the ordinance or regulation and a reliable method to obtain the maximum additional fuel at least 24 hours prior to depletion of onsite fuel. (c) The acquisition of services necessary to maintain, and test the equipment and its functions to ensure the safe and sufficient operation of the alternate power source maintained at the assisted living facility. (d) The acquisition and maintenance of a monoxide alarm.	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11943056	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 09/27/2023
NAME OF PROVIDER OR SUPPLIER SUNSHINE LIVING ALF CORP		STREET ADDRESS, CITY, STATE, ZIP CODE 676 UNION STREET DUNEDIN, FL 34698			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 9 (2) SUBMISSION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall submit its plan to the local emergency management agency for review within 30 days of the effective date of this rule. Assisted living facility plans previously submitted and approved pursuant to emergency Rule 58AER17-1 will require resubmission only if changes are made to the plan. (b) Each new assisted living facility shall submit the plan required under this rule prior to obtaining a license. (c) Each existing assisted living facility that undergoes any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of its systems or equipment affecting the facility's compliance with this rule shall amend its plan and submit it to the local emergency management agency for review and approval. (3) APPROVED PLANS. (a) Each assisted living facility must maintain a copy of its approved plan in a manner that makes the plan readily available at the licensee's physical address for review by a legally authorized entity. If the plan is maintained in an electronic format, assisted living facility staff must be readily available to access and produce the plan. For purposes of this section, "readily available" means the ability to immediately produce the plan, either in electronic or paper format, upon request. (b) Within two (2) business days of the approval of the plan from the local emergency management agency, the assisted living facility shall submit in writing proof of the approval to the Agency for Health Care Administration. (c) The assisted living facility shall submit a consumer-friendly summary of the emergency	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11943056	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 09/27/2023
NAME OF PROVIDER OR SUPPLIER SUNSHINE LIVING ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 676 UNION STREET DUNEDIN, FL 34698		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 10 power plan to the Agency. The Agency shall post the summary and notice of the approval and implementation of the assisted living facility emergency power plans on its website within ten (10) business days of the plan's approval by the local emergency management agency and update within ten (10) business days of implementation. (4) IMPLEMENTATION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall, no later than _____, have implemented the plan required under this rule. (b) The Agency shall allow an extension up to _____ to providers in compliance with paragraph (c) below and who can show delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes. Assisted living facilities shall notify the Agency that they will utilize the extension and keep the Agency apprised of progress on a quarterly basis to ensure there are no unnecessary delays. If an assisted living facility can show in its quarterly progress reports that unavoidable delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes will occur beyond the initial extension date, the assisted living facility may request a waiver pursuant to section 120.542, F.S. (c) During the extension period, an assisted living facility must make arrangements pending full implementation of its plan that provides the residents with an area or areas to congregate that meets the safe indoor air temperature requirements of subsection (1) (a) for a minimum of ninety-six (96) hours. 1. An assisted living facility not located in an evacuation zone must either have an alternative	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11943056	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 09/27/2023
NAME OF PROVIDER OR SUPPLIER SUNSHINE LIVING ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 676 UNION STREET DUNEDIN, FL 34698		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 11 power source onsite or have a contract in place for delivery of an alternative power source and fuel when requested. Within twenty-four (24) hours of the issuance of a state of emergency for an event that may impact primary power delivery for the area of the assisted living facility, it must have the alternative power source and no less than ninety-six (96) hours of fuel stored onsite. 2. An assisted living facility located in an evacuation zone pursuant to chapter 252, F.S. must either: a. Fully and safely evacuate its residents prior to the arrival of the event; or b. Have an alternative power source and no less than ninety-six (96) hours of fuel stored onsite, within twenty-four (24) hours of the issuance of a state of emergency for the area of the assisted living facility. (d) Each new assisted living facility shall implement the plan required under this rule prior to obtaining a license. (e) Existing assisted living facilities that undergo any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of the systems or equipment affecting the assisted living facility's compliance with this rule shall implement its amended plan concurrent with any such additions, modifications, alterations, refurbishment, renovations or reconstruction. (f) The Agency for Health Care Administration may request cooperation from the State Fire Marshal to conduct inspections to ensure implementation of the plan in compliance with this rule. (5) POLICIES AND PROCEDURES. (a) Each assisted living facility shall develop and implement written policies and procedures to ensure that the assisted living facility can	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11943056	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 09/27/2023
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SUNSHINE LIVING ALF CORP

**676 UNION STREET
DUNEDIN, FL 34698**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 12 effectively and immediately activate, operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. The procedures shall ensure that residents do not experience complications from fluctuations in air temperatures inside the facility. Procedures must address the care of residents occupying the facility during a declared state of emergency, specifically, a description of the methods to be used to mitigate the potential for heat related injury including: 1. The use of cooling devices and equipment; 2. The use of refrigeration and freezers to produce ice and appropriate temperatures for the maintenance of medicines requiring refrigeration; 3. Wellness checks by assisted living facility staff to monitor for signs of _____ and heat injury; and 4. A provision for obtaining medical intervention from emergency services for residents whose life safety is in jeopardy. (b) Each assisted living facility shall maintain the written policies and procedures in a manner that makes them readily available at the licensee's physical address for review by a legally authorized entity. If the policies and procedures are maintained in an electronic format, assisted living facility staff must be readily available to access the policies and procedures and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce the policies and procedures, either in electronic or paper format, upon request. (c) The written policies and procedures must be readily available for inspection by each resident; each resident's legal representative, designee, surrogate, guardian, attorney in fact, or case manager; each resident's estate; and such additional parties as authorized in writing or by	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11943056	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 09/27/2023
NAME OF PROVIDER OR SUPPLIER SUNSHINE LIVING ALF CORP		STREET ADDRESS, CITY, STATE, ZIP CODE 676 UNION STREET DUNEDIN, FL 34698			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 13 law. (6) REVOCATION OF LICENSE, FINES OR SANCTIONS. For a violation of any part of this rule, the Agency for Health Care Administration may seek any remedy authorized by chapter 429, part I, or chapter 408, part II, F.S., including, but not limited to, license revocation, license suspension, and the imposition of administrative fines. (7) COMPREHENSIVE EMERGENCY MANAGEMENT PLAN. (a) Assisted living facilities whose comprehensive emergency management plan is to evacuate must comply with this rule. (b) Each facility whose plan has been approved shall submit the plan as an addendum with any future submissions for approval of its comprehensive emergency management plan. (8) NOTIFICATION. (a) Within five (5) business days, each assisted living facility must notify in writing, unless permission for electronic communication has been granted, each resident and the resident's legal representative: 1. Upon submission of the plan to the local emergency management agency that the plan has been submitted for review and approval; 2. Upon final implementation of the plan by the assisted living facility. (b) Each assisted living facility must maintain a copy of each notification set forth in paragraph (a) above in a manner that makes each notification readily available at the licensee's physical address for review by a legally authorized entity. If the notifications are maintained in an electronic format, facility staff must be readily available to access and produce the notifications. For purposes of this section, "readily available" means the ability to immediately produce the	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11943056	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 09/27/2023
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SUNSHINE LIVING ALF CORP

**676 UNION STREET
DUNEDIN, FL 34698**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 14 notifications, either in electronic or paper format, upon request. This Statute or Rule is not met as evidenced by: Based on observation, and interview, the facility failed to maintain sufficient fuel at the facility to ensure that in the event of the loss of primary electrical power there is sufficient fuel readily available to maintain temperatures at or below 81 degrees for 9 of 9 sampled residents. Findings include: On at 11:02 AM, an environmental safety tour was conducted with the facility Administrator. No backup fuel was observed on site and the generator containing fuel was observed stored next to the facility. An interview was conducted with the Administrator on at 1:18 PM. The Administrator confirmed that the facility did not have any backup fuel stored on site. The Administrator also agreed the generator had 15 gallons of fuel inside during the observation and confirmed the portable generator should be stored in a more secure setting. (Photographic Evidence Obtained) Class III	A 200		