Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967677	A. BUILDING: _____ B. WING _____	08/06/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VILLA SERENA V	2750 N W 6 STREET MIAMI, FL 33125

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 000	Initial Comments A Standard survey with limited mental health was conducted at Villa Serena V on . The provider had deficiencies identified at the time of the survey.	A 000		
A 160 SS=D	59A-36.015(1) FAC Records - Facility 59A-36.015 Records. The facility must maintain required records in a manner that makes such records readily available at the licensee's physical address for review by a legally authorized entity. If records are maintained in an electronic format, facility staff must be readily available to access the data and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce documents, records, or other such data, either in electronic or paper format, upon request. (1) FACILITY RECORDS. Facility records must include: (a) The facility's license displayed in a conspicuous and public place within the facility. (b) An up-to-date admission and discharge log listing the names of all residents and each resident's: 1. Date of admission, the facility or place from which the resident was admitted, and if applicable, a notation indicating that the resident was admitted with a , ; and, 2. Date of discharge, reason for discharge, and identification of the facility or home address to which the resident was discharged. Readmission of a resident to the facility after discharge requires a new entry in the log. Discharge of a resident is not required if the facility is holding a bed for a resident who is out of the facility but intending to return pursuant to Rule 59A-36.018, F.A.C. If the resident dies while in the care of the	A 160		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967677	A. BUILDING: _____ B. WING _____	08/06/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VILLA SERENA V	2750 N W 6 STREET MIAMI, FL 33125

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 160	Continued From page 1 facility, the log must indicate the date of . (c) A log listing the names of all temporary emergency placement and respite care residents if not included on the log described in paragraph (b). (d) The facility's emergency management plan, with documentation of review and approval by the county emergency management agency, as described in Rule 59A-36.019, F.A.C., that must be readily available by facility staff. (e) The facility's liability insurance policy required in Rule 59A-36.013, F.A.C. (f) For facilities that have a surety bond, a copy of the surety bond currently in effect as required by Rule 59A-36.013, F.A.C. (g) The admission package presented to new or prospective residents (less the resident's contract) described in Rule 59A-36.006, F.A.C. (h) If the facility advertises that it provides special care for persons with 's or related , a copy of all such facility advertisements as required by Section 429.177, F.S. (i) A grievance procedure for receiving and responding to resident complaints and recommendations as described in Rule 59A-36.007, F.A.C. (j) All food service records required in Rule 59A-36.012, F.A.C., including menus planned and served and county health department inspection reports. Facilities that contract for food services, must include a copy of the contract for food services and the food service contractor's license or certificate to operate. (k) All fire safety inspection reports issued by the local authority or the State Fire Marshal pursuant to Section 429.435, F.S., and rule Chapter 69A-40, F.A.C., issued within the last 2 years. (l) All sanitation inspection reports issued by the	A 160		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967677	A. BUILDING: _____ B. WING _____	08/06/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VILLA SERENA V	2750 N W 6 STREET MIAMI, FL 33125

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 160	Continued From page 2 county health department pursuant to Section 381.031, F.S., and Chapter 64E-12, F.A.C., issued within the last 2 years. (m) Pursuant to Section 429.35, F.S., all completed survey, inspection and complaint investigation reports, and notices of sanctions and moratoriums issued by the agency within the last 5 years. (n) The facility's resident elopement response policies and procedures. (o) The facility's documented resident elopement response drills. (p) The facility's policies and procedures pursuant to subsection 59A-36.007(10), F.A.C.; (q) The facility's . . . . prevention policies and procedures; (r) The facility's medication practices; (s) The facility's policy on physical ; (t) The facility's policy on assistive devices; (u) The facility's policy on third-party providers; (v) The facility's policy on visitation pursuant to Section 408.823(2)(a), F.S.; (w) For facilities licensed as limited mental health, extended congregate care, or limited nursing services, records required as stated in Rules 59A-36.020, 59A-36.021 and 59A-36.022, F.A.C., respectively. This Statute or Rule is not met as evidenced by: Based on record review and interview, the facility failed to maintain an admission discharge log which reflected the discharge address for residents who left the facility. Findings included: A review of the admission and discharged log revealed discharge without addresses listed to where residents were discharge to.	A 160		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967677	A. BUILDING: _____ B. WING _____	08/06/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VILLA SERENA V	2750 N W 6 STREET MIAMI, FL 33125

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 160	Continued From page 3 In an interview on at 12:35 PM the Assistant Administrator acknowledged the admission, and discharge did not have the addresses. Class III	A 160		
A 200 SS=D	59A-36.025 FAC Emergency Environmental Control 59A-36.025 Emergency Environmental Control for Assisted Living Facilities. (1) DETAILED EMERGENCY ENVIRONMENTAL CONTROL PLAN. Each assisted living facility shall prepare a detailed plan ("plan") to serve as a supplement to its Comprehensive Emergency Management Plan, to address emergency environmental control in the event of the loss of primary electrical power in that assisted living facility which includes the following information: (a) The acquisition of a sufficient alternate power source such as a generator(s), maintained at the assisted living facility, to ensure that current licensees of assisted living facilities will be equipped to ensure air temperatures will be maintained at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. 1. The required temperature must be maintained in an area or areas, determined by the assisted living facility, of sufficient size to maintain residents safely at all times and that is appropriate for resident care needs and life safety requirements. For planning purposes, no less than twenty (20) net square per resident must be provided. The assisted living facility may use eighty percent (80%) of its licensed bed capacity as the number of residents to be used in the to determine the required square	A 200		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967677	A. BUILDING: _____ B. WING _____	08/06/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VILLA SERENA V	2750 N W 6 STREET MIAMI, FL 33125

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 4	A 200		

footage. This may include areas that are less than the entire assisted living facility if the assisted living facility's comprehensive emergency management plan includes allowing a resident to congregate when he or she desires in portions of the building where temperatures will be maintained and includes procedures for monitoring residents for signs of heat related injury as required by this rule. This rule does not prohibit a facility from acting as a receiving provider for evacuees when the conditions stated in Section 408.821, F.S. and subsection 59A-36.019(5), F.A.C., are met. The plan shall include information regarding the area(s) within the assisted living facility where the required temperature will be maintained.
2. The alternate power source and fuel supply shall be located in an area(s) in accordance with local zoning and the Florida Building Code.
3. Each assisted living facility is unique in size; the types of care provided; the physical and mental capabilities and needs of residents; the type, frequency, and amount of services and care offered; and staffing characteristics. Accordingly, this rule does not limit the types of systems or equipment that may be used to achieve temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. The plan shall include information regarding the systems and equipment that will be used by the assisted living facility and the fuel required to operate the systems and equipment.
a. An assisted living facility in an evacuation zone pursuant to Chapter 252, F, S. must maintain an alternative power source and fuel as required by this subsection at all times when the assisted living facility is occupied but is permitted to utilize a mobile generator(s) to enable portability if

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967677	A. BUILDING: _____ B. WING _____	08/06/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VILLA SERENA V	2750 N W 6 STREET MIAMI, FL 33125

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 5 evacuation is necessary. b. Assisted living facilities located on a single campus with other facilities under common ownership, may share fuel, alternative power resources, and resident space available on the campus if such resources are sufficient to support the requirements of each facility's residents, as specified in this rule. Details regarding how resources will be shared and any necessary movement of residents must be clearly described in the emergency power plan. c. A multistory facility, whose comprehensive emergency management plan is to move residents to a higher floor during a flood or surge event, must place its alternative power source and all necessary additional equipment so it can safely operate in a location protected from flooding or storm surge damage. (b) The acquisition of sufficient fuel, and safe maintenance of that fuel at the facility, to ensure that in the event of the loss of primary electrical power there is sufficient fuel available for the alternate power source to maintain temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours after the loss of primary electrical power during a declared state of emergency. The plan must include information regarding fuel source and fuel storage. 1. Facilities must store minimum amounts of fuel onsite as follows: a. A facility with a licensed capacity of 16 beds or less must store 48 hours of fuel onsite. b. A facility with a licensed capacity of 17 or more beds must store 72 hours of fuel onsite. 2. An assisted living facility located in an area in a declared state of emergency area pursuant to Section 252.36, F.S. that may impact primary power delivery must secure ninety-six (96) hours	A 200		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967677	A. BUILDING: _____ B. WING _____	08/06/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VILLA SERENA V	2750 N W 6 STREET MIAMI, FL 33125

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 6 of fuel. The assisted living facility may utilize portable fuel storage containers for the remaining fuel necessary for ninety-six (96) hours during the period of a declared state of emergency. 3. Piped natural gas is an allowable fuel source and meets the onsite fuel supply requirements under this rule. 4. If local ordinances or other regulations limit the amount of onsite fuel storage for the assisted living facility's location, then the assisted living facility must develop a plan that includes maximum onsite fuel storage allowable by the ordinance or regulation and a reliable method to obtain the maximum additional fuel at least 24 hours prior to depletion of onsite fuel. (c) The acquisition of services necessary to maintain, and test the equipment and its functions to ensure the safe and sufficient operation of the alternate power source maintained at the assisted living facility. (d) The acquisition and maintenance of a monoxide alarm. (2) SUBMISSION OF THE PLAN. (a) Each new assisted living facility shall submit the plan required under this rule prior to obtaining a license. (b) Each existing assisted living facility that undergoes any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of its systems or equipment affecting the facility's compliance with this rule shall amend its plan and submit it to the county emergency management agency for review and approval. (3) APPROVED PLANS. (a) Each assisted living facility must maintain a copy of its approved plan in a manner that makes the plan readily available at the licensee's physical address for review by a legally	A 200		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967677	A. BUILDING: _____ B. WING _____	08/06/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VILLA SERENA V	2750 N W 6 STREET MIAMI, FL 33125

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 7 authorized entity. If the plan is maintained in an electronic format, assisted living facility staff must be readily available to access and produce the plan. For purposes of this section, "readily available" means the ability to immediately produce the plan, either in electronic or paper format, upon request. (b) Within 30 days of the approval of the plan from the county emergency management agency, the assisted living facility shall submit in writing proof of the approval to the Agency for Health Care Administration to assistedliving@ahca.myflorida.com. (c) The assisted living facility shall submit a consumer-friendly summary of the emergency power plan to the Agency. The Agency shall post the summary and notice of the approval and implementation of the assisted living facility emergency power plans on its website within ten (10) business days of the plan's approval by the county emergency management agency and update within ten (10) business days of implementation. (4) IMPLEMENTATION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall, no later than . , have implemented the plan required under this rule. (b) Each new assisted living facility shall implement the plan required under this rule prior to obtaining a license. (c) Existing assisted living facilities that undergo any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of the systems or equipment affecting the assisted living facility's compliance with this rule shall implement its amended plan concurrent with any such additions, modifications, alterations, refurbishment, renovations or	A 200		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967677	A. BUILDING: _____ B. WING _____	08/06/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VILLA SERENA V	2750 N W 6 STREET MIAMI, FL 33125

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 8 reconstruction. (5) POLICIES AND PROCEDURES. (a) Each assisted living facility shall develop and implement written policies and procedures to ensure that the assisted living facility can effectively and immediately activate, operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. The procedures shall ensure that residents do not experience complications from fluctuations in air temperatures inside the facility. Procedures must address the care of residents occupying the facility during a declared state of emergency, specifically, a description of the methods to be used to mitigate the potential for heat related injury including: 1. The use of cooling devices and equipment; 2. The use of refrigeration and freezers to produce ice and appropriate temperatures for the maintenance of medicines requiring refrigeration; 3. Wellness checks by assisted living facility staff to monitor for signs of , and heat injury; and 4. A provision for obtaining medical intervention from emergency services for residents whose life safety is in jeopardy. (b) Each assisted living facility shall maintain the written policies and procedures in a manner that makes them readily available at the licensee's physical address for review by a legally authorized entity. If the policies and procedures are maintained in an electronic format, assisted living facility staff must be readily available to access the policies and procedures and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce the policies and procedures, either in electronic or paper format, upon request. (c) The written policies and procedures must be	A 200		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967677	A. BUILDING: _____ B. WING _____	08/06/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VILLA SERENA V	2750 N W 6 STREET MIAMI, FL 33125

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 9 readily available for inspection by each resident; each resident's legal representative, designee, surrogate, guardian, attorney in fact, or case manager; each resident's estate; and such additional parties as authorized in writing or by law. (6) REVOCATION OF LICENSE, FINES OR SANCTIONS. For a violation of any part of this rule, the Agency for Health Care Administration may seek any remedy authorized by Chapter 429, Part I, or Chapter 408, Part II, F.S., including, but not limited to, license revocation, license suspension, and the imposition of administrative fines. (7) COMPREHENSIVE EMERGENCY MANAGEMENT PLAN. (a) Assisted living facilities whose comprehensive emergency management plan is to evacuate must comply with this rule. (b) Each facility whose plan has been approved shall submit the plan as an addendum with any future submissions for approval of its comprehensive emergency management plan. (8) NOTIFICATION. (a) Within five (5) business days, each assisted living facility must notify in writing, unless permission for electronic communication has been granted, each resident and the resident's legal representative: 1. Upon the initial submission of the plan to the county emergency management agency that the plan has been submitted for review and approval; 2. Upon final implementation of the plan by the assisted living facility. 3. Annual submissions and approvals of the plan do not require notification to residents or their legal representatives unless a significant modification as defined in Rule 59A-36.019, F.A.C., has been made to the plan.	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967677	A. BUILDING: _____ B. WING _____	08/06/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VILLA SERENA V	2750 N W 6 STREET MIAMI, FL 33125

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 10 (b) Each assisted living facility must maintain a copy of each notification set forth in paragraph (a) above in a manner that makes each notification readily available at the licensee's physical address for review by a legally authorized entity. If the notifications are maintained in an electronic format, facility staff must be readily available to access and produce the notifications. For purposes of this section, "readily available" means the ability to immediately produce the notifications, either in electronic or paper format, upon request. This Statute or Rule is not met as evidenced by: Based on observations, and interview, the facility failed be able to test the monoxide alarm in the facility. Findings included: On at 8:20 AM observed a monoxide alarm, mounted on the wall in dining area and fire alarm on the ceiling near it. Staff B and C were asked to test the monoxide alarm and were unable to identify and test it. Instead, the fire alarm was identified and tested as the monoxide alarm. On at 12:36 PM the owner stated, "we have a maintenance guy that tests it for the facility, and the caregivers got it mixed up." Class III	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967677	A. BUILDING: _____ B. WING _____	08/06/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VILLA SERENA V	2750 N W 6 STREET MIAMI, FL 33125

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
ZZ875 SS=D	430.5025(4 &) / ; Training (4) Employees of covered providers must complete the following training for 's and related forms of : (a) Upon beginning employment, each employee must receive basic written information about interacting with persons who have 's or related forms of . (b) Within 30 days after beginning employment, each employee who provides personal care to or has regular contact with participants, patients, or residents must complete a 1-hour training program provided by the department. 1. The department shall provide training that is available online at no cost. The 1-hour training program shall contain information on understanding the basics about the most common forms of , how to identify the signs and symptoms of , and skills for communicating and interacting with persons with ' s or related forms of . A record of the completion of the training program must be made available to the covered provider which identifies the training curricula, the name of the employee, and the date of completion. 2. A covered provider must maintain a record of the employee's completion of the training program and, upon written request of the employee, provide the employee with a copy of the record of completion consistent with the employer's written policies. 3. An employee who has completed the training required in this subsection is not required to repeat the program upon changing employment to a different covered provider. (c) Within 7 months after beginning employment for a home health agency, nurse registry, or companion or homemaker service provider, each	ZZ875		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967677	A. BUILDING: _____ B. WING _____	08/06/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VILLA SERENA V	2750 N W 6 STREET MIAMI, FL 33125

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
ZZ875	Continued From page 1	ZZ875		

employee who provides personal care must complete 2 hours of training in addition to the training required in paragraphs (a) and (b). The additional training must include, but is not limited to, behavior management, promoting the person ' s independence in activities of daily living, and skills in working with families and caregivers.
(d) Within 7 months after beginning employment for a nursing home, an assisted living facility, an adult family-care home, or an adult day care center, each employee who provides personal care must complete 3 hours of training in addition to the training required in paragraphs (a) and (b). The additional training must include, but is not limited to, behavior management, promoting the person's independence in activities of daily living, skills in working with families and caregivers, group and individual activities, maintaining an appropriate environment, and ethical issues.
(e) For an assisted living facility, adult family-care home, or adult day care center that advertises and provides, or is designated to provide, specialized care for persons with 's or related forms of , in addition to the training specified in paragraphs (a) and (b), employees must receive the following training:
1. Within 3 months after beginning employment, each employee who provides personal care to or has regular contact with the residents or participants must complete the additional 3 hours of training as provided in paragraph (d).
2. Within 6 months after beginning employment, each employee who provides personal care must complete an additional 4 hours of -specific training. Such training must include, but is not limited to, understanding and related forms of , the stages of 's , communication strategies, medical information,

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967677	A. BUILDING: _____ B. WING _____	08/06/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VILLA SERENA V	2750 N W 6 STREET MIAMI, FL 33125

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
ZZ875	Continued From page 2 and stress management. 3. Thereafter, each employee who provides personal care must participate in at least 4 hours of continuing education each calendar year through contact hours, on-the-job training, or electronic learning . For this subparagraph, the term "on-the-job training" means a form of direct coaching in which a facility administrator or his or her designee instructs an employee who provides personal care with guidance, support, or -on experience to help develop and refine the employee's skills for caring for a person with 's or a related form of . The continuing education must cover at least one of the topics included in the -specific training in which the employee has not received previous training in the previous calendar year. The continuing education may be fulfilled and documented in a minimum of one quarter-hour increments through on-the-job training of the employee by a facility administrator or his or her designee or by an electronic learning chosen by the facility administrator. On-the-job training may not account for more than 2 hours of continuing education each calendar year. (f)1. An employee provided, assigned, or referred by a health care services pool must complete the training required in paragraph (c), paragraph (d), or paragraph (e) that is applicable to the covered provider and the position in which the employee will be working. The documentation verifying the completed training and continuing education of the employee, if applicable, must be provided to the covered provider upon request. 2. A health care services pool must verify and maintain documentation as required under s. 400.980(5) before providing, assigning, or referring an employee to a covered provider.	ZZ875		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967677	A. BUILDING: _____ B. WING _____	08/06/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VILLA SERENA V	2750 N W 6 STREET MIAMI, FL 33125

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
ZZ875	Continued From page 3 (7) For a certified nursing assistant as defined in s. 464.201, training hours completed as required under this section may count toward the total hours of training required to maintain certification as a nursing assistant. (8) For a health care practitioner as defined in s. 456.001, training hours completed as required under this section may count toward the total hours of continuing education required by that practitioner's licensing board. (9) Each person employed, , or referred to provide services before , , must complete the training required in this section before , . Proof of completion of equivalent training completed before , , shall substitute for the training required in subsection (4). Each person employed, , or referred to provide services on or after , , may complete training using approved curriculum under paragraph (5)(d) until the effective date of the rules adopted by the department under subsection (6). This Statute or Rule is not met as evidenced by: Based on interview and record review, the facility failed to ensure one out of three (Administrator) sampled staff completed the one-hour training within 30 days after beginning employment training program provided by the department and three out of three (Administrator, Staff B and Staff C) sampled staff had completed the three hours of training in 's and related forms of training within seven months after beginning employment. Findings included: On at 12:30 PM, the facility Assistant Administrator acknowledged after review of	ZZ875		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967677	A. BUILDING: _____ B. WING _____	08/06/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VILLA SERENA V	2750 N W 6 STREET MIAMI, FL 33125

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
ZZ875	Continued From page 4 personnel files that the Administrator, Staff B and Staff C did not have the training in 's and related forms of . A review of the facility personnel files revealed the Administrator had not completed the one-hour and related forms of training provided by the department. A review of staff records revealed that Administrator hired on , Staff B hired on , and Staff C was hired on did not have the additional three-hour and related forms of training within seven months after beginning employed. Class III	ZZ875		