Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967009	A. BUILDING: _____ B. WING _____	R 08/17/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VEREDA NUEVA	12412 SW 215 LANE MIAMI, FL 33177

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 000}	Initial Comments A revisit survey was conducted at Vereda Nueva on . Deficiencies were identified at the time of the survey.	{A 000}		
{A 081} SS=F	429.52(1 & 7) FS; 59A-36.011( ) FAC Training - Staff In-Service 429.52 (1)(a) Each new assisted living facility employee who has not previously completed core training must attend a preservice orientation provided by the facility before interacting with residents. The preservice orientation must be at least 2 hours in duration and cover topics that help the employee provide responsible care and respond to the needs of facility residents. Upon completion, the employee and the administrator of the facility must sign a statement that the employee completed the required preservice orientation. The facility must keep the signed statement in the employee ' s personnel record. (b) Each assisted living facility employee must complete the training required under s. 430.5025. However, an employee of an assisted living facility licensed as a limited mental health facility under s. 429.075 is exempt from the training requirements under s. 430.5025(4)(d). (c) If an assisted living facility employee completes the 1-hour training required under s. 430.5025 before interacting with residents, such training may count toward the 2 hours of preservice orientation required under paragraph (a). (7) Facility staff shall participate in inservice training relevant to their job duties as specified by agency rule. Topics covered during the preservice orientation are not required to be repeated during inservice training. A single certificate of	{A 081}		

AHCA Form 3020-0001
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE TITLE (X6) DATE

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967009	A. BUILDING: _____ B. WING _____	R 08/17/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VEREDA NUEVA	12412 SW 215 LANE MIAMI, FL 33177

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 081}	Continued From page 1 completion that covers all required inservice training topics may be issued to a participating staff member if the training is provided in a single training course. 59A-36.011 (2) STAFF PRESERVICE ORIENTATION. (a) Facilities must provide a preservice orientation of at least 2 hours to all new assisted living facility employees who have not previously completed core training as detailed in subsection (1). (b) New staff must complete the preservice orientation prior to interacting with residents. (c) Once complete, the employee and the facility administrator must sign a statement that the employee completed the preservice orientation which must be kept in the employee's personnel record. (d) In addition to topics that may be chosen by the facility administrator, the preservice orientation must cover: 1. Resident's rights; and, 2. The facility's license type and services offered by the facility. (3) STAFF IN-SERVICE TRAINING. Facility administrators or managers shall provide or arrange for the following in-service training to facility staff: (a) Staff who provide direct care to residents, other than nurses, certified nursing assistants, or home health aides trained in accordance with rule 59A-8.0095, F.A.C., must receive a minimum of 1 hour in-service training in control, including universal precautions and facility sanitation procedures, before providing personal care to residents. The facility must use its control policies and procedures when	{A 081}		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967009	A. BUILDING: _____ B. WING _____	R 08/17/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VEREDA NUEVA	12412 SW 215 LANE MIAMI, FL 33177

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 081}	Continued From page 2 offering this training. Documentation of compliance with the staff training requirements of 29 CFR 1910.1030, relating to borne , , may be used to meet this requirement. (b) Staff who provide direct care to residents must receive a minimum of 1 hour in-service training within 30 days of employment that covers the following subjects: 1. Reporting adverse incidents. 2. Facility emergency procedures including chain-of-command and staff roles relating to emergency evacuation. (c) Staff who provide direct care to residents, who have not taken the core training program, shall receive a minimum of 1 hour in-service training within 30 days of employment that covers the following subjects: 1. Resident rights in an assisted living facility. 2. Recognizing and reporting resident , neglect, and , . The facility must use its prevention policies and procedures when offering this training. (d) Staff who provide direct care to residents, other than nurses, CNAs, or home health aides trained in accordance with rule 59A-8.0095, F.A.C., must receive 3 hours of in-service training within 30 days of employment that covers the following subjects: 1. Resident behavior and needs. 2. Providing assistance with the activities of daily living. (e) Staff who prepare or serve food, who have not taken the assisted living facility core training must receive a minimum of 1-hour-in-service training within 30 days of employment in safe food handling practices. (f) All facility staff shall receive in-service training regarding the facility's resident elopement	{A 081}		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967009	A. BUILDING: _____ B. WING _____	R 08/17/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VEREDA NUEVA	12412 SW 215 LANE MIAMI, FL 33177

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 081}	Continued From page 3 response policies and procedures within thirty (30) days of employment. 1. All facility staff shall be provided with a copy of the facility's resident elopement response policies and procedures. 2. All facility staff shall demonstrate an understanding and competency in the implementation of the elopement response policies and procedures. This Statute or Rule is not met as evidenced by: Based on record review and interview, the facility failed to ensure that one out of five sampled staff (D) had a preservice orientation of at least two hours. Findings Included: A review of Staff D's (caregiver) employee records showed no documentation of two-hour preservice orientation training. Staff D's hire date was . During an interview on at 7:50 AM Staff E (owner) stated that they must have gotten misplaced. Class III	{A 081}		
{A 200} SS=E	59A-36.025 FAC Emergency Environmental Control 59A-36.025 Emergency Environmental Control for Assisted Living Facilities.	{A 200}		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967009	A. BUILDING: _____ B. WING _____	R 08/17/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VEREDA NUEVA	12412 SW 215 LANE MIAMI, FL 33177

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 200}	Continued From page 4 (1) DETAILED EMERGENCY ENVIRONMENTAL CONTROL PLAN. Each assisted living facility shall prepare a detailed plan ("plan") to serve as a supplement to its Comprehensive Emergency Management Plan, to address emergency environmental control in the event of the loss of primary electrical power in that assisted living facility which includes the following information: (a) The acquisition of a sufficient alternate power source such as a generator(s), maintained at the assisted living facility, to ensure that current licensees of assisted living facilities will be equipped to ensure air temperatures will be maintained at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. 1. The required temperature must be maintained in an area or areas, determined by the assisted living facility, of sufficient size to maintain residents safely at all times and that is appropriate for resident care needs and life safety requirements. For planning purposes, no less than twenty (20) net square per resident must be provided. The assisted living facility may use eighty percent (80%) of its licensed bed capacity as the number of residents to be used in the to determine the required square footage. This may include areas that are less than the entire assisted living facility if the assisted living facility's comprehensive emergency management plan includes allowing a resident to congregate when he or she desires in portions of the building where temperatures will be maintained and includes procedures for monitoring residents for signs of heat related injury as required by this rule. This rule does not prohibit a facility from acting as a receiving provider for evacuees when the conditions stated in Section 408.821, F.S. and subsection	{A 200}		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967009	A. BUILDING: _____ B. WING _____	R 08/17/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VEREDA NUEVA	12412 SW 215 LANE MIAMI, FL 33177

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 200}	Continued From page 5 59A-36.019(5), F.A.C., are met. The plan shall include information regarding the area(s) within the assisted living facility where the required temperature will be maintained. 2. The alternate power source and fuel supply shall be located in an area(s) in accordance with local zoning and the Florida Building Code. 3. Each assisted living facility is unique in size; the types of care provided; the physical and mental capabilities and needs of residents; the type, frequency, and amount of services and care offered; and staffing characteristics. Accordingly, this rule does not limit the types of systems or equipment that may be used to achieve temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. The plan shall include information regarding the systems and equipment that will be used by the assisted living facility and the fuel required to operate the systems and equipment. a. An assisted living facility in an evacuation zone pursuant to Chapter 252, F, S. must maintain an alternative power source and fuel as required by this subsection at all times when the assisted living facility is occupied but is permitted to utilize a mobile generator(s) to enable portability if evacuation is necessary. b. Assisted living facilities located on a single campus with other facilities under common ownership, may share fuel, alternative power resources, and resident space available on the campus if such resources are sufficient to support the requirements of each facility's residents, as specified in this rule. Details regarding how resources will be shared and any necessary movement of residents must be clearly described in the emergency power plan. c. A multistory facility, whose comprehensive	{A 200}		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967009	A. BUILDING: _____ B. WING _____	R 08/17/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VEREDA NUEVA	12412 SW 215 LANE MIAMI, FL 33177

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 200}	Continued From page 6	{A 200}		

emergency management plan is to move residents to a higher floor during a flood or surge event, must place its alternative power source and all necessary additional equipment so it can safely operate in a location protected from flooding or storm surge damage.
(b) The acquisition of sufficient fuel, and safe maintenance of that fuel at the facility, to ensure that in the event of the loss of primary electrical power there is sufficient fuel available for the alternate power source to maintain temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours after the loss of primary electrical power during a declared state of emergency. The plan must include information regarding fuel source and fuel storage.
1. Facilities must store minimum amounts of fuel onsite as follows:
a. A facility with a licensed capacity of 16 beds or less must store 48 hours of fuel onsite.
b. A facility with a licensed capacity of 17 or more beds must store 72 hours of fuel onsite.
2. An assisted living facility located in an area in a declared state of emergency area pursuant to Section 252.36, F.S. that may impact primary power delivery must secure ninety-six (96) hours of fuel. The assisted living facility may utilize portable fuel storage containers for the remaining fuel necessary for ninety-six (96) hours during the period of a declared state of emergency.
3. Piped natural gas is an allowable fuel source and meets the onsite fuel supply requirements under this rule.
4. If local ordinances or other regulations limit the amount of onsite fuel storage for the assisted living facility's location, then the assisted living facility must develop a plan that includes maximum onsite fuel storage allowable by the

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967009	A. BUILDING: _____ B. WING _____	R 08/17/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VEREDA NUEVA	12412 SW 215 LANE MIAMI, FL 33177

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 200}	Continued From page 7 ordinance or regulation and a reliable method to obtain the maximum additional fuel at least 24 hours prior to depletion of onsite fuel. (c) The acquisition of services necessary to maintain, and test the equipment and its functions to ensure the safe and sufficient operation of the alternate power source maintained at the assisted living facility. (d) The acquisition and maintenance of a monoxide alarm. (2) SUBMISSION OF THE PLAN. (a) Each new assisted living facility shall submit the plan required under this rule prior to obtaining a license. (b) Each existing assisted living facility that undergoes any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of its systems or equipment affecting the facility's compliance with this rule shall amend its plan and submit it to the county emergency management agency for review and approval. (3) APPROVED PLANS. (a) Each assisted living facility must maintain a copy of its approved plan in a manner that makes the plan readily available at the licensee's physical address for review by a legally authorized entity. If the plan is maintained in an electronic format, assisted living facility staff must be readily available to access and produce the plan. For purposes of this section, "readily available" means the ability to immediately produce the plan, either in electronic or paper format, upon request. (b) Within 30 days of the approval of the plan from the county emergency management agency, the assisted living facility shall submit in writing proof of the approval to the Agency for Health Care Administration to	{A 200}		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967009	A. BUILDING: _____ B. WING _____	R 08/17/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VEREDA NUEVA	12412 SW 215 LANE MIAMI, FL 33177

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 200}	Continued From page 8 assistedliving@ahca.myflorida.com. (c) The assisted living facility shall submit a consumer-friendly summary of the emergency power plan to the Agency. The Agency shall post the summary and notice of the approval and implementation of the assisted living facility emergency power plans on its website within ten (10) business days of the plan's approval by the county emergency management agency and update within ten (10) business days of implementation. (4) IMPLEMENTATION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall, no later than . , have implemented the plan required under this rule. (b) Each new assisted living facility shall implement the plan required under this rule prior to obtaining a license. (c) Existing assisted living facilities that undergo any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of the systems or equipment affecting the assisted living facility's compliance with this rule shall implement its amended plan concurrent with any such additions, modifications, alterations, refurbishment, renovations or reconstruction. (5) POLICIES AND PROCEDURES. (a) Each assisted living facility shall develop and implement written policies and procedures to ensure that the assisted living facility can effectively and immediately activate, operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. The procedures shall ensure that residents do not experience complications from fluctuations in air temperatures inside the facility. Procedures must address the care of	{A 200}		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967009	A. BUILDING: _____ B. WING _____	R 08/17/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VEREDA NUEVA	12412 SW 215 LANE MIAMI, FL 33177

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 200}	Continued From page 9	{A 200}		

residents occupying the facility during a declared state of emergency, specifically, a description of the methods to be used to mitigate the potential for heat related injury including:
1. The use of cooling devices and equipment;
2. The use of refrigeration and freezers to produce ice and appropriate temperatures for the maintenance of medicines requiring refrigeration;
3. Wellness checks by assisted living facility staff to monitor for signs of , and heat injury; and
4. A provision for obtaining medical intervention from emergency services for residents whose life safety is in jeopardy.
(b) Each assisted living facility shall maintain the written policies and procedures in a manner that makes them readily available at the licensee's physical address for review by a legally authorized entity. If the policies and procedures are maintained in an electronic format, assisted living facility staff must be readily available to access the policies and procedures and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce the policies and procedures, either in electronic or paper format, upon request.
(c) The written policies and procedures must be readily available for inspection by each resident; each resident's legal representative, designee, surrogate, guardian, attorney in fact, or case manager; each resident's estate; and such additional parties as authorized in writing or by law.
(6) REVOCATION OF LICENSE, FINES OR SANCTIONS. For a violation of any part of this rule, the Agency for Health Care Administration may seek any remedy authorized by Chapter 429, Part I, or Chapter 408, Part II, F.S., including, but not limited to, license revocation, license

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967009	A. BUILDING: _____ B. WING _____	R 08/17/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VEREDA NUEVA	12412 SW 215 LANE MIAMI, FL 33177

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 200}	Continued From page 10 suspension, and the imposition of administrative fines. (7) COMPREHENSIVE EMERGENCY MANAGEMENT PLAN. (a) Assisted living facilities whose comprehensive emergency management plan is to evacuate must comply with this rule. (b) Each facility whose plan has been approved shall submit the plan as an addendum with any future submissions for approval of its comprehensive emergency management plan. (8) NOTIFICATION. (a) Within five (5) business days, each assisted living facility must notify in writing, unless permission for electronic communication has been granted, each resident and the resident's legal representative: 1. Upon the initial submission of the plan to the county emergency management agency that the plan has been submitted for review and approval; 2. Upon final implementation of the plan by the assisted living facility. 3. Annual submissions and approvals of the plan do not require notification to residents or their legal representatives unless a significant modification as defined in Rule 59A-36.019, F.A.C., has been made to the plan. (b) Each assisted living facility must maintain a copy of each notification set forth in paragraph (a) above in a manner that makes each notification readily available at the licensee's physical address for review by a legally authorized entity. If the notifications are maintained in an electronic format, facility staff must be readily available to access and produce the notifications. For purposes of this section, "readily available" means the ability to immediately produce the notifications, either in electronic or paper format, upon request.	{A 200}		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	AL11967009	A. BUILDING: _____ B. WING _____	R 08/17/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
VEREDA NUEVA	12412 SW 215 LANE MIAMI, FL 33177

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 200}	Continued From page 11 This Statute or Rule is not met as evidenced by: Based on observation and interviews, that facility failed to properly maintain alternative power source. Findings included Observation on at 8:00 AM Staff D attempted to start the generator and when she had connected it to the propane gas an audible noise of leaking propane was heard. Further observation showed that one of the fuel hoses on the generator was leaking propane gas. During an interview on at 8:06 AM Staff D stated that it turned on last week. When asked if she believed the leaking gas was dangerous, she said yes. Class III	{A 200}		