

**AGENCY FOR HEALTH CARE
ADMINISTRATION**

PRINTED: 06/20/2019
FORM APPROVED

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910533	(X3) DATE SURVEY COMPLETED 04/19/2019
NAME OF PROVIDER OR SUPPLIER BROOKDALE PHILLIPPI CREEK	STREET ADDRESS, CITY, STATE, ZIP CODE 5501 SWIFT ROAD SARASOTA, FL 34231	
SUMMARY STATEMENT OF DEFICIENCIES (FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)		
0000 - Initial Comments An unannounced emergency power plan monitoring survey was conducted through at Brookdale Phillippi Creek, an assisted living facility in Sarasota, Florida. The following is description of the deficiency. 0200 - Emergency Environmental Control - 58A-5.036 FAC Based on record review and staff interview, the facility failed to ensure compliance with the emergency environmental control plan for assisted living facilities. This has the potential to lead to serious health complications in the event of an emergency. The findings included: On, record review revealed no evidence of implementation of the emergency power plan by as required by regulation. In addition, there was no evidence of an extension to implement the emergency power plan. On at approximately 2:45 p.m., the facility Executive Director said he would obtain a copy of an extension from corporate. On, the Executive Director provided a copy of a Final Order granting a variance from implementation of the emergency power plan. On, review of the Final Order granting a variance revealed the variance was only in effect until On at 10:45 a.m., the facility Executive Director confirmed there was no documented evidence of a current variance or extension of implementation of the emergency power plan. Class III		