STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	ASL5106148	A. BUILDING: _____ B. WING _____	06/03/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
MOORINGS OF ARLINGTON HEIGHTS (AL)	1071 S MOORINGS DRIVE ARLINGTON HEIGHTS, IL 60005

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 000	Initial Comment Annual Licensure Survey conducted Violations: 295.2040e)g) Technical Infraction: 295.4010c) During this survey, it was identified that the establishment did not have service plans signed for (R1 & R5) prior to the survey date of 6/1/2026. The regulations were reviewed with the establishment who verbalized understanding. It was determined a technical infraction would be given surrounding this event. While the surveyor was onsite, the establishment has taken steps to correct the situation, including prevention from reoccurrence, as listed in 295.4010c). No violation imposed.	A 000		
A2040	Section 295.2040 Disaster Preparedness This Regulation is not met as evidenced by: Type 1 Violation: Section 295.2040 Disaster Preparedness e) Drills shall include residents, establishment personnel, and other persons in the establishment. g) Drills shall involve the actual evacuation of residents to an assembly point as specified in the emergency plan and shall provide residents with experience using various means of escape. If an establishment has an evacuation capability classification of impractical, those residents who cannot meaningfully assist in their own evacuation or who have special health problems	A2040		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	ASL5106148	A. BUILDING: _____ B. WING _____	06/03/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
MOORINGS OF ARLINGTON HEIGHTS (AL)	1071 S MOORINGS DRIVE ARLINGTON HEIGHTS, IL 60005

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A2040	Continued From page 1 shall not be required to participate in the drill; however, other requirements of the Life Safety Code will apply. These requirements are not met as evidenced by: Based on interview and record review the establishment failed to include residents in an actual evacuation during fire drills on all shifts. This failure creates a substantial probability of severe harm or death to a resident or residents. Findings include: On 6/1/2026 at 3:01PM, E2 (Assisted Living Director) staff go room to room during fire drills. E2 said some of the residents stay in their room for the floor that is not impacted by the fire. The establishment provided Fire Drill Evaluation Forms list fire drills completed on 8/20/2025 at 2:30PM, 10/20/2025 at 3:45PM, 12/19/2025 at 11:15PM, 2/25/2026 at 10:15AM, 4/17/2026 at 3:45PM.	A2040		