Electronically Delivered

October 14, 2026

Licensee
ALL WULLANCARE INC
7433 Lee Avenue North
Brooklyn Park, MN 55443

RE: Project Number(s) SL36667016

Dear Licensee:

The Minnesota Department of Health (MDH) completed a survey on September 2, 2026, for the purpose of evaluating and assessing compliance with state licensing statutes. At the time of the survey, MDH noted violations of the laws pursuant to Minnesota Statute, Chapter 144G, Minnesota Food Code, Minnesota Rules Chapter 4626, Minnesota Statute 626.5572 and/or Minnesota Statute Chapter 260E.

MDH concludes the licensee is in substantial compliance. State law requires the facility must take action to correct the state correction orders and document the actions taken to comply in the facility's records. The Department reserves the right to return to the facility at any time should the Department receive a complaint or deem it necessary to ensure the health, safety, and welfare of residents in your care.

STATE CORRECTION ORDERS

The enclosed State Form documents the state correction orders. MDH documents state licensing correction orders using federal software. Tag numbers are assigned to Minnesota state statutes for Assisted Living Facilities. The assigned tag number appears in the far left column entitled "ID Prefix Tag." The state statute number and the corresponding text of the state statute out of compliance are listed in the "Summary Statement of Deficiencies" column. This column also includes the findings that are in violation of the state statute after the statement, "This MN Requirement is not met as evidenced by . . ."

IMPOSITION OF FINES

In accordance with Minn. Stat. § 144G.31, Subd. 4, fines and enforcement actions may be imposed based on the level and scope of the violations and may be imposed immediately with no opportunity to correct the violation first as follows:

Level 1: no fines or enforcement;
Level 2: a fine of $500 per violation, in addition to any enforcement mechanism authorized in § 144G.20;
Level 3: a fine of $1,000 per incident, in addition to any enforcement mechanism authorized in § 144G.20;

Level 4: a fine of $3,000 per incident, in addition to any enforcement mechanism authorized in § 144G.20;
Level 5: a fine of $5,000 per violation, in addition to any enforcement mechanism authorized in § 144G.20.

Therefore, in accordance with Minn. Stat. §§ 144G.01 to 144G.9999, the following fines are assessed pursuant to this survey:

St - 0 - 0775 - 144g.45 Subd. 2. (a) - Fire Protection And Physical Environment - $500.00
St - 0 - 0780 - 144g.45 Subd. 2 (a) (1) - Fire Protection And Physical Environment - $500.00
St - 0 - 0810 - 144g.45 Subd. 2 (b-F) - Fire Protection And Physical Environment - $500.00

Therefore, in accordance with Minn. Stat. §§ 144G.01 to 144G.9999, **the total amount you are assessed is $1,500.00**. You will be invoiced approximately 30 days after receipt of this notice, subject to appeal.

DOCUMENTATION OF ACTION TO COMPLY
In accordance with Minn. Stat. § 144G.30, Subd. 5(c), the licensee must document actions taken to comply with the correction orders within the time period outlined on the state form; however, plans of correction are not required to be submitted for approval.

The correction order documentation should include the following:

- Identify how the area(s) of noncompliance was corrected related to the resident(s)/employee(s) identified in the correction order.
- Identify how the area(s) of noncompliance was corrected for all of the provider's resident(s)/employees that may be affected by the noncompliance.
- Identify what changes to your systems and practices were made to ensure compliance with the specific statute(s).

CORRECTION ORDER RECONSIDERATION PROCESS
In accordance with Minn. Stat. § 144G.32, Subd. 2, you may challenge the correction order(s) issued, including the level and scope, and any fine assessed through the correction order reconsideration process. The request for reconsideration must be in writing and received by MDH within 15 calendar days of the correction order receipt date.

To submit a reconsideration request, please visit:
https://forms.web.health.state.mn.us/form/HRDAppealsForm

REQUESTING A HEARING
Alternatively, in accordance with Minn. Stat. § 144G.31, Subd. 5(d), an assisted living provider that has been assessed a fine under this subdivision has a right to a reconsideration or a hearing under this section and chapter 14. Pursuant to Minn. Stat. § 144G.20, Subd. 14 and Subd. 18, a request for a hearing must be in writing and received by the Department of Health within 15 business days of the

correction order receipt date. The request must contain a brief and plain statement describing each matter or issue contested and any new information you believe constitutes a defense or mitigating factor.

To submit a hearing request, please visit:
https://forms.web.health.state.mn.us/form/HRDAppealsForm

To appeal fines via reconsideration, please follow the procedure outlined above. Please note that you may request a reconsideration **or** a hearing, but not both. If you wish to contest tags without fines in a reconsideration and tags with the fines at a hearing, please submit two separate appeals forms at the website listed above.

The MDH Health Regulation Division (HRD) values your feedback about your experience during the survey and/or investigation process. Please fill out this anonymous provider feedback questionnaire at your convenience at this link: **https://forms.office.com/g/Bm5uQEpHVa**. Your input is important to us and will enable MDH to improve its processes and communication with providers.

You are encouraged to retain this document for your records. It is your responsibility to share the information contained in the letter and state form with your organization's Governing Body.

If you have any questions, please contact me.

Sincerely,



Jess Schoenecker, Supervisor
State Evaluation Team
Email: Jess.Schoenecker@state.mn.us
Telephone: 651-201-3789 Fax: 1-866-890-9290

HHH

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	36667	A. BUILDING: _____ B. WING _____	09/02/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
ALL WULLANCARE INC	7433 LEE AVENUE NORTH BROOKLYN PARK, MN 55443

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
0 000	Initial Comments ******ATTENTION****** ASSISTED LIVING PROVIDER LICENSING CORRECTION ORDER In accordance with Minnesota Statutes, section 144G.08 to 144G.95, these correction orders are issued pursuant to a survey. Determination of whether violations are corrected requires compliance with all requirements provided at the Statute number indicated below. When Minnesota Statute contains several items, failure to comply with any of the items will be considered lack of compliance. INITIAL COMMENTS: SL#36667016-0 On August 31, 2026, through September 2, 2026, the Minnesota Department of Health conducted a survey at the above provider, and the following correction orders are issued. At the time of the survey, there were four (4) residents; 4 receiving services under the Assisted Living license.	0 000	Minnesota Department of Health is documenting the State Correction Orders using federal software. Tag numbers have been assigned to Minnesota State Statutes for Assisted Living License Providers. The assigned tag number appears in the far-left column entitled "ID Prefix Tag." The state Statute number and the corresponding text of the state Statute out of compliance is listed in the "Summary Statement of Deficiencies" column. This column also includes the findings which are in violation of the state requirement after the statement, "This Minnesota requirement is not met as evidenced by." Following the surveyors' findings is the Time Period for Correction. PLEASE DISREGARD THE HEADING OF THE FOURTH COLUMN WHICH STATES,"PROVIDER'S PLAN OF CORRECTION." THIS APPLIES TO FEDERAL DEFICIENCIES ONLY. THIS WILL APPEAR ON EACH PAGE. THERE IS NO REQUIREMENT TO SUBMIT A PLAN OF CORRECTION FOR VIOLATIONS OF MINNESOTA STATE STATUTES. THE LETTER IN THE LEFT COLUMN IS USED FOR TRACKING PURPOSES AND REFLECTS THE SCOPE AND LEVEL ISSUED PURSUANT TO 144G.31 SUBDIVISION 1-3.	
0 775 SS=F	144G.45 Subd. 2. (a) Fire protection and physical environment	0 775		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	36667	A. BUILDING: _____ B. WING _____	09/02/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
ALL WULLANCARE INC	7433 LEE AVENUE NORTH BROOKLYN PARK, MN 55443

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
0 775	Continued From page 1 Each assisted living facility must comply with the State Fire Code in Minnesota Rules, chapter 7511, and: This MN Requirement is not met as evidenced by: Based on observation, interview, and record review, the licensee failed to ensure the physical environment of the facility was maintained in compliance with the requirements of Minnesota Statute 144G. This practice resulted in a level two violation (a violation that did not harm a resident's health or safety but had the potential to have harmed a resident's health or safety, but was not likely to cause serious injury, impairment, or death) and was issued at a widespread scope (when problems are pervasive or represent a systemic failure that has affected or has the potential to affect a large portion or all of the residents). The findings include: Please refer to the document titled, Physical Environment Inspection Report (PEIR) dated September 1, 2026, for the specific violations related the physical environment under Minnesota Statute 144G. TIME PERIOD FOR CORRECTION: Seven (7) Days	0 775		
0 780 SS=F	144G.45 Subd. 2 (a) (1) Fire protection and physical environment (a) Each assisted living facility must comply with the State Fire Code in Minnesota Rules, chapter 7511, and:	0 780		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	36667	A. BUILDING: _____ B. WING _____	09/02/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
ALL WULLANCARE INC	7433 LEE AVENUE NORTH BROOKLYN PARK, MN 55443

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
0 780	Continued From page 2 (1) for dwellings or sleeping units, as defined in the State Fire Code: (i) provide smoke alarms in each room used for sleeping purposes; (ii) provide smoke alarms outside each separate sleeping area in the immediate vicinity of bedrooms; (iii) provide smoke alarms on each story within a dwelling unit, including basements, but not including crawl spaces and unoccupied attics; (iv) where more than one smoke alarm is required within an individual dwelling unit or sleeping unit, interconnect all smoke alarms so that actuation of one alarm causes all alarms in the individual dwelling unit or sleeping unit to operate; and (v) ensure the power supply for existing smoke alarms complies with the State Fire Code, except that newly introduced smoke alarms in existing buildings may be battery operated; This MN Requirement is not met as evidenced by: Based on observation, interview, and record review, the licensee failed to ensure the physical environment of the facility was maintained in compliance with the requirements of Minnesota Statute 144G. This practice resulted in a level two violation (a violation that did not harm a resident's health or safety but had the potential to have harmed a resident's health or safety, but was not likely to cause serious injury, impairment, or death) and was issued at a widespread scope (when	0 780		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	36667	A. BUILDING: _____ B. WING _____	09/02/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
ALL WULLANCARE INC	7433 LEE AVENUE NORTH BROOKLYN PARK, MN 55443

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
0 780	Continued From page 3 problems are pervasive or represent a systemic failure that has affected or has the potential to affect a large portion or all of the residents). The findings include: Please refer to the document titled, Physical Environment Inspection Report (PEIR) dated September 1, 2026, for the specific violations related the physical environment under Minnesota Statute 144G. TIME PERIOD FOR CORRECTION: Seven (7) Days	0 780		
0 810 SS=F	144G.45 Subd. 2 (b-f) Fire protection and physical environment (b) Each assisted living facility shall develop and maintain fire safety and evacuation plans. The plans shall include but are not limited to: (1) location and number of resident sleeping rooms; (2) staff actions to be taken in the event of a fire or similar emergency; (3) fire protection procedures necessary for residents; and (4) procedures for resident movement, evacuation, or relocation during a fire or similar emergency including the identification of unique or unusual resident needs for movement or evacuation. (c) Staff of assisted living facilities shall receive training on the fire safety and evacuation plans upon hiring and at least twice per year thereafter. (d) Fire safety and evacuation plans shall be readily available at all times within the facility. (e) Residents who are capable of assisting in their own evacuation shall be trained on the	0 810		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	36667	A. BUILDING: _____ B. WING _____	09/02/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
ALL WULLANCARE INC	7433 LEE AVENUE NORTH BROOKLYN PARK, MN 55443

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
0 810	Continued From page 4 proper actions to take in the event of a fire to include movement, evacuation, or relocation. The training shall be made available to residents at least once per year. (f) Evacuation drills are required for staff twice per year per shift with at least one evacuation drill every other month. Evacuation of the residents is not required. Fire alarm system activation is not required to initiate the evacuation drill. This MN Requirement is not met as evidenced by: Based on observation, interview, and record review, the licensee failed to ensure the physical environment of the facility was maintained in compliance with the requirements of Minnesota Statute 144G. This practice resulted in a level two violation (a violation that did not harm a resident's health or safety but had the potential to have harmed a resident's health or safety, but was not likely to cause serious injury, impairment, or death) and was issued at a widespread scope (when problems are pervasive or represent a systemic failure that has affected or has the potential to affect a large portion or all of the residents). The findings include: Please refer to the document titled, Physical Environment Inspection Report (PEIR) dated September 1, 2026, for the specific violations related the physical environment under Minnesota Statute 144G. TIME PERIOD FOR CORRECTION: Twenty One	0 810		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	36667	A. BUILDING: _____ B. WING _____	09/02/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
ALL WULLANCARE INC	7433 LEE AVENUE NORTH BROOKLYN PARK, MN 55443

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
0 810	Continued From page 5 (21) Days	0 810		
0 970 SS=C	144G.50 Subd. 5 Waivers of liability prohibited The contract must not include a waiver of facility liability for the health and safety or personal property of a resident. The contract must not include any provision that the facility knows or should know to be deceptive, unlawful, or unenforceable under state or federal law, nor include any provision that requires or implies a lesser standard of care or responsibility than is required by law. This MN Requirement is not met as evidenced by: Based on interview and record review, the licensee failed to ensure the assisted living contract did not include language waiving the licensee's liability for health, safety, or personal property of a resident. This had the potential to affect all residents. This practice resulted in a level one violation (a violation that will cause only minimal impact on the resident and does not affect health or safety) and was issued at a widespread scope (when problems are pervasive or represent a systemic failure that has affected or has the potential to affect a large portion or all the residents). The findings include: On August 31, 2026, at approximately 1:05 p.m., licensed assisted living director/clinical nurse supervisor (LALD/CNS)-A provided R1's Assisted Living Contract and stated the contract was used by the licensee for all residents who would live in the facility.	0 970		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	36667	A. BUILDING: _____ B. WING _____	09/02/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
ALL WULLANCARE INC	7433 LEE AVENUE NORTH BROOKLYN PARK, MN 55443

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
0 970	Continued From page 6 R1's current Assisted Living Contract dated December 27, 2022, on page 15, included a section titled K. Hold Harmless, and read, "You agree to hold harmless [licensee] from any and all claims arising from an injury or illness ...". On August 24, 2026, at approximately 1:35 p.m., LALD/CNS-A acknowledged the licensee's assisted living contract included a waiver of liability for health and safety. LALD/CNS-A stated they were not aware that the licensee's assisted living contract had a waiver of liability and the liability waiver would need to be removed from the licensee contracts. No further information was provided. TIME PERIOD FOR CORRECTION: Twenty-one (21) days	0 970		

Metro District Office
Minnesota Department of Health
625 Robert St N, PO BOX 64975
St Paul, MN 55164
Phone: 651-201-4500

Food & Beverage Inspection Report

Establishment Info

ALL WULLANCARE INC
7433 Lee Ave N
Brooklyn Park, MN 55443
Hennepin County
Parcel:

Phone:

License Info

License: HFID 36667

Risk:
License:
Expires on:
CFPM: Agnes Ayunbiade
CFPM #: 16299; Exp: 7/24/2027

Inspection Info

Report Number: F8041261128
Inspection Type: Full - Single
Date: 9/1/2026 Time: 10:30 AM
Duration: minutes
Announced Inspection:
Total Priority 1 Orders: 0
Total Priority 2 Orders: 0
Total Priority 3 Orders: 0
Delivery: Emailed

No orders were issued for this inspection report.

Food & Beverage General Comment

Inspection was completed with the food service manager, Agnes Agunbiade. Carl Samrock was the HRD nurse evaluator.

Facility has a residential kitchen. Food must be prepared for same day service only. Kitchen has a smooth ceiling, wood flooring, wood cabinets with a hollow base and tile walls.

Establishment has a dish machine that achieved a utensil surface temperature of at least 160F. There is a freezer in the garage and a refrigerator in the basement.

Discussed the following:
- Employee illness policy and logging requirements
- Reporting foodborne illness complaints to the health dept.
- Handwashing
- Date marking
- Glove-use and bare hand contact
- Proper food storage
-Vomit clean-up procedures
- Restrictions concerning serving a highly susceptible population

NOTE: All new food equipment must meet the applicable standards of the American National Standards Institute (ANSI). Plans and specifications must be submitted for review and approval prior to new construction, remodeling or alterations.

I acknowledge receipt of the Metro District Office inspection report number F8041261128 from 9/1/2026

Agnes Agunbiade

Sarah Conboy,
Public Health Sanitarian Supervisor
651-201-3984
sarah.conboy@state.mn.us

Metro District Office
Minnesota Department of Health
625 Robert St N, PO BOX 64975
St Paul, MN 55164

Temperature Observations/Recordings

Establishment Info

ALL WULLANCARE INC
Brooklyn Park
County/Group: Hennepin County

Inspection Info

Report Number: F8041261128
Inspection Type: Full
Date: 9/1/2026
Time: 10:30 AM

Food Temperature: Product/Item/Unit: ambient air**; Temperature Process:** Cold-Holding
Location: kitchen refrigerator at 41 Degrees F.
Comment:
Violation Issued?: No

Food Temperature: Product/Item/Unit: bologna**; Temperature Process:** Cold-Holding
Location: basement refrigerator at 39 Degrees F.
Comment:
Violation Issued?: No

DEPARTMENT OF HEALTH

Physical Environment Inspection Report

ASSISTED LIVING | ASSISTED LIVING WITH DEMENTIA CARE

Project No: SL36667016-0	**Date:** 9/1/2026
Facility Name: ALL WULLANCARE INC	
Facility Address: 7433 Lee Ave N, Brooklyn Park, Minnesota 55443	

☒ **TAG IDENTIFICATION: 0775**

SCOPE/ SEVERITY: Level 2; Widespread **TIME PERIOD OF CORRECTION:** Seven (7) days

1. Each assisted living facility must comply with the provisions of the Minnesota State Fire Code (MSFC) in Minnesota Rules chapter 7511. [Minn. Stat. 144G.45 subd. 2]

2. Clothes dryers and their exhaust systems shall be cleaned as necessary to keep lint traps, exhaust ducts, and mechanical and heating components free from excessive lint accumulation. [Minn. Stat. 144G.45 subd. 2; MSFC 304.4]

   Comments: The dryer duct was disconnected from the clothes dryer. An excess of lint was present behind the clothes dryer.

☒ **TAG IDENTIFICATION: 0780**

SCOPE/ SEVERITY: Level 2; Widespread **TIME PERIOD OF CORRECTION:** Seven (7) days

1. Smoke alarms shall be interconnected so that actuation of one alarm causes all alarms in the individual dwelling or sleeping unit to operate where more than one smoke alarm is required within an individual dwelling or sleeping unit. [Minn. Stat. 144G.45 subd.2]

   Comments: The smoke alarm in resident room 3 was not interconnected with the remainder of the facility.

☒ **TAG IDENTIFICATION: 0810**

SCOPE/ SEVERITY: Level 2; Widespread **TIME PERIOD OF CORRECTION:** Twenty One (21) days

1. Each assisted living facility shall develop and maintain fire safety and evacuation plans (FSEP) that include the location and number of resident rooms. [Minn. Stat. 144G.45 subd.2]

   Comments: The posted evacuation plans indicated the garage was used as a designated exit. Exiting through an area of higher hazard is prohibited.

2. Each assisted living facility shall develop and maintain fire safety and evacuation plans (FSEP) that include employee actions to be taken in the event of a fire or similar emergency. [Minn. Stat. 144G.45 subd.2]

   Comments: Multiple staff fire policies where present in the facility's FSEP.