

PRINTED: 10/16/2017
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL054051	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____		(X3) DATE SURVEY COMPLETED 09/27/2017
NAME OF PROVIDER OR SUPPLIER LENOIR ASSISTED LIVING		STREET ADDRESS, CITY, STATE, ZIP CODE 2773 PINEWOOD HOME ROAD PINK HILL, NC 28572			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
C 000	Initial Comments Report of a Construction Section Biennial Survey by Suzanna Fay and Billy S. Bryant conducted on September 27, 2017. Based on information gathered from our files, the Facility was first licensed on October 10, 1990 for Sixty (60) residents. A fully sprinkled addition was completed and licensed on February 1, 1996, making a total of Ninety-Four (94) Residents including Thirty-Two (32) Special Care Beds. Based on this information, we are requiring the original facility to meet the 1987 Minimum Standards and Regulations for Homes for the Aged and Disabled and the 1978 North Carolina State Building Code, Institutional Occupancy; the addition to meet the 1996 Rules for the Licensing of Adult Care Homes and the 1996 North Carolina State Building Code, Institutional Occupancy; and the entire facility to meet the applicable portions of the 2005 Rules for Adult care Home of Seven or More Beds.	C 000			
C 101	Existing Licensed Fac- No less than '71 Rules SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0301 APPLICATION OF PHYSICAL PLANT REQUIREMENTS The physical plant requirements for each adult care home shall be applied as follows: (2) Except where otherwise specified, existing licensed facilities or portions of existing licensed facilities shall meet licensure and code requirements in effect at the time of construction, change in service or bed count, addition, renovation, or alteration; however in no case shall the requirements for any licensed facility where no addition or renovation has been made, be less than those requirements found in the 1971 "Minimum and Desired Standards and	C 101			

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

Mitchell Moran

TITLE

Maintenance Director

(X6) DATE

11/1/17

STATE FORM

4009

IHE121

If continuation sheet 1 of 11

PRINTED: 10/16/2017
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL054061	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____		(X3) DATE SURVEY COMPLETED 09/27/2017
NAME OF PROVIDER OR SUPPLIER LENOIR ASSISTED LIVING		STREET ADDRESS, CITY, STATE, ZIP CODE 2773 PINWOOD HOME ROAD PINK HILL, NC 28572			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
C 101	Continued From page 1 Regulations" for "Homes for the Aged and Infirm", copies of which are available at the Division of Health Service Regulation at no cost: This Rule is not met as evidenced by: 1. Based on observations, the facility did not meet the licensure and code requirements in effect at the time of construction, change in service or bed count, addition, renovation or alteration. Findings on September 2017: a. The SCU was relocated from the 300 Hall to the 200 Hall. The maglock system for the SCU did not have a master manual override. b. There was not a schematic diagram for the maglock system posted at the fire alarm panel.	C 101			
		A	Master manual override switch add outside of med rooms	11/24/17	
		B	Schematic diagram will be posted at alarm panel	11/24/17	
C 111	Must Have Current San. & Fire Safety Reports SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0302 DESIGN AND CONSTRUCTION f) The facility shall have current sanitation and fire and building safety inspection reports which shall be maintained in the home and available for review. This Rule is not met as evidenced by: 1. Review of records revealed that the facility did not maintain current sanitation and fire and building safety inspection reports. Findings on September 27, 2017: a. The current building sanitation inspection was dated August 22, 2016. b. The kitchen sanitation inspection report was not available for review.	C 111			
		A	Have call for inspection will send update when done		
		B-C	Reports are attached	10/31/17	

PRINTED: 10/16/2017
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL054051	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____		(X3) DATE SURVEY COMPLETED 09/27/2017
NAME OF PROVIDER OR SUPPLIER LENOIR ASSISTED LIVING		STREET ADDRESS, CITY, STATE, ZIP CODE 2773 PINEWOOD HOME ROAD PINK HILL, NC 28572			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
C 164	Continued From page 3 furnishings were not maintained in good repair. Findings on September 27, 2017: a. Room 116 - the door hardware was loose. 2. Observations revealed that the ceilings were not maintained clean and in good repair. Findings on September 27, 2017: a. Janitor closet by Guest bath - there are large brown water stains from a prior roof leak on the wall and ceiling around the exhaust fan and in the back corner. b. Kitchen - there are large patched areas on the ceiling that have not been sanded and painted.	C 164 A A-B	Door knob was tightened Janitor closet and Kitchen will be repaired and painted as the whole building is being painted contractor is working on now and will be done by the end of the year	10/23/17	
C 166	Housekeeping-Maintained Free of Hazards SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0306 HOUSEKEEPING AND FURNISHINGS (a) Adult care homes shall: (5) be maintained in an uncluttered, clean and orderly manner, free of all obstructions and hazards; (e) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: 1. Based on observation the facility was not maintained free from hazards. Oxygen bottles that are improperly stored without any means of restraint to keep them from falling or being knocked over may present a danger to the occupants of the facility. Findings on September 27, 2017: a. Administrative Office had one unrestrained oxygen tank. The tank was removed at the time	C 166 A	was removed at time of survey	9/27/17	

Division of Health Service Regulation
STATE FORM

4999

KHE121

If continuation sheet 4 of 11

PRINTED: 10/16/2017
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL064081	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED 09/27/2017
NAME OF PROVIDER OR SUPPLIER LENOIR ASSISTED LIVING		STREET ADDRESS, CITY, STATE, ZIP CODE 2773 PINWOOD HOME ROAD PINK HILL, NC 28572	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)
C 166	Continued From page 4 of survey. b. Copier Room had three unrestrained oxygen tanks and the other tanks were stored in an inappropriate container. c. 200 Hall Janitor Closet - the oxygen bottles were stored in a plastic beverage rack. 2. Based on observation there is a failure to maintain the facility free from hazards. Padlocked rooms or areas pose a risk of entrapment. Findings on September 27, 2017: a. The kitchen freezer unit had a hasp latch with a padlock. The padlock was removed at the time of survey. 3. Observations revealed that the flooring was not maintained in good repair and free of hazards. Findings on September 27, 2017: a. Room 310 - the carpet is unraveling down the middle of the room creating a trip hazard. b. 200 Hall, Med tech room - the carpet at the entry is heavily damaged creating a trip hazard. c. Room 207 - the carpet is unraveling in the bedroom creating a trip hazard.	C 166 B-C A A-C	all oxygen tanks are in approved racks was removed at time of survey all flooring is going to be replaced by the end of the year
C 189	Building Equipment Maintained Safe, Operating SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in an adult care home shall be maintained in a safe and operating condition. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e)	C 189	

Division of Health Service Regulation
STATE FORM

6888

KHE121

If continuation sheet 5 of 11

PRINTED: 10/16/2017
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL054051	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED 09/27/2017
NAME OF PROVIDER OR SUPPLIER LENOIR ASSISTED LIVING		STREET ADDRESS, CITY, STATE, ZIP CODE 2773 PINWOOD HOME ROAD PINK HILL, NC 28572		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 189	Continued From page 5 which shall not apply to existing facilities. This Rule is not met as evidenced by: 1. Based on observation there is a failure to maintain the building's fire safety systems in a safe condition. Holes or gaps at penetrations through fire resistant rated ceilings could allow fire and smoke to spread beyond the area of origin. Findings on September 27, 2017: a. Room 105 - there is a gap around the heat detector in the bathroom. b. Room 108 - there is a small hole at the nurse call light. c. Room 115 - there is a gap in the ceiling at the nurse call light. d. Main Electrical room: 1) The ceiling is damaged and there are mildew stains at the first electrical panel. 2.) There is a large hole in the ceiling where the freezer condensate lines penetrate. 3.) There is damage to the ceiling at the heat detector leaving a large hole. 4.) There are open penetrations for the electrical conduit at the second electrical panel. 5.) There is an open cable penetration at the Galaxy control panel. e. 300 Hall lobby by curved wall - one of the sprinkler head escutcheon plates has dropped leaving a gap at the ceiling. 2. Based on observation electrical equipment has not been maintained in a safe manner. Failure to maintain ground fault circuits in an operating manner could effect the safety of the residents, staff and visitors. Findings on September 27, 2017:	C 189		
		A-C	Holes was repaired	9/28/17
		D-1	ceiling was repaired	10/3/17
		D-2	hole was filled with fire sealant	10/3/17
		D-3	hole was repaired	10/3/17
		D-4&5	penetration was filled with fire sealant	10/3/17
		E	escutcheon was pushed back up to ceiling	10/3/17

Division of Health Service Regulation
STATE FORM

6903

KHE121

If continuation sheet 6 of 11

PRINTED: 10/16/2017
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL054051	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____		(X3) DATE SURVEY COMPLETED 09/27/2017
NAME OF PROVIDER OR SUPPLIER LENOIR ASSISTED LIVING		STREET ADDRESS, CITY, STATE, ZIP CODE 2773 PINEWOOD HOME ROAD PINK HILL, NC 28572			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
C 189	Continued From page 6 a. Room 110 Bath - the GFCI outlet did not trip when tested. b. Bath 3A - the GFCI outlet did not work when checked with a GFCI tester. c. Old dining room at 300 Hall - the GFCI outlet to the left on the counter is broken. 3. Based on observation the facility's fire safety equipment is not maintained in operating condition. Failure to maintain fire safety equipment in operating condition could effect the safety of the occupants of the facility. Findings on September 27, 2017: a. Room 115 - the heat detector was not secure to its base. b. Room 115 - the heat detector is missing from its base. c. The kitchen range hood suppression system did not have an inspection tag. d. Exit by Room 310 - the exterior sprinkler head is completely covered in spider webs and debris. There is a 1/2" hole in the soffit at the sprinkler head. It appears that the escutcheon plate is missing as well. e. Water heater room at 300 ramp - the flange around the sprinkler head is broken and no longer covers the penetration for the sprinkler head. f. Water heater room at 300 ramp - there are open penetrations at the piping and the ceiling is damaged. 4. Based on observation there is a failure to install and maintain required plumbing safety devices or equipment. The absence of the plumbing safety devices or equipment could cause the domestic water supply to become contaminated. Findings on September 27, 2017:	C 189 A-C A-B C D E F	GFCI outlets was replaced Heat detector was secure to base and replaced missing detector hood suppression system will be updated and inspection tag replaced sprinkler head was cleaned and escutcheon has been ordered escutcheon has been ordered penetration and ceiling has been repaired	10/31/17 9/28/17 11/29/17 11/29/17 11/29/17 9/28/17	

Division of Health Service Regulation
STATE FORM

KHE121

If continuation sheet 7 of 11

PRINTED: 10/16/2017
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL054051	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED 09/27/2017
NAME OF PROVIDER OR SUPPLIER LENOIR ASSISTED LIVING		STREET ADDRESS, CITY, STATE, ZIP CODE 2773 PINEWOOD HOME ROAD PINK HILL, NC 28572		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR USC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 195	Continued From page 9 facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1. Observations revealed that the water temperature was not maintained between 100 and 118 degrees F at all fixtures used by residents. Findings on September 27, 2017: a. 200 Hall - the water temperature readings at two locations were 118 degrees F and 120 degrees F.	C 195 A	water heater was turned down and now the water reads between 100 and 118	10/3/17
C 199	Exhaust Ventilation SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (g) The spaces listed in this Paragraph shall be provided with exhaust ventilation at the rate of two cubic feet per minute per square foot. This requirement does not apply to facilities licensed before April 1, 1984, with natural ventilation in these specified spaces: (1) soiled linen storage; (2) soil utility room; (3) bathrooms and toilet rooms; (4) housekeeping closets; and (5) laundry area. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1. Observations revealed that the facility did not provide exhaust ventilation in required areas at the rate of two cubic feet per minute per square	C 199	(Attached is temperature test done)	

Division of Health Service Regulation
STATE FORM

5999

KHE121

If continuation sheet 10 of 11

Food Establishment Inspection Report

Score: 97.5Establishment Name: Lenoir Assisted LivingEstablishment ID: 06054160014Location Address: 2773 Pinewood Home DrCity: Pink Hill State: North CarolinaZip: 28572 County: LenoirPermittee: Victorian Senior Care

Telephone: _____

☒ Inspection ☐ Re-Inspection

Wastewater System:

☒ Municipal/Community ☐ On-Site

Water Supply:

☒ Municipal/Community ☐ On-SiteDate: 6/26/17 Status Code: ATime In: 10:15 Time Out: 11:30Category#: 4FDA Establishment Type: IFSNo. of Risk Factor/Intervention Violations: 0No. of Repeat Risk Factor/Intervention Violations: 0

Foodborne Illness Risk Factors and Public Health Interventions

Risk factors: Contributing factors that increase the chance of developing foodborne illness.

Public Health interventions: Control measures to prevent foodborne illness or injury.

Compliance Status		OUT	CDI	R	VR
Supervision .2652					
1	OUT	2	0		
Employee Health .2652					
2	OUT	3	1	0	
3	OUT	3	1	0	
Good Hygienic Practices .2652, .2653					
4	OUT	2	1	0	
5	OUT	1	0	0	
Preventing Contamination by Hands .2652, .2653, .2655, .2656					
6	OUT	4	2	0	
7	OUT	3	1	0	
8	OUT	2	1	0	
Approved Sources .2653, .2655					
9	OUT	0	1	0	
10	OUT	2	1	0	
11	OUT	2	1	0	
12	OUT	3	1	0	
Protection from Contamination .2652, .2654					
13	OUT	0	1	0	
14	OUT	0	1	0	
15	OUT	2	1	0	
Potentially Hazardous Food Time/Temperature .2652					
16	OUT	3	1	0	
17	OUT	3	1	0	
18	OUT	3	1	0	
19	OUT	0	1	0	
20	OUT	0	1	0	
21	OUT	0	1	0	
22	OUT	2	1	0	
Consumer Advisory .2653					
23	OUT	1	0	0	
Highly Susceptible Populations .2652					
24	OUT	2	1	0	
Chemical .2653, .2657					
25	OUT	1	0	0	
26	OUT	2	1	0	
Compliance with Approved Procedures .2653, .2654, .2655					
27	OUT	2	1	0	

Good Retail Practices

Good Retail Practices: Preventative measures to control the addition of pathogens, chemicals, and physical objects into foods.

Compliance Status		OUT	CDI	R	VR
Safe Food and Water .2652, .2653, .2655					
28	OUT	1	0	0	
29	OUT	2	1	0	
30	OUT	1	0	0	
Food Temperature Control .2653, .2654					
31	OUT	1	0	0	
32	OUT	1	0	0	
33	OUT	1	0	0	
34	OUT	1	0	0	
Food Identification .2652					
35	OUT	2	1	0	
Prevention of Food Contamination .2652, .2653, .2654, .2655, .2657					
36	OUT	2	1	0	
37	OUT	2	1	0	
38	OUT	1	0	0	
39	OUT	1	0	0	
40	OUT	1	0	0	
Proper Use of Utensils .2653, .2654					
41	OUT	1	0	0	
42	OUT	1	0	0	
43	OUT	1	0	0	
44	OUT	1	0	0	
Utilities and Equipment .2652, .2654, .2657					
45	OUT	2	1	0	
46	OUT	1	0	0	
47	OUT	1	0	0	
Physical Facilities .2654, .2655, .2656					
48	OUT	2	1	0	
49	OUT	2	1	0	
50	OUT	2	1	0	
51	OUT	1	0	0	
52	OUT	1	0	0	
53	OUT	1	0	0	
54	OUT	1	0	0	
TOTAL DEDUCTIONS:					<u>2.5</u>



Comment Addendum to Food Establishment Report

Establishment Name: Lenoir Assisted Living
 Location Address: 2723 Pinewood Home Dr
 City: Pink Hill State: NC
 County: _____ Zip: 28572
 Wastewater System: ☒ Municipal/Community ☐ On-Site
 Water Supply: ☒ Municipal/Community ☐ On-Site
 Permittee: Victorian Senior Care
 Telephone: _____

Establishment ID: 06054160214
☒ Inspection ☐ Re-Inspection
☐ Visit
☐ Verification
☐ Name Change
☐ Status Change
☐ Pre-Opening Visit
☐ Other _____

Date: 6/26/17
 Status Code: A
 Category#: 4

Temperature Observations

Item/Location	Temp	Item/Location	Temp	Item/Location	Temp
Hamburger Steak/Steamer	166°	Beans/Steam well	165°	Soup/Steam well	165°
Corn/Steam well	172°	Cheese/walk-in	44°	Pasta salad/walk-in	44°
Chili/walk-in	43°				

Observations and Corrective Actions

Item Number	Food Code Citation	Violations cited in this report must be corrected within the time frames below, or as stated in sections 2-405.11 of the Food Code.
34)	4-502.11(13)	Thermometer was not calibrated proper. Ensure that thermometer is calibrated to 32°
36)	6-502.111	Several flies observed in kitchen. Be vigilant about pest control.
39)	3-304.14	Wet wiping cloths in empty bucket. Store wet wiping cloths in sanitizer 200-400 ppm quat.
52)	5-502.114	Dumpster missing drain plug. Needs to be replaced.
53)	6-502.11	Ceiling above prep sink is in disrepair and wall/baseboard next to back door is in disrepair. Needs to be repaired.

Person in Charge (Print & Sign):

Ashley Sawyer Ashley Sawyer

Verification Required Date:

N/A

Regulatory Authority (Print & Sign):

Luke Barret Luke Barret, RPHS

REHS ID: 25025

REHS Contact Phone Number:

(252) 526-4246
Ext 2258



72-110

NATIONAL FIRE ALARM CODE

INSPECTION AND TESTING FORM

DATE: 1/17/17

TIME: _____

SERVICE ORGANIZATION

Name: Williams Fire Sprinkler Co. Inc.Address: P.O. Box 1048 - 14677 U.S. Highway 64 West, Williamston, NC 27892Representative: Pedro Benas

License No.: _____

Telephone: 252-792-0195

PROPERTY NAME (USER)

Name: Lenoir Assisted Living, LLCAddress: 2772 Pinewood Home Road, Pink Hill, NC 28572Owner Contact: RandyTelephone: 252-569-6187

MONITORING ENTITY

Contact: Security CentralTelephone: 800-428-4171Monitoring Account Ref. No.: CX / 2483

APPROVING AGENCY

Contact: _____

Telephone: _____

TYPE TRANSMISSION

- ☐ McCulloch
☐ Multiplex
☒ Digital / FOTS Lines
☐ Reverse Priority
☐ RF
☐ Other (Specify) _____

SERVICE

- ☐ Weekly
☐ Monthly
☐ Quarterly
☐ Semiannually
☒ Annually
☐ Other (Specify) _____

Control Unit Manufacturer: Sirens Knight / 6125 CommunicationsCircuit Styles: 4 & YNumber of Circuits: 20 Zones & 2 NACsSoftware Rev.: 1.4

Last Date System Had Any Service Performed: _____

Last Date That Any Software or Configuration Was Revised: _____

Model No.: 5206

ALARM-INITIATING DEVICES AND CIRCUIT INFORMATION

Quantity of
Devices Installed

Circuit Style

Quantity of
Devices Tested

11
44
7
74
1
2

4
4
4
4
4
4

11
44
7
74
1
2

Manual Fire Alarm Boxes
 Ion Detectors
 Photo Detectors
 Duct Detectors
 Heat Detectors
 Waterflow Switches
 Supervisory Switches
 Other (Specify): _____

Alarm verification feature is disabled ☒ enabled _____

© 2007 National Fire Protection Association

NFPA 72 (p. 1 of 4)

FIGURE 10.6.2.3 Example of an Inspection and Testing Form.



2007 Edition

INSPECTION, TESTING, AND MAINTENANCE

72-111

ALARM NOTIFICATION APPLIANCES AND CIRCUIT INFORMATION

Quantity of Appliances Installed	Circuit Style	Quantity of Appliances Tested	
2	Y	2	Bells
			Horns
			Chimes
			Strobes
			Speakers
13	Y	13	Other (Specify): None/300000

No. of alarm notification appliance circuits: 2

Are circuits monitored for integrity? ☒ Yes ☐ No

SUPERVISORY SIGNAL-INITIATING DEVICES AND CIRCUIT INFORMATION

Quantity of Devices Installed	Circuit Style	Quantity of Devices Tested	
N/A	N/A	N/A	Building Temp.
N/A	N/A	N/A	Site Water Temp.
N/A	N/A	N/A	Site Water Level
N/A	N/A	N/A	Fire Pump Power
N/A	N/A	N/A	Fire Pump Running
N/A	N/A	N/A	Fire Pump Auto Position
N/A	N/A	N/A	Fire Pump or Pump Controller Trouble
N/A	N/A	N/A	Fire Pump Running
N/A	N/A	N/A	Generator in Auto Position
N/A	N/A	N/A	Generator or Controller Trouble
N/A	N/A	N/A	Switch Transfer
N/A	N/A	N/A	Generator Engine Running
N/A	N/A	N/A	Other:

SIGNALING LINE CIRCUITS

Quantity and style of signaling line circuits connected to system (see NFPA 72, Table 6.6.1):

Quantity: N/A Style(s): N/A

SYSTEM POWER SUPPLIES

(a) Primary (Main): Nominal Voltage: 120 VAC Amps: 20 Amps

Overcurrent Protection: Type: Breaker Amps: 20 Amps

Location (of Primary Supply Panelboard): Electrical Room

Disconnecting Means Location: Panel Switch #

(b) Secondary (Standby):

Storage Battery: Amp-Hr Rating: 7 Ah

Calculated capacity in 5.1 Amp-Hrs to operate system for 5.1 hours

Engine-driven generator dedicated to fire alarm system:

Location of fuel storage:

TYPE BATTERY

- ☐ Dry Cell ☐ Lead-Acid
- ☐ Nickel-Cadmium ☐ Other (Specify):
- ☒ Sealed Lead-Acid

(c) Emergency or standby system used as a backup to primary power supply, instead of using a secondary power supply:

- ☐ Emergency system described in NFPA 70, Article 700
- ☒ Legally required standby described in NFPA 70, Article 701
- ☐ Optional standby system described in NFPA 70, Article 702, which also meets the performance requirements of Article 700 or 701

FIGURE 10.6.2.3 Continued



72-112

NATIONAL FIRE ALARM CODE

PRIOR TO ANY TESTING				
NOTIFICATIONS ARE MADE	Yes	No	Who	Time
Monitoring Entity	☒	☐	<u>Security Control</u>	_____
Building Occupants	☒	☐	<u>Management</u>	_____
Building Management	☒	☐	<u>J</u>	_____
Other (Specify)	☐	☐	_____	_____
AHJ Notified of Any Impairments	☐	☐	_____	_____

SYSTEM TESTS AND INSPECTIONS			
TYPE	Visual	Functional	Comments
Control Unit	☒	☒	_____
Interface Equipment	☐	☐	_____
Lamps/LEDs	☒	☒	_____
Fuses	☒	☒	_____
Primary Power Supply	☒	☒	_____
Trouble Signals	☒	☐	_____
Disconnect Switches	☐	☐	_____
Ground-Fault Monitoring	☒	☒	_____

SECONDARY POWER			
TYPE	Visual	Functional	Comments
Battery Condition	☒	☐	_____
Load Voltage		☐	_____
Discharge Test		☐	_____
Charger Test		☐	_____
Specific Gravity		☐	_____

TRANSIENT SUPPRESSORS			
	Visual	Functional	Comments
	☐		_____

REMOTE ANNUNCIATORS			
	Visual	Functional	Comments
	☐	☐	_____

NOTIFICATION APPLIANCES			
	Visual	Functional	Comments
Audible	☒	☒	_____
Visible	☒	☒	_____
Speakers	☐	☐	_____
Voice Clarity		☐	_____

INITIATING AND SUPERVISORY DEVICE TESTS AND INSPECTIONS							
Loc. & S/N	Device Type	Visual Check	Functional Test	Factory Setting	Measured Setting	Pass	Fail
<u>Smoke 6</u>	<u>Halls</u>	☒	☐	_____	_____	☒	☐
<u>Heads</u>	<u>Halls</u>	☒	☐	_____	_____	☒	☐
<u>Push</u>	<u>Exits</u>	☒	☐	_____	_____	☒	☐
<u>Tamper 3</u>	<u>Rest Room</u>	☒	☐	_____	_____	☒	☐
<u>Flow Switch</u>	<u>Rest Room</u>	☐	☐	_____	_____	☐	☐

Comments: _____

FIGURE 10.6.2.3 Continued



INSPECTION, TESTING, AND MAINTENANCE

72-118

EMERGENCY COMMUNICATIONS EQUIPMENT		Visual	Functional	Comments
Phone Set		☐	☐	
Phone Jacks		☐	☐	
Off-Hook Indicator		☐	☐	
Amplifier(s)		☐	☐	
Tone Generator(s)		☐	☐	
Call-in Signal		☐	☐	
System Performance		☐	☐	

COMBINATION SYSTEMS		Visual	Device Operation	Simulated Operation
Fire Extinguisher Monitoring Device/System		☐	☐	☐
Carbon Monoxide Detector/System		☐	☐	☐
(Specify) _____		☐	☐	☐

INTERFACE EQUIPMENT		Visual	Device Operation	Simulated Operation
(Specify) Door Release		☒	☒	☐
(Specify) AHU Shutdown		☒	☒	☐
(Specify) _____		☐	☐	☐

SPECIAL HAZARD SYSTEMS		Visual	Device Operation	Simulated Operation
(Specify) Kitchen Hood		☐	☐	☒
(Specify) _____		☐	☐	☐
(Specify) _____		☐	☐	☐

Special Procedures: _____

Comments: _____

SUPERVISING STATION MONITORING		Yes	No	Time	Comments
Alarm Signal		☒	☐		
Alarm Restoration		☒	☐		
Trouble Signal		☒	☐		
Trouble Signal Restoration		☒	☐		
Supervisory Signal		☒	☐		
Supervisory Restoration		☒	☐		

NOTIFICATIONS THAT TESTING IS COMPLETE		Yes	No	Who	Time
Building Management		☒	☐	<u>Margaret</u>	
Monitoring Agency		☐	☐	<u>Security Central</u>	
Building Occupants		☐	☐	<u>Margaret</u>	
Other (Specify) _____		☐	☐		

The following did not operate correctly: _____

System restored to normal operation: Date: 1/17/17 Time: _____

THIS TESTING WAS PERFORMED IN ACCORDANCE WITH APPLICABLE NFPA STANDARDS.

Name of Inspector: Robert P. Harris Date: 1/17/17 Time: _____

Signature: _____

Name of Owner or Representative: KRIS BROWN Date: 1/17/17 Time: _____

Signature: _____

© 2007 National Fire Protection Association NFPA 72 (p. 4 of 4)

FIGURE 10.6.2.3 Continued





Hot Water Temperatures

Weekly Inspection

[illegible]