

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL041039	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED R 04/15/2025
---	---	--	--

NAME OF PROVIDER OR SUPPLIER BROOKDALE HIGH POINT NORTH AL (NC)	STREET ADDRESS, CITY, STATE, ZIP CODE 1568 SKEET CLUB ROAD HIGH POINT, NC 27265
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 000}	Initial Comments Report of a Construction Section Biennial Follow Up Survey conducted by Tod Hancock on April 15, 2025. Deficiencies remain uncorrected and a Plan of Correction is required.	{C 000}		
{C 189}	Building Equipment Maintained Safe, Operating SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in an adult care home shall be maintained in a safe and operating condition. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 3. Based on observation, the Facility failed to maintain the electrical system in a safe and operating condition. Findings on April 15, 2025: a. Exterior near HVAC Compressor #1 - the wall mounted ground-fault circuit-interrupter (GFCI) electrical power receptacle did not trip when the test button was pushed and when tested with a ground fault receptacle tester & circuit analyzer device. b. Exterior near HVAC Compressor #4 - the wall mounted ground-fault circuit-interrupter (GFCI) electrical power receptacle did not trip when the test button was pushed and when tested with a ground fault receptacle tester & circuit analyzer device.	{C 189}	Exterior GFCI outlets near compressor #1 and compressor #4 to be replaced.	4/28/2025

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

STATE FORM

6899

VTJ322

If continuation sheet 1 of 1

[Signature] 5/29/25 Executive Director