

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL041031	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED R 03/18/2025
NAME OF PROVIDER OR SUPPLIER BROOKDALE NORTHWEST GREENSBORO		STREET ADDRESS, CITY, STATE, ZIP CODE 5809 OLD OAK RIDGE ROAD GREENSBORO, NC 27410		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 000}	Initial Comments Report of a Construction Section Biennial Follow Up Survey by Tod Hancock, conducted on March 18, 2025. Deficiencies remain uncorrected and a Plan of Correction is required.	{C 000}	The community will coordinate with the Fire Marshall to schedule a time to address any unresolved deficiencies Following the Fire Marshall's visits the community will submit documentation that all issues have been resolved and compliance has been achieved	10/01/25
{C 111}	Must Have Current San. & Fire Safety Reports SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0302 DESIGN AND CONSTRUCTION(f) The facility shall have current sanitation and fire and building safety inspection reports which shall be maintained in the home and available for review. This Rule is not met as evidenced by: 1. Based on an interview with the Executive Director and Maintenance Director the facility failed to maintain in the facility, current (completed within the last twelve months) sanitation and fire and building safety inspection reports available for review. Findings March 18, 2025: a. There was no Fire Official (Fire Marshal) report available for review. b. There was no Standard for the Inspection, Testing, and Maintenance of Water-Base Fire Protection System (NFPA 25) report available for review.	{C 111}		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Casandra Nixon 07/01/25

Executive Director