Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Mallon Place Inc	***Provider Number***	001017
Address	1724 MALLON ,	***Approval Status***	Approved
City, State, Zip	Spokane, WA 99201	***Facility Type***	Residential Care

On 06/05/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin - (ITM) Inspection, Testing, & Maintenance

Any citation that requires inspection, testing, or maintenance (ITM) is required to have the testing completed, paper results delivered, and any deficiencies found during the ITM corrected before the citation is cleared."	For your information.

2 Relocatable power taps and current taps

Relocatable power taps and current taps. The construction and use of current taps and relocatable power taps shall be in accordance with NFPA 70 and this code. (IFC 603.5, 2021)	The following violations were observed: In the basement there is a refrigerator plugged into a powerstrip. CORRECTED AT INSPECTION.

3 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2021) NFPA 72 14.4.5.4.1 Smoke alarms shall not remain in service longer than 10 years from the date of manufacture, unless otherwise provided by the manufacturer's published instructions.	The following violations were observed: In staff restroom number 4 there is a smoke detector that is older than 10 years. REPLACED AT INSPECTION.

Initials of Authorized Facility Representative:

This document was prepared by Residential Care Services for the Locator website.

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Mallon Place Inc	***Provider Number***	001017
Address	1724 MALLON ,	***Approval Status***	Approved
City, State, Zip	Spokane, WA 99201	***Facility Type***	Residential Care

On 06/05/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
4 Fire Drills	
In all Group I, Group E, and Group R2 Occupancies licensed by the state and inspected by the state fire marshal's office, at least twelve planned and unannounced fire drills shall be held every year. (1) Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. (2) A detailed written record of all fire drills shall be maintained and available for inspection. (3) When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms.	The following violations were observed: The following Drill was missing. 4th Quarter (October - December 2025) - night shift Facility is reminded that fire drills are required on all shifts, one each per quarter.

Next inspection scheduled on or after: 07/31/2027

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Richard Harless IV Maintenance
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746

Barbara R. McMullen
Digitally signed by Barbara R. McMullen
Date: 2026.06.09 05:21:56 -07'00'

Signature

Initials of Authorized Facility Representative:

This document was prepared by Residential Care Services for the Locator website.