Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Country Meadow Village	***Provider Number***	001020
Address	1501 COLLINS RD ,	***Approval Status***	Approved
City, State, Zip	Sedro-Woolley, WA 98284	***Facility Type***	Residential Care

On 06/09/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin Complaint

COMPLAINT # 226617 Here's a complaint of Fire Pannel Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	Complaint ref # 226617 At 1000 on 06/09/2026, DSFM Brown conducted complaint inspection for Country Meadow Village located at 1501 Collins Rd, Sedro-Woolley, WA 98284 to investigate complaint ref # 226617. I interviewed the Facility Maintenance Director. On 05/31/2026, the installed fire alarm system activated and indicated smoke in the 300 hallway of the community. Staff searched all rooms within the 300 hallway and found no indication of smoke. The facility contacted the fire alarm vendor who said to enter fire watch until they could arrive on Monday. Vendor was on site 6/1/2026 and found a loose wire which was repaired. System is back to normal and operational. No sprinkler activation No evacuation No injuries were report. Fire department did respond. No violations observed.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Country Meadow Village	***Provider Number***	001020
Address	1501 COLLINS RD ,	***Approval Status***	Approved
City, State, Zip	Sedro-Woolley, WA 98284	***Facility Type***	Residential Care

On 06/09/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Susan Cortez Maint

Signature *Print Name and Title*

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

Signature

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____