Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Country Meadow Village	***Provider Number***	001020
Address	1501 COLLINS RD ,	***Approval Status***	Approved
City, State, Zip	Sedro-Woolley, WA 98284	***Facility Type***	Residential Care

On 08/18/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Susan Carter

Signature

Susan Carter Maintenance

Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

Signature

This document was prepared by Residential Care Services for the Locator website.

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Country Meadow Village	***Provider Number***	001020
Address	1501 COLLINS RD ,	***Approval Status***	Disapproved
City, State, Zip	Sedro-Woolley, WA 98284	***Facility Type***	Residential Care

On 07/14/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Extension Cords

Extension cords. Extension cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.. (IFC 603.6 2021)	There was an extension cord utilized as permanent wiring in room 312 bathroom.

2 Appliance Connection to Building Piping

Gas-fired commercial cooking appliances installed on casters and appliances that are moved for cleaning and sanitation purposes shall be connected to the piping system with an appliance connector listed as complying with ANSI Z21.69/CSA 6.16. The commercial cooking appliance connector installation shall be configured in accordance with the manufacturer's installation instructions. Movement of appliances with casters shall be limited by a restraining device installed in accordance with the connector and appliance manufacturer's instructions. (IFC 606.4 2021)	The gas appliances on casters in the kitchen are not limited by a restraining device.

3 Door Operation

Swinging fire doors shall close from the full-open position and latch automatically. (IFC 705.2.4 2021)	The fire rated cross corridor door near room 116 would not close and latch from the fully open position.

4 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	The sprinkler contractor that completed the annual testing and inspection on 9/22/2025 was not certified to complete the work.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Country Meadow Village	***Provider Number***	001020
Address	1501 COLLINS RD ,	***Approval Status***	Disapproved
City, State, Zip	Sedro-Woolley, WA 98284	***Facility Type***	Residential Care

On 07/14/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
5 Maintenance	
Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required. (IFC 1203.4 2021)	Facility is unable to provide documentation for the generator monthly 30 minute full load testing.

Next inspection scheduled on or after: 08/13/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

S. Cortez
Signature

Susan Cortez Maintenance
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

Signature

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____