Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fairview Assisted Living Inc	***Provider Number***	001146
Address	1617 Calsipel ,	***Approval Status***	Approved
City, State, Zip	Spokane, WA 99205	***Facility Type***	Residential Care

On 06/24/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Administration

	Extension request received from Jeremiah Brucell for 30 days.

2 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Sprinklers replaced.

3 Hydraulic Design Information Sign

25.5* Hydraulic Design Information Sign. 25.5.1 The installing contractor shall identify a hydraulically designed sprinkler system with a permanently marked weatherproof metal or rigid plastic sign secured with corrosionresistant wire, chain, or other approved means. Such signs shall be placed at the alarm valve, dry pipe valve, preaction valve, or deluge valve supplying the corresponding hydraulically designed area. 25.5.2 The sign shall include the following information: (1) Location of the design area or areas (2) Discharge densities over the design area or areas (3) Required flow and residual pressure demand at the base of the riser (4) Occupancy classification or commodity classification and maximum permitted storage height and configuration (5) Hose stream allowance included in addition to the sprinkler demand (6) The name of the installing contractor	New placards provided.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fairview Assisted Living Inc	***Provider Number***	001146
Address	1617 Calsipel ,	***Approval Status***	Approved
City, State, Zip	Spokane, WA 99205	***Facility Type***	Residential Care

On 06/24/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
4 Fire Drills	
In all Group I, Group E, and Group R2 Occupancies licensed by the state and inspected by the state fire marshal's office, at least twelve planned and unannounced fire drills shall be held every year. (1) Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. (2) A detailed written record of all fire drills shall be maintained and available for inspection. (3) When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms.	Completed.

Next inspection scheduled on or after: 05/31/2027

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Heidi Bozett
Signature

Heidi Bozett / owner
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746

Barbara McMullen
Signature

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fairview Assisted Living Inc	***Provider Number***	001146
Address	1617 Calsipel ,	***Approval Status***	Disapproved
City, State, Zip	Spokane, WA	***Facility Type***	Residential Care

On 04/16/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin - (ITM) Inspection, Testing, & Maintenance

Any citation that requires inspection, testing, or maintenance (ITM) is required to have the testing completed, paper results delivered, and any deficiencies found during the ITM corrected before the citation is cleared."	For your information.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fairview Assisted Living Inc	***Provider Number***	001146
Address	1617 Calsipel ,	***Approval Status***	Disapproved
City, State, Zip	Spokane, WA	***Facility Type***	Residential Care

On 04/16/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

2 Testing and Maintenance

Code Requirement	Statement of Violation
Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	The following violation was observed: 1. The sprinklers in the kitchen have extreme amounts of particulates attached. 2. The sprinkler in the oxygen room and outside of the office on the main floor are broken. For your information regarding UL testing of sprinklers. NFPA 25, Chapter 5.3.1 Sprinklers 5.3.1.1 Where required by this section, sample sprinklers shall be submitted to a recognized testing laboratory acceptable to the authority having jurisdiction for field service testing. 5.3.1.1.1 Where sprinklers have been in service for 50 years, they shall be replaced or representative samples from one or more sample areas shall be tested. 5.3.1.1.1.1 Test procedures shall be repeated at 10-year intervals. 5.3.1.1.1.2 Sprinklers manufactured prior to 1920 shall be replaced. 5.3.1.1.1.3 Sprinklers manufactured using fast-response elements that have been in service for 20 years shall be replace or a representative samples shall be tested and then retested at 10 year intervals. 5.3.1.1.1.4 Representative samples of solder-type sprinklers with a temperature classification of extra high (325 degrees F) or greater that are exposed to semi-continuous to continuous maximum allowable ambient temperature conditions shall be tested at 5 year intervals. 5.3.1.1.1.5 Where sprinklers have been in service for 75 years, they shall be replaced or representative samples from one or more sample areas shall be submitted to a recognized testing laboratory acceptable to the authority having jurisdiction for field service testing and repeated at 5 year intervals. 5.3.1.1.1.6 Dry sprinklers that have been in service for 10 years shall be replaced or representative samples shall be tested and then retested at 10-year intervals. 5.3.1.1.2 Where sprinklers are subjected to harsh environments, including corrosive atmospheres and corrosive water supplies, on a 5 year basis, either sprinklers shall be replaced or a representative sample shall be tested.

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.

Business Name	Fairview Assisted Living Inc	***Provider Number***	001146
Address	1617 Calsipel ,	***Approval Status***	Disapproved
City, State, Zip	Spokane, WA	***Facility Type***	Residential Care

On 04/16/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
	5.3.1.2 A representative sample of sprinklers for testing per 5.3.1.1.1 shall consist of a minimum of not less than four sprinklers or 1 percent of the number of sprinklers per individual sprinkler sample, whichever is greater. 5.3.1.3 Where one sprinkler within a representative sample fails to meet the test requirement, all sprinklers within the area represented by that sample shall be replaced.

3 Hydraulic Design Information Sign

25.5* Hydraulic Design Information Sign. 25.5.1 The installing contractor shall identify a hydraulically designed sprinkler system with a permanently marked weatherproof metal or rigid plastic sign secured with corrosionresistant wire, chain, or other approved means. Such signs shall be placed at the alarm valve, dry pipe valve, preaction valve, or deluge valve supplying the corresponding hydraulically designed area. 25.5.2 The sign shall include the following information: (1) Location of the design area or areas (2) Discharge densities over the design area or areas (3) Required flow and residual pressure demand at the base of the riser (4) Occupancy classification or commodity classification and maximum permitted storage height and configuration (5) Hose stream allowance included in addition to the sprinkler demand (6) The name of the installing contractor	The following violation was observed: The hydraulic design information is unreadable.

4 Fire Drills

In all Group I, Group E, and Group R2 Occupancies licensed by the state and inspected by the state fire marshal's office, at least twelve planned and unannounced fire drills shall be held every year. (1) Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. (2) A detailed written record of all fire drills shall be maintained and available for inspection. (3) When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms.	The following violation was observed: Facility did not complete a swing shift fire drill for: 1st Quarter 2026 (January - March) Facility shall complete an additional swing shift drill prior to reinspection.

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fairview Assisted Living Inc	***Provider Number***	001146
Address	1617 Calsipel ,	***Approval Status***	Disapproved
City, State, Zip	Spokane, WA	***Facility Type***	Residential Care

On 04/16/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement — Statement of Violation

Next inspection scheduled on or after: 05/16/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Heidi Bozett
Signature

Heidi Bozett / owner
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746

Barbara
Signature

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.