Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fairwinds Spokane	***Provider Number***	001455
Address	520 HOLLAND AVE ,	***Approval Status***	Approved
City, State, Zip	Spokane, WA 992181207	***Facility Type***	Residential Care

On 06/16/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin Complaint

COMPLAINT # 226894 Here's a complaint of Fire Pannel Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? N/A 2. If the sprinklers were activated? No 3. If there was an evacuation / how many were evacuated? No/none 4. If there were injuries / how many? None 5. Did the fire department respond? No	On June 16, 2026 a representative from the State Fire Marshals office conducted a complaint inspection at the Fairwinds of Spokane, 520 East Holland Ave for complaint 226894. On 5/28/26 there was a severe thunder storm in the area that caused an issue with the power in the building, this power outage also caused a problem with the NAC/circuit board in the fire alarm system. The alarm panel was displaying an alert and the fire alarm contractor was immediately notified. The fire alarm contractor responded on 5/29/26, provided another power source until repairs could be made. On 5/30/26 it was discovered that there were additional issues with the fire alarm system, the facility then went into fire watch. Fire alarm contractor completed repairs on 6/3/26 and system is back online. Fire watch documents reviewed; fire alarm contractor documents reviewed, facility followed their policies and procedures. No violations cited.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fairwinds Spokane	***Provider Number***	001455
Address	520 HOLLAND AVE ,	***Approval Status***	Approved
City, State, Zip	Spokane, WA 992181207	***Facility Type***	Residential Care

On 06/16/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Michelle DeLeon Ferreira
Signature

Michelle DeLeon Ferreira, General Manager
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) [illegible]

Barbara R. McMullen
Signature

Digitally signed by Barbara R. McMullen
Date: 2026.06.18 07:05:26 -07'00'

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____