




Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Park Place	Provider Number	001532
Address	6900 37TH AVE S,	Approval Status	Approved
City, State, Zip	Seattle, WA	Facility Type	Residential Care

On 09/09/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

Don Vince Cruz Environmental Service
Print Name and Title Director

Deputy State Fire Marshal Jason Van Gorkum
2502 112 ST E
Tacoma WA 984455104
(509) 406-7209

Jason Van Gorkum Date: 2025.09.10
10:13:51 -07'00'
Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Park Place	Provider Number	001532
Address	6900 37TH AVE S,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98118	Facility Type	Residential Care


On 03/27/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
9. Latching hardware operates and secures the door when it is in the closed position 10. Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame 11. No field modification to the door assembly have been preformed that void the label. 12. Meeting edge protection, gasketing and edge seals where required, are inspected to verify their presence and intertie 13. Signage affixed to a door meets the requirements listed in 4.1.4	

Next inspection scheduled on or after: 05/05/2025


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Marta Vince-Cruz, Executive Director
Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum
2803 156 AVE SE
Bellevue WA 98007
(509) 406-7209


Signature