Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	University House At Issaquah	***Provider Number***	001565
Address	22975 SE BLACK NUGGET RD ,	***Approval Status***	Approved
City, State, Zip	Issaquah, WA 98029	***Facility Type***	Residential Care

On 09/28/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin Complaint

COMPLAINT # 241928 Here's a complaint of Fire Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	1. The fire was caused by a stove that was left on and some paper towels 2. Yes the fire sprinklers activated 3. One person was laterally evacuated from the fire area. 4. No injuries 5. Yes the fire department responded. No violations noted

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature *Print Name and Title*

Deputy State Fire Marshal Arthur Jesse Ward
2502 112 ST E
Tacoma WA 984455104
(425) 401-7735

Jesse Ward
Signature

Digitally signed by Jesse Ward
Date: 2026.10.08 07:53:41 -07'00'

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.