Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Wheatland Village Assisted Living	***Provider Number***	001640
Address	1500 CATHERINE ST ,	***Approval Status***	Approved
City, State, Zip	Walla Walla, WA 99362	***Facility Type***	Residential Care

On 07/23/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Ann Adrian

Signature

Ann Adrian, Sr. Executive Director

Print Name and Title

Deputy State Fire Marshal Alan Harlan
2803 156TH AVE SE
Bellevue WA 98007
(425) 495-7121

Alan Harlan Digitally signed by Alan Harlan Date: 2026.07.23 15:42:52 -07'00'

Signature

This document was prepared by Residential Care Services for the Locator website.

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Wheatland Village Assisted Living	***Provider Number***	001640
Address	1500 CATHERINE ST ,	***Approval Status***	Disapproved
City, State, Zip	Walla Walla, WA 99362	***Facility Type***	Residential Care

On 07/01/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin - (ITM) Inspection, Testing, & Maintenance

Any citation that requires inspection, testing, or maintenance (ITM) is required to have the testing completed, paper results delivered, and any deficiencies found during the ITM corrected before the citation is cleared."	

2 Working Space and Clearance

Working space and clearances. Working space around electrical equipment shall be provided in accordance with Section 110.26 of NFPA 70 for electrical equipment rated 1,000 volts or less, and Section 110.32 of NFPA 70 for electrical equipment rated over 1,000 volts. The minimum required working space shall be not less than 30 inches (762 mm) in width, 36 inches (914 mm) in depth and 78 inches (1981 mm) in height in front of electrical service equipment. Where the electrical service equipment is wider than 30 inches (762 mm), the minimum working space shall be not less than the width of the equipment. Storage of materials shall not be located within the designated working space. (IFC 603.4, 2021)	Corrected

3 Relocatable power taps and current taps

Relocatable power taps and current taps. The construction and use of current taps and relocatable power taps shall be in accordance with NFPA 70 and this code. (IFC 603.5, 2021)	The following violation was observed: 1) Room 318 non unfused powerstrip.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Business Name	Wheatland Village Assisted Living	***Provider Number***	001640
Address	1500 CATHERINE ST ,	***Approval Status***	Disapproved
City, State, Zip	Walla Walla, WA 99362	***Facility Type***	Residential Care

On 07/01/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

4 Application and Use

603.5.2 Application and use. Relocatable power taps and current taps shall be directly connected to a permanently installed receptacle. Exceptions: 1. Where approved for use in a Group A occupancy or in a meeting room in a Group B occupancy, not more than five relocatable power taps shall be permitted to be connected together or connected to an extension cord for temporary use to supply power to electronic equipment. 2. Current taps and relocatable power taps shall not be required to connect directly to a permanently installed receptacle outlet where used for 90 days or less for the purpose of testing the performance of such devices. (IFC 603.5.2, 2021)	Corrected

5 Extension Cords

Extension cords. Extension cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.. (IFC 603.6 2021)	The following location's had extension cords being used for permanent wiring 1) 2nd floor health services nurses office.

6 Portable Electric Space Heaters - Listed & Labled

Only listed and labeled portable, electric space heaters shall be used. (IFC 0605.10.1)	Corrected

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Business Name	Wheatland Village Assisted Living	***Provider Number***	001640
Address	1500 CATHERINE ST ,	***Approval Status***	Disapproved
City, State, Zip	Walla Walla, WA 99362	***Facility Type***	Residential Care

On 07/01/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
7 Cleaning	
Hoods, grease-removal devices, fans, ducts and other appurtenances shall be cleaned at intervals as required by Sections 606.3.3.1 through 606.3.3.3. (IFC 606.3.3 2021)	Corrected
8 Owner's Responsibility	
The owner shall maintain an inventory of all required fire-resistance-rated construction, construction installed to resist the passage of smoke and the construction included in Sections 703 through 707 and Sections 602.4.1 and 602.4.2 of the International Building Code. Such construction shall be visually inspected by the owner annually and properly repaired, restored or replaced where damaged, altered, breached or penetrated. Records of inspections and repairs shall be maintained. Where concealed, such elements shall not be required to be visually inspected by the owner unless the concealed space is accessible by the removal or movement of a panel, access door, ceiling tile or similar movable entry to the space. (IFC 701.6 2021)	Corrected
9 Penetrations - Maintaining Protection	
Materials and firestop systems used to protect membrane and through penetrations in fire-resistance-rated construction and construction installed to resist the passage of smoke shall be maintained. The materials and firestop systems shall be securely attached to or bonded to the construction being penetrated with no openings visible through or into the cavity of the construction. Where the system design number is known, the system shall be inspected to the listing criteria and manufacturer's installation instructions. (IFC 703.1 2021)	The following location's had penetrations in fire-resistance-rated construction and construction installed to resist the passage of smoke: 1) Prep area near door.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Business Name	Wheatland Village Assisted Living	***Provider Number***	001640
Address	1500 CATHERINE ST ,	***Approval Status***	Disapproved
City, State, Zip	Walla Walla, WA 99362	***Facility Type***	Residential Care

On 07/01/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

10 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified. (IFC 705.2 2021)	The following fire/ / smoke doors were propped open: 1) ~~3 A fire door was obstructed by a hand sanitizer stand.~~ 2) Room 317 doorstop Corrected 3) Room 318 doorstop 4) Room 117 doorstop

11 Duct and Air Transfer Openings - Maintaining Protection

Dampers protecting ducts and air transfer openings shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Other products or materials used to protect the openings for ducts and air transfer openings shall be securely attached to or bonded to the construction containing the duct or air transfer opening, without visible openings through or into the cavity of the construction. Any damaged products or materials protecting duct and air transfer openings shall be repaired, restored or replaced. (IFC 706.1 2018)	Facility was unable to provide documentation that the 4 year fire/smoke damper inspection had been performed for Wheatland and Parkview. All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

12 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Corrected

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Business Name	Wheatland Village Assisted Living	***Provider Number***	001640
Address	1500 CATHERINE ST ,	***Approval Status***	Disapproved
City, State, Zip	Walla Walla, WA 99362	***Facility Type***	Residential Care

On 07/01/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

13 Portable Fire Extinguishers - General Requirements

Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10. Exceptions: 1. The distance of travel to reach an extinguisher shall not apply The travel distance to reach an extinguisher shall not apply to the spectator seating portions of Group A-5 occupancies. 2. Thirty-day inspections shall not be required and maintenance shall be allowed to be once every three years for dry-chemical or halogenated agent portable fire extinguishers that are supervised by a listed and approved electronic monitoring device, provided that all of the following conditions are met: 2.1. Electronic monitoring shall confirm that extinguishers are properly positioned, properly charged and unobstructed. 2.2. Loss of power or circuit continuity to the electronic monitoring device shall initiate a trouble signal. 2.3. The extinguishers shall be installed inside of a building or cabinet in a noncorrosive environment. 2.4. Electronic monitoring devices and supervisory circuits shall be tested every 3 years when extinguisher maintenance is performed. 2.5. A written log of required hydrostatic test dates for extinguishers shall be maintained by the owner to verify that hydrostatic tests are conducted at the frequency required by NFPA 10. 3. In Group I-3, portable fire extinguishers shall be permitted to be located at staff locations. (IFC 906.2 2021)	The following violation was observed: 1) The fire extinguisher in elevator room missing monthly inspection.

14 Installation and Monitoring

fire alarm system shall be installed and monitored in accordance with Sections 907.6.1 through 907.6.6.3 and NFPA 72. (IFC 907.6 2021)	Corrected

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Business Name	Wheatland Village Assisted Living	***Provider Number***	001640
Address	1500 CATHERINE ST ,	***Approval Status***	Disapproved
City, State, Zip	Walla Walla, WA 99362	***Facility Type***	Residential Care

On 07/01/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
15 Where Required Carbon monoxide detection shall be provided in Group I and R occupancies and in classrooms in Group E occupancies in the locations specified in Section 915.2 where any of the conditions in Sections 915.1.2 through 915.1.6 exist. EXCEPTIONS: 1. R-2 occupancies, with the exception of R-2 college dormitories, are required to install carbon monoxide detectors without exception. 2. Sleeping units or dwelling units in I and R-1 occupancies and R-2 college dormitories, hotel, DOC prisons and work releases and assisted living facilities and residential treatment facilities licensed by the state of Washington, which do not themselves contain a fuel-burning appliance, a fuel-burning fireplace, or have an attached garage, need not be provided with carbon monoxide alarms provided that they comply with the exceptions of Section 915.1.4. (IFC 915.1.1 2021 WAC 51-54A)	Corrected

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Wheatland Village Assisted Living	***Provider Number***	001640
Address	1500 CATHERINE ST ,	***Approval Status***	Disapproved
City, State, Zip	Walla Walla, WA 99362	***Facility Type***	Residential Care

On 07/01/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
16 Controlled Egress Doors in Groups I-1 and I-2	
Electric locking systems, including electromechanical locking systems and electromagnetic locking systems, shall be permitted to be locked in the means of egress in Group I-1 or I-2 occupancies where the clinical needs of persons receiving care require their containment. Controlled egress doors shall be permitted in such occupancies where the building is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or an approved automatic smoke or heat detection system installed in accordance with Section 907, provided that the doors are installed and operate in accordance with all of the following: 1. The doors shall unlock on actuation of the automatic sprinkler system or automatic smoke detection system. 2. The door locks shall unlock on loss of power controlling the lock or lock mechanism. 3. The door locking system shall be installed to have the capability of being unlocked by a switch located at the fire command center, a nursing station or other approved location. The switch shall directly break power to the lock. 4. A building occupant shall not be required to pass through more than one door equipped with a controlled egress locking system before entering an exit. 5. The procedures for unlocking the doors shall be described and approved as part of the emergency planning and preparedness required by Chapter 4 of the International Fire Code. 6. There is a system, such as a keypad and code, in place that allows visitors, staff persons and appropriate residents to exit. Instructions for exiting shall be posted within six feet of the door. 7. All clinical staff shall have the keys, codes or other means necessary to operate the locking systems. 8. Emergency lighting shall be provided at the door. 9. The door locking system units shall be listed in accordance with UL 294. EXCEPTIONS: 1. Items 1 through 4 and 6 shall not apply to doors to areas where persons, which because of clinical needs, require restraint or containment as part of the function of a psychiatric treatment area.	Corrected

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Business Name	Wheatland Village Assisted Living	***Provider Number***	001640
Address	1500 CATHERINE ST ,	***Approval Status***	Disapproved
City, State, Zip	Walla Walla, WA 99362	***Facility Type***	Residential Care

On 07/01/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
2. Items 1 through 4 and 6 shall not apply to doors to areas where a listed egress control system is utilized to reduce the risk of child abduction from nursery and obstetric areas of a Group I-2 hospital. (IFC 1010.1.9.7 2021 WAC 51-54A)	

17 Power Source

Exit signs shall be illuminated at all times. To ensure continued illumination for a duration of not less than 90 minutes in case of primary power loss, the sign illumination means shall be connected to an emergency power system provided from storage batteries, unit equipment or an on-site generator. The installation of the emergency power system shall be in accordance with Section 603. Group I-2, Condition 2 exit sign illumination shall not be provided by unit equipment batteries only. Exception: Approved exit sign illumination types that provide continuous illumination independent of external power sources for a duration of not less than 90 minutes, in case of primary power loss, are not required to be connected to an emergency electrical system. (IFC 1013.6.3 2021)	Corrected

18 Obstructions

A means of egress shall be free from obstructions that would prevent its use, including the accumulation of snow and ice. (IFC 1032.3 2021)	Corrected

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Business Name	Wheatland Village Assisted Living	***Provider Number***	001640
Address	1500 CATHERINE ST ,	***Approval Status***	Disapproved
City, State, Zip	Walla Walla, WA 99362	***Facility Type***	Residential Care

On 07/01/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
19 Securing Compressed Gas Containers, Cylinders and Tanks	
Compressed gas containers, cylinders and tanks shall be secured to prevent falling caused by contact, vibration or seismic activity. Securing of compressed gas containers, cylinders and tanks shall be by one of the following methods: 1. Securing containers, cylinders and tanks to a fixed object with one or more restraints. 2. Securing containers, cylinders and tanks on a cart or other mobile device designed for the movement of compressed gas containers, cylinders or tanks. 3. Nesting of compressed gas containers, cylinders and tanks at container filling or servicing facilities or in sellers' warehouses not open to the public. Nesting shall be allowed provided that the nested containers, cylinders or tanks, if dislodged, do not obstruct the required means of egress. 4. Securing of compressed gas containers, cylinders and tanks to or within a rack, framework, cabinet or similar assembly designed for such use. Exception: Compressed gas containers, cylinders and tanks in the process of examination, filling, transport or servicing. (IFC 5303.5.3 2021)	Corrected

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Wheatland Village Assisted Living	***Provider Number***	001640
Address	1500 CATHERINE ST ,	***Approval Status***	Disapproved
City, State, Zip	Walla Walla, WA 99362	***Facility Type***	Residential Care

On 07/01/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
20 Fire Drills	
In all Group I, Group E, and Group R2 Occupancies licensed by the state, at least twelve planned and unannounced fire drills shall be held every year. Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. A detailed written record of all fire drills shall be maintained and available for inspection at all times. When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms. Fire drills shall include the transmission of a fire alarm signal and simulation of emergency conditions. The fire alarm monitoring company shall be notified prior to the activation of the fire alarm system for drill purposes and again at the conclusion of the transmission and restoration of the fire alarm system to normal mode. (WAC 212-12-044)	Corrected

Next inspection scheduled on or after: 07/31/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Ron Burt Plant Ops. Director
Print Name and Title

Deputy State Fire Marshal Alan Harlan
2803 156TH AVE SE
Bellevue WA 98007
(425) 495-7121

Signature

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.