



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Olympic Place Retirement & AL Community	Provider Number	001712
Address	20909 OLYMPIC PL NE,	Approval Status	Approved
City, State, Zip	Arlington, WA 98223	Facility Type	Residential Care

On 09/10/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Signature

Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

Signature

This document was prepared by Residential Care Services for the Locator website.

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Olympic Place Retirement & AL Community	Provider Number	001712
Address	20909 OLYMPIC PL NE,	Approval Status	Disapproved
City, State, Zip	Arlington, WA 98223	Facility Type	Residential Care

On 08/22/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 142968 Here's a complaint of fire alarm Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	Complaint ref # 142968 At 1345 on 08/22/2024, DSFM Brown conducted complaint inspection for Olympic Place Retirement & AL Community located at 20909 Olympic PI NE, Arlington, WA, 98223. An interview with the Regional Maintenance Director, to investigate complaint ref# 142968 was completed. At approximately 0430 on 08/15/2024 the fire alarm was activated due to an air leak in the sprinkler system. The fire department is respond and secured to water to the dry and wet system. The facility is currently on fire watch. Vendor is scheduled to arrive this evening to place the system back in operation. No residents were evacuated and no damages to the facility. No injuries were report. IFC violations are as follows.
--	--

2 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2009, 2012, 2015, 2018)	The dry and wet sprinkler system are not operational.
--	---

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Olympic Place Retirement & AL Community	Provider Number	001712
Address	20909 OLYMPIC PL NE,	Approval Status	Disapproved
City, State, Zip	Arlington, WA 98223	Facility Type	Residential Care

On 08/22/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 09/21/2024

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

Signature

This document was prepared by Residential Care Services for the Locator website.