




Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Olympic Place Retirement & AL Community	Provider Number	001712
Address	20909 OLYMPIC PL NE,	Approval Status	Approved
City, State, Zip	Arlington, WA	Facility Type	Residential Care

On 10/29/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature


Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Olympic Place Retirement & AL Community	Provider Number	001712
Address	20909 OLYMPIC PL NE,	Approval Status	Disapproved
City, State, Zip	Arlington, WA	Facility Type	Residential Care

On 09/11/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 193247 Here's a complaint of Fire Alarm Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	Complaint ref # 193247 At 1500 on 09/11/2025, DSFM Brown conducted complaint inspection for Olympic Place Retirement & AL Community located at 20909 Olympic Pl, Arlington, WA 98223 to investigate complaint ref # 1193247. I interviewed the Facility Maintenance Director. During a re-inspection visit on 9/3/2025 it was discovered that the fire alarm system on the 3rd floor was not working and the entire fire alarm system was in test mode and will not contact emergency service. System was producing multiple false alarms so the system was place in test mode. Facility was in fire watch, documentation was not be completed correctly. As of 9/11/2025 service technicians are currently troubleshoot the system, system is still in test mode, fire watch is being conducted on the 3rd floor every 15 minutes by a dedicated person, and fire watch documentation is being completed correctly. No injuries were report. IFC violations are as follows.
---	--

2 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	The installed fire alarms system is in trouble status. Alarms on the 3rd floor are not operational and system will not call emergency services.
---	--

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900


Business Name	Olympic Place Retirement & AL Community	Provider Number	001712
Address	20909 OLYMPIC PL NE,	Approval Status	Disapproved
City, State, Zip	Arlington, WA	Facility Type	Residential Care

On 09/11/2025 the Office of the State Fire Marshal conducted an inspection at your facility.


Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 10/11/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature


Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

Signature

This document was prepared by Residential Care Services for the Locator website.