Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Olympic Place Retirement & AL Community	***Provider Number***	001712
Address	20909 OLYMPIC PL NE,	***Approval Status***	Approved
City, State, Zip	Arlington, WA 98223	***Facility Type***	Residential Care

On 06/22/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin Complaint

COMPLAINT # 228551 Here's a complaint of Fire alarm Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	Complaint ref # 228551 At 1500 on 06/22/2026, DSFM Brown conducted complaint inspection for Olympic Place Retirement & AL Community located at 20909 Olympic Pl, Arlington, WA 98223 to investigate complaint ref # 228551. I interviewed the Facility Executive Director. On 6/13/2026 at approximately 1400 the Maintenance Director was attempting to drain the residual water from the dry sprinkler system. In doing so a mistake was made and the dry system was accidently charged with water which activated the fire alarm waterflow device. The facility stated fire watch as a precaution. Vender arrived on 6/15/2026 and reset the system. No sprinkler activation No evacuation No injuries were report. No violations observed.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Olympic Place Retirement & AL Community	***Provider Number***	001712
Address	20909 OLYMPIC PL NE,	***Approval Status***	Approved
City, State, Zip	Arlington, WA 98223	***Facility Type***	Residential Care

On 06/22/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Roxie Stormo-ED

Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

Signature

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____