Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Olympic Place Retirement & AL Community	***Provider Number***	001712
Address	20909 OLYMPIC PL NE,	***Approval Status***	Disapproved
City, State, Zip	Arlington, WA 98223	***Facility Type***	Residential Care

On 09/23/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified. (IFC 705.2 2021)	Facility is unable to provide documentation that the annual fire door inspection has been completed. Update: The documentation provided had deficiencies that have not been corrected.

2 Door Operation

Swinging fire doors shall close from the full-open position and latch automatically. (IFC 705.2.4 2021)	Corrected

3 Duct and Air Transfer Openings - Maintaining Protection

Dampers protecting ducts and air transfer openings shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Other products or materials used to protect the openings for ducts and air transfer openings shall be securely attached to or bonded to the construction containing the duct or air transfer opening, without visible openings through or into the cavity of the construction. Any damaged products or materials protecting duct and air transfer openings shall be repaired, restored or replaced. (IFC 706.1 2018)	Facility is unable to provide documentation for the 4 year fire and smoke damper inspection.

4 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Corrected

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Business Name	Olympic Place Retirement & AL Community	***Provider Number***	001712
Address	20909 OLYMPIC PL NE,	***Approval Status***	Disapproved
City, State, Zip	Arlington, WA 98223	***Facility Type***	Residential Care

On 09/23/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

5 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2021)	Corrected

6 Inspection and Maintenance

Fire department connections shall be periodically inspected, tested and maintained in accordance with NFPA 25. Records of inspection, testing and maintenance shall be maintained. (IFC 912.7 2021)	Corrected

7 Fuel-Burn Appliances Outside of Dwelling, Sleep Units & Classro

Carbon monoxide detection shall be provided in dwelling units, sleeping units and classrooms located in buildings that contain fuel-burning appliances or fuel-burning fireplaces. Exceptions: 1. Carbon monoxide detection shall not be required in dwelling units, sleeping units and classrooms without communicating openings between the fuel-burning appliance or fuel-burning fireplace and the dwelling unit, sleeping unit or classroom. 2. Carbon monoxide detection shall not be required in dwelling units, sleeping units and classrooms where a carbon monoxide detector is provided in one of the following locations: 2.1. In an approved location between the fuel-burning appliance or fuel-burning fireplace and the dwelling unit, sleeping unit or classroom. 2.2. On the ceiling of the room containing the fuel-burning appliance or fuel-burning fireplace. (IFC 915.1.4 2021)	Corrected

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Business Name	Olympic Place Retirement & AL Community	***Provider Number***	001712
Address	20909 OLYMPIC PL NE,	***Approval Status***	Disapproved
City, State, Zip	Arlington, WA 98223	***Facility Type***	Residential Care

On 09/23/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

8 Maintenance

Carbon monoxide alarms and carbon monoxide detection systems shall be maintained in accordance with NFPA 72. Carbon monoxide alarms and carbon monoxide detectors that become inoperable or begin producing end-of-life signals shall be replaced. (IFC 915.6 2021 WAC)	Corrected

9 Maintenance

Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required. (IFC 1203.4 2021)	Corrected

10 Securing Compressed Gas Containers, Cylinders and Tanks

Compressed gas containers, cylinders and tanks shall be secured to prevent falling caused by contact, vibration or seismic activity. Securing of compressed gas containers, cylinders and tanks shall be by one of the following methods: 1. Securing containers, cylinders and tanks to a fixed object with one or more restraints. 2. Securing containers, cylinders and tanks on a cart or other mobile device designed for the movement of compressed gas containers, cylinders or tanks. 3. Nesting of compressed gas containers, cylinders and tanks at container filling or servicing facilities or in sellers' warehouses not open to the public. Nesting shall be allowed provided that the nested containers, cylinders or tanks, if dislodged, do not obstruct the required means of egress. 4. Securing of compressed gas containers, cylinders and tanks to or within a rack, framework, cabinet or similar assembly designed for such use. Exception: Compressed gas containers, cylinders and tanks in the process of examination, filling, transport or servicing. (IFC 5303.5.3 2021)	Corrected

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Olympic Place Retirement & AL Community	***Provider Number***	001712
Address	20909 OLYMPIC PL NE,	***Approval Status***	Disapproved
City, State, Zip	Arlington, WA 98223	***Facility Type***	Residential Care

On 09/23/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
11 Fire Drills	
In all Group I, Group E, and Group R2 Occupancies licensed by the state and inspected by the state fire marshal's office, at least twelve planned and unannounced fire drills shall be held every year. (1) Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. (2) A detailed written record of all fire drills shall be maintained and available for inspection. (3) When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms.	Corrected

Next inspection scheduled on or after: 10/23/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Jennifer Dennis CEO Director

Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

Signature

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Olympic Place Retirement & AL Community	***Provider Number***	001712
Address	20909 OLYMPIC PL NE,	***Approval Status***	Disapproved
City, State, Zip	Arlington, WA 98223	***Facility Type***	Residential Care

On 08/18/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified. (IFC 705.2 2021)	Facility is unable to provide documentation that the annual fire door inspection has been completed.

2 Door Operation

Swinging fire doors shall close from the full-open position and latch automatically. (IFC 705.2.4 2021)	1. The fire rated cross corridor door near room 101 would not close and latch from the fully open position. 2. The two fire rated doors to the kitchen would not close and latch from the fully open position.

3 Duct and Air Transfer Openings - Maintaining Protection

Dampers protecting ducts and air transfer openings shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Other products or materials used to protect the openings for ducts and air transfer openings shall be securely attached to or bonded to the construction containing the duct or air transfer opening, without visible openings through or into the cavity of the construction. Any damaged products or materials protecting duct and air transfer openings shall be repaired, restored or replaced. (IFC 706.1 2018)	Facility is unable to provide documentation for the 4 year fire and smoke damper inspection.

4 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Facility is unable to provide documentation for the 5 year internal piping inspection.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Business Name	Olympic Place Retirement & AL Community	***Provider Number***	001712
Address	20909 OLYMPIC PL NE,	***Approval Status***	Disapproved
City, State, Zip	Arlington, WA 98223	***Facility Type***	Residential Care

On 08/18/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
5 Inspection, Testing and Maintenance	
The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2021)	Facility is unable to provide documentation for the annual fire alarm system testing.
6 Inspection and Maintenance	
Fire department connections shall be periodically inspected, tested and maintained in accordance with NFPA 25. Records of inspection, testing and maintenance shall be maintained. (IFC 912.7 2021)	Facility was unable to provide documentation that the Fire Department Connection has been hydrostatically tested in accordance with NFPA 25.
7 Fuel-Burn Appliances Outside of Dwelling, Sleep Units & Classro	
Carbon monoxide detection shall be provided in dwelling units, sleeping units and classrooms located in buildings that contain fuel-burning appliances or fuel-burning fireplaces. Exceptions: 1. Carbon monoxide detection shall not be required in dwelling units, sleeping units and classrooms without communicating openings between the fuel-burning appliance or fuel-burning fireplace and the dwelling unit, sleeping unit or classroom. 2. Carbon monoxide detection shall not be required in dwelling units, sleeping units and classrooms where a carbon monoxide detector is provided in one of the following locations: 2.1. In an approved location between the fuel-burning appliance or fuel-burning fireplace and the dwelling unit, sleeping unit or classroom. 2.2. On the ceiling of the room containing the fuel-burning appliance or fuel-burning fireplace. (IFC 915.1.4 2021)	There were no Carbon Monoxide alarm within near the 2nd floor fireplace.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Business Name	Olympic Place Retirement & AL Community	***Provider Number***	001712
Address	20909 OLYMPIC PL NE,	***Approval Status***	Disapproved
City, State, Zip	Arlington, WA 98223	***Facility Type***	Residential Care

On 08/18/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
8 Maintenance	
Carbon monoxide alarms and carbon monoxide detection systems shall be maintained in accordance with NFPA 72. Carbon monoxide alarms and carbon monoxide detectors that become inoperable or begin producing end-of-life signals shall be replaced. (IFC 915.6 2021 WAC)	Facility is unable to provide documentation for the monthly carbon monoxide detector testing.
9 Maintenance	
Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required. (IFC 1203.4 2021)	Facility is unable to provide documentation for the annual servicing of the emergency generator. Facility is unable to provide documentation for the weekly inspections and Monthly 30 minute full load testing.
10 Securing Compressed Gas Containers, Cylinders and Tanks	
Compressed gas containers, cylinders and tanks shall be secured to prevent falling caused by contact, vibration or seismic activity. Securing of compressed gas containers, cylinders and tanks shall be by one of the following methods: 1. Securing containers, cylinders and tanks to a fixed object with one or more restraints. 2. Securing containers, cylinders and tanks on a cart or other mobile device designed for the movement of compressed gas containers, cylinders or tanks. 3. Nesting of compressed gas containers, cylinders and tanks at container filling or servicing facilities or in sellers' warehouses not open to the public. Nesting shall be allowed provided that the nested containers, cylinders or tanks, if dislodged, do not obstruct the required means of egress. 4. Securing of compressed gas containers, cylinders and tanks to or within a rack, framework, cabinet or similar assembly designed for such use. Exception: Compressed gas containers, cylinders and tanks in the process of examination, filling, transport or servicing. (IFC 5303.5.3 2021)	Oxygen cylinder 2nd floor storage room is not secured to prevent the cylinder from falling.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Olympic Place Retirement & AL Community	***Provider Number***	001712
Address	20909 OLYMPIC PL NE,	***Approval Status***	Disapproved
City, State, Zip	Arlington, WA 98223	***Facility Type***	Residential Care

On 08/18/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
11 Fire Drills	
In all Group I, Group E, and Group R2 Occupancies licensed by the state and inspected by the state fire marshal's office, at least twelve planned and unannounced fire drills shall be held every year. (1) Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. (2) A detailed written record of all fire drills shall be maintained and available for inspection. (3) When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms.	Facility cannot provide documentation for the completion of twelve planned and unannounced fire drills in the previous 12 months. The following Drills are missing. 1st Shift - Quarter 2 2nd Shift - Quarter 3 and 4 3rd Shift - Quarter 1 and 4

Next inspection scheduled on or after: 09/17/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Trevor Quint Maintenance Director
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

Signature

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____