



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Foundation House	Provider Number	001917
Address	32290 1st ,	Approval Status	Approved
City, State, Zip	Federal Way, WA 98003	Facility Type	Residential Care

On 06/28/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 86450

Here's a complaint of power outage

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? N/A
2. If the sprinklers were activated? N/A
3. If there was an evacuation / how many were evacuated? N/A
4. If there were injuries / how many? 0
5. Did the fire department respond? Yes due to stuck elevator

On June 28, 2023 DSFM Christian entered Brookdale Foundation House in regard to a complaint about a power outage.

The facility encountered a power outage due to a vehicle hitting a power pole. I interviewed the Executive Director and she stated the power was only out for about an hour. All fire systems worked properly and the generator kicked in. The facility did have to call the fire department due to visitors stuck in the elevator. The facility conducted safety checks every 15 mins to ensure resident safety.

No deficiencies were cited at this time.

Next inspection scheduled on or after:


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

 Christine Anderson
Print Name and Title Executive Director

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 984455104
(360) 594-5796


Signature