



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Foundation House	Provider Number	001917
Address	32290 1st ,	Approval Status	Approved
City, State, Zip	Federal Way, WA 98003	Facility Type	Residential Care

On 07/24/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 89658

Here's a complaint of sprinkler pipe leak

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? N/A
2. If the sprinklers were activated? No
3. If there was an evacuation / how many were evacuated? N/A
4. If there were injuries / how many? 0
5. Did the fire department respond? No

On July 24, 2023 DSFM Christian entered Brookdale Foundation House in regard to a complaint about a sprinkler pipe leaking.


The maintenance Director stated there was a tiny hole found in the sprinkler piping. The facility called Cintas who came out and sealed the pipe. The facility performed a fire watch while the glue dried and all systems are back in working order.

No deficiencies at this time.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12

Owner or Authorized Representative


Signature

Brian Thompson Director of Maintenance
Print Name and Title

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 98445104
(360) 584-5796


Signature