



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Brookdale Foundation House
Address 32290 1st ,
City, State, Zip Federal Way, WA 98003

Provider Number 001917
Approval Status Approved
Facility Type Residential Care

On 07/18/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 138773

Here's a complaint of dryer fire

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? Unknown
2. If the sprinklers were activated? No
3. If there was an evacuation / how many were evacuated? 0
4. If there were injuries / how many? 0
5. Did the fire department respond? Yes


On July 18, 2024, DSFM Christian entered Brookdale Foundation House in regard to a complaint about a fire in a dryer. The facility stated they were drying sheets and a towel. It is unknown how it caught fire. The maintenance was able to contain the fire to the dryer and put it out. Fire department was called. The dryer is out of commission. I did not see any link build up or any reasoning that would cause a fire during the inspection.

No violations observed.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.


Owner or Authorized Representative


Signature

Brian Thompson
Print Name and Title

D.S.E.

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 984455104
(360) 584-5796


Signature