Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Regency Newcastle	***Provider Number***	2018
Address	7454 Newcastle Golf Club RD ,	***Approval Status***	Approved
City, State, Zip	Newcastle, WA 98059	***Facility Type***	Residential Care

On 06/22/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

1 Admin Complaint

Code Requirement	Statement of Violation
COMPLAINT # 227368 Here's a complaint of FIre alarm Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	COMPLAINT # 227368 On 6/22/2026 a complaint investigation was conducted at Regency Newcastle located at 7454 Newcastle Golf Club Road, Newcastle, WA 98059. An interview was conducted with facility staff. Staff smelled what seemed to be burning paper an Administrator, Administrator instructed facility to set off the fire alarm. Fire department found a fire in the commercial dryer located in the lower floor of building. Facility stated fire department had to break down door going into commercial laundry area. Fire department instructed facility to evacuate 1st floor of building. It was stated that fire might have started from kitchen rags. Facility was instructed to have conversation with kitchen staff on proper washing of grease loaded dish rags and about location of master keys with the rest of the staff. The fire alarm was activated by staff, the fire sprinkler system was not activated, there were no injuries, there was a partial evacuation, and the fire department did respond.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative:_____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Regency Newcastle	***Provider Number***	2018
Address	7454 Newcastle Golf Club RD ,	***Approval Status***	Approved
City, State, Zip	Newcastle, WA 98059	***Facility Type***	Residential Care

On 06/22/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement — Statement of Violation

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

NOT AVAILABLE
Signature

Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

Signature

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative:_____