Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	The Ridge an Encore Community	***Provider Number***	2231
Address	1501 TOWER VIEW CIR NW,	***Approval Status***	Approved
City, State, Zip	Silverdale, WA 98383	***Facility Type***	Residential Care

On 08/26/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin Complaint

COMPLAINT # 236750 Here's a complaint of: Fire in the Cedar kitchenette Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	On 8/26/2026 an complaint investigation was conducted at The Ridge an Encore Community located at 1501 NW Tower View Circle, Silverdale, WA 98383. An interview was conducted with facility staff. Staff member put dry noodles in the microwave and left it unattended causing it to start smoking. The smoke set off the fire alarm system and staff responded with a fire extinguisher. Staff and residents were moved out of the area. There was no sign of a fire but there was smoke, the sprinkler system did not activate. The fire alarm system did activate and the fire department did respond. There were no evacuations out of the building and there were no injuries.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Taylor Burns

Signature

Taylor Burns Executive Director

Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

Signature

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.