



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Canyon Lakes	Provider Number	2263
Address	2802 W 35TH AVE ,	Approval Status	Approved
City, State, Zip	Kennewick, WA 99337	Facility Type	Residential Care

On 04/09/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 173561 Here's a complaint of water outage 1. The cause of the fire? No. 2. If the sprinklers were activated? No. 3. If there was an evacuation / how many were evacuated? Yes. Resident was relocated within the facility. 4. If there were injuries / how many? None. 5. Did the fire department respond? Yes.	On April 9, 2025 I conducted a complaint inspection at Brookdale Canyon Lakes facility in Kennewick, Washington. The complain states that on March 31, 2025 at 1530 hours Resident Apartment 223 presented a water leakage in the kitchen. The leak was discovered to be originated from the domestic water pipe system. Fire Sprinkler System did not show signs of being affected. Apartment 223 and community kitchen's fire prevention systems did not show any signs of being affected. Facility's procedures were followed and no code violations were observed.
--	---

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Ryan Cumpton Maintenance Supervisor
Print Name and Title

Deputy State Fire Marshal Jessica Teobaldino-Mutton
143302 E Law Lane
Kennewick WA 99337
(425) 557-0362


Signature