



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Canyon Lakes	Provider Number	2263
Address	2802 W 35TH AVE ,	Approval Status	Pending
City, State, Zip	Kennewick, WA 99337	Facility Type	Residential Care

On 06/11/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Signature

Joseph Green
Print Name and Title

Deputy State Fire Marshal Barbara Maier
PO BOX 42642
Olympia WA 98504
(360) 596-3925

CDSFM Barbara A Maier

Digitally signed by CDSFM Barbara A Maier
DN: cn=CDSFM Barbara A Maier, o=Washington State
Patrol, ou=Fire Protection Bureau,
email=barbara.maier@wsp.wa.gov, c=US
Date: 2025.06.11 14:36:01 -0700

Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Initials of Authorized Facility Representative: _____



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Canyon Lakes	Provider Number	2263
Address	2802 W 35TH AVE ,	Approval Status	Disapproved
City, State, Zip	Kennewick, WA 99337	Facility Type	Residential Care

On 04/09/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Record Keeping

Records shall be maintained of required emergency evacuation drills and include the following information:

1. Identity of the person conducting the drill.
2. Date and time of the drill.
3. Notification method used.
4. Employees on duty and participating.
5. Number of occupants evacuated.
6. Special conditions simulated.
7. Problems encountered.
8. Weather conditions when occupants were evacuated.
9. Time required to accomplish complete evacuation.

(IFC 0405.6 2021)

The fire drills documentation does not include all the required information.

2 Abatement of Electrical Hazards

Abatement of unsafe conditions and electrical hazards. Conditions that constitute an electrical shock or fire hazard shall be abated..

(IFC 603.2 2021)

Corrected.

3 Extension Cords

Extension cords. Extension cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors..

(IFC 603.6 2021)

Corrected.



**Washington State Patrol
Fire Protection Bureau**

Phone: (360) 596-3900

Business Name	Brookdale Canyon Lakes	Provider Number	2263
Address	2802 W 35TH AVE ,	Approval Status	Disapproved
City, State, Zip	Kennewick, WA 99337	Facility Type	Residential Care

On 04/09/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

4 Repair of penetrations

Repair of penetrations. Where damaged, materials used to protect membrane- and through-penetrations shall be replaced or restored with materials or systems that meet or exceed the code requirements applicable at the time when the assembly was constructed, remodeled or altered.

Corrected.

5 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified.

(IFC 705.2 2021)

Corrected.

6 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

1. Facility is unable to provide documentation for the annual forward flow test in accordance with NFPA 25.

2. Corrected.

3. Corrected.

4. Corrected.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Canyon Lakes	Provider Number	2263
Address	2802 W 35TH AVE ,	Approval Status	Disapproved
City, State, Zip	Kennewick, WA 99337	Facility Type	Residential Care

On 04/09/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

7 Portable Fire Extinguishers - General Requirements

Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Exceptions:

1. The distance of travel to reach an extinguisher shall not apply. The travel distance to reach an extinguisher shall not apply to the spectator seating portions of Group A-5 occupancies.
2. Thirty-day inspections shall not be required and maintenance shall be allowed to be once every three years for dry-chemical or halogenated agent portable fire extinguishers that are supervised by a listed and approved electronic monitoring device, provided that all of the following conditions are met:
 - 2.1. Electronic monitoring shall confirm that extinguishers are properly positioned, properly charged and unobstructed.
 - 2.2. Loss of power or circuit continuity to the electronic monitoring device shall initiate a trouble signal.
 - 2.3. The extinguishers shall be installed inside of a building or cabinet in a noncorrosive environment.
 - 2.4. Electronic monitoring devices and supervisory circuits shall be tested every 3 years when extinguisher maintenance is performed.
 - 2.5. A written log of required hydrostatic test dates for extinguishers shall be maintained by the owner to verify that hydrostatic tests are conducted at the frequency required by NFPA 10.
3. In Group I-3, portable fire extinguishers shall be permitted to be located at staff locations.

(IFC 906.2 2021)

Corrected.

8 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

Corrected.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Canyon Lakes	Provider Number	2263
Address	2802 W 35TH AVE ,	Approval Status	Disapproved
City, State, Zip	Kennewick, WA 99337	Facility Type	Residential Care

On 04/09/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

9 Internally Illuminated Exit Signs

Electrically powered, self-luminous and photoluminescent exit signs shall be listed and labeled in accordance with UL 924 and shall be installed in accordance with the manufacturer's instructions and Section 1203. Exit signs shall be illuminated at all times. (IFC 1013.5 2021)	The internally illuminated exit signs near 241 was not illuminated on normal power.
--	---

10 Installation

Emergency power systems and standby power systems shall be installed in accordance with the International Building Code, NFPA 70, NFPA 110 and NFPA 111. (IFC 1203.1.3 2018)	The level 1 backup generator has a natural gas fuel source but does not have a secondary fuel source as required by NFPA 110.
---	---

Next inspection scheduled on or after: 05/09/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Ryan Cumpton Maintenance Supervisor
Print Name and Title

Deputy State Fire Marshal Jessica Teobaldino-Mutton
143302 E Law Lane
Kennewick WA 99337
(425) 557-0862


Signature



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Brookdale Canyon Lakes	Provider Number 2263
Address 2802 W 35TH AVE ,	Approval Status Disapproved
City, State, Zip Kennewick, WA 99337	Facility Type Residential Care

On 10/28/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Record Keeping

Records shall be maintained of required emergency evacuation drills and include the following information:

1. Identity of the person conducting the drill.
2. Date and time of the drill.
3. Notification method used.
4. Employees on duty and participating.
5. Number of occupants evacuated.
6. Special conditions simulated.
7. Problems encountered.
8. Weather conditions when occupants were evacuated.
9. Time required to accomplish complete evacuation.

(IFC 0405.6 2021)

The fire drills documentation does not include all the required information.

2 Abatement of Electrical Hazards

Abatement of unsafe conditions and electrical hazards. Conditions that constitute an electrical shock or fire hazard shall be abated..

(IFC 603.2 2021)

The power panel in the kitchen was missing breaker #25 and did not having a protective covering installed.

3 Extension Cords

Extension cords. Extension cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors..

(IFC 603.6 2021)

There were 2 extension cords plugged into each other in the housekeeping laundry



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Brookdale Canyon Lakes	Provider Number 2263
Address 2802 W 35TH AVE ,	Approval Status Disapproved
City, State, Zip Kennewick, WA 99337	Facility Type Residential Care

On 10/28/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

4 Repair of penetrations

Repair of penetrations. Where damaged, materials used to protect membrane- and through-penetrations shall be replaced or restored with materials or systems that meet or exceed the code requirements applicable at the time when the assembly was constructed, remodeled or altered.

There were two 8 inch holes in the fire barrier in the basement crawlspace that has not been repaired.

5 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified.

(IFC 705.2 2021)

The fire rated door to the 2nd floor elevator #3 has a broken door closure preventing the door from closing upon the activation of the fire alarm.

6 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

1. Facility is unable to provide documentation for the annual forward flow test in accordance with NFPA 25.

2. There was a missing escutcheon plate from the sprinkler located near room 131.

3. Mixed standard response and quick response sprinkler heads were found in the dining room near the private dining room.

4. The walk-in type cooler with automatic defrost has ordinary temperature heads installed.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

This document was prepared by Residential Care Services for the Locator website.

Business Name Brookdale Canyon Lakes	Provider Number 2263
Address 2802 W 35TH AVE ,	Approval Status Disapproved
City, State, Zip Kennewick, WA 99337	Facility Type Residential Care

On 10/28/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

7 Portable Fire Extinguishers - General Requirements

Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Exceptions:

1. The distance of travel to reach an extinguisher shall not apply. The travel distance to reach an extinguisher shall not apply to the spectator seating portions of Group A-5 occupancies.

2. Thirty-day inspections shall not be required and maintenance shall be allowed to be once every three years for dry-chemical or halogenated agent portable fire extinguishers that are supervised by a listed and approved electronic monitoring device, provided that all of the following conditions are met:

2.1. Electronic monitoring shall confirm that extinguishers are properly positioned, properly charged and unobstructed.

2.2. Loss of power or circuit continuity to the electronic monitoring device shall initiate a trouble signal.

2.3. The extinguishers shall be installed inside of a building or cabinet in a noncorrosive environment.

2.4. Electronic monitoring devices and supervisory circuits shall be tested every 3 years when extinguisher maintenance is performed.

2.5. A written log of required hydrostatic test dates for extinguishers shall be maintained by the owner to verify that hydrostatic tests are conducted at the frequency required by NFPA 10.

3. In Group I-3, portable fire extinguishers shall be permitted to be located at staff locations.

(IFC 906.2 2021)

1. The required annual maintenance for the fire extinguisher in the water heat has not been completed in accordance with NFPA 10.

2. The required annual maintenance for the fire extinguisher near the staff lounge needs to be replaced.

3. The required annual maintenance for the fire extinguisher near room 15 needs to be replaced.

8 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

The power breaker #14 in for the fire alarm system is missing locking device.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Brookdale Canyon Lakes	Provider Number 2263
Address 2802 W 35TH AVE ,	Approval Status Disapproved
City, State, Zip Kennewick, WA 99337	Facility Type Residential Care

On 10/28/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

9 Internally Illuminated Exit Signs

Electrically powered, self-luminous and photoluminescent exit signs shall be listed and labeled in accordance with UL 924 and shall be installed in accordance with the manufacturer's instructions and Section 1203. Exit signs shall be illuminated at all times.

(IFC 1013.5 2021)

The internally illuminated exit sign near 241 was not illuminated on normal power.

10 Installation

Emergency power systems and standby power systems shall be installed in accordance with the International Building Code, NFPA 70, NFPA 110 and NFPA 111.


(IFC 1203.1.3 2018)

The level 1 backup generator has a natural gas fuel source but does not have a secondary fuel source as required by NFPA 110.

Next inspection scheduled on or after: 11/27/2024

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Joseph Green Executive Director
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

Brandon G. Brown Digitally signed by Brandon G. Brown
Date: 2024.10.28 22:28:28 -07'00'

Signature