



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Olympia East	Provider Number	2275
Address	616 Lilly Road RD NE,	Approval Status	Approved
City, State, Zip	Olympia, WA 98506	Facility Type	Residential Care

On 04/29/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 127407 Here's a complaint of sprinkler malfunction Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	COMPLAINT # 127407 On April 29th, 2024 a complaint investigation was conducted at Brookdale Olympia East located at 616 Lilly Road NE, Olympia WA. Interviews were conducted with the maintenance staff, and the Director. Sprinkler head was activated for unknown reasons on the 3rd floor with no fire present. Facility conducted fire watch until system was back in normal status. There was not fire, one sprinkler was activated, there was no evacuation, there were no injuries, and the fire department did respond.
---	---

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Not Available
Signature

Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

[Signature]
Signature