



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Arbor Place	Provider Number	2278
Address	12806 Bothell-Everett HWY ,	Approval Status	Approved
City, State, Zip	Everett, WA	Facility Type	Residential Care

On 12/09/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 204436 Here's a complaint of Water Leak Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	Complaint ref # 204436 At 1400 on 12/09/2025, DSFM Brown conducted complaint inspection for Brookdale Arbor Place located at 12806 Bothell Everett Hwy, Everett, WA 98208 to investigate complaint ref # 204436. I interviewed the Facility Executive Director. On 12/04/2025, at approximately 1850, contract painters were finishing in room 220, while removing equipment one sprinkler head in room 220 was damaged and activated. Local fire department did respond, no injuries were report during this incident. Water damaged was discovered in room 220, 114, 115, and 116. The sprinkler vender was on site and the sprinkler system was restored by 2130. Two residents were moved to other room within the facility while the damage is being repaired. No injuries were report. No violations observed.
---	--

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

Brandon Brown

Digitally signed by Brandon Brown
Date: 2025.12.09 16:04:00 -08'00'

Signature



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Arbor Place	Provider Number	2278
Address	12806 Bothell-Everett HWY ,	Approval Status	Approved
City, State, Zip	Everett, WA	Facility Type	Residential Care

On 12/09/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

This document was prepared by Residential Care Services for the Locator website.