Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Coventry House	***Provider Number***	2334
Address	430 2ND AVE ,	***Approval Status***	Disapproved
City, State, Zip	Othello, WA 99344	***Facility Type***	Residential Care

On 06/29/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Relocatable power taps and current taps

Relocatable power taps and current taps. The construction and use of current taps and relocatable power taps shall be in accordance with NFPA 70 and this code. (IFC 603.5, 2021)	Corrected

2 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2021)	The following violation was observed: -The semi annual fire alarm report had deficiencies. All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

3 Seperation From Hazardous Conditions

Compressed gas containers, cylinders and tanks and systems in storage or use shall be separated from materials and conditions that pose exposure hazards to or from each other. Compressed gas containers, cylinders, tanks and systems in storage or use shall be separated in accordance with Sections 5303.7.1 through 5303.7.11.2. (IFC 5303.7 2021)	Corrected

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Coventry House	***Provider Number***	2334
Address	430 2ND AVE ,	***Approval Status***	Disapproved
City, State, Zip	Othello, WA 99344	***Facility Type***	Residential Care

On 06/29/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

Next inspection scheduled on or after: 07/29/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Genesis Casados Billing Office Manager

Print Name and Title

Deputy State Fire Marshal Alan Harlan
2803 156TH AVE SE
Bellevue WA 98007
(425) 495-7121

Signature

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____