



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Mountlake Terrace Plaza	Provider Number	2373
Address	23303 58th AVE ,	Approval Status	Approved
City, State, Zip	Mountlake Terrace, WA 98043	Facility Type	Residential Care

On 12/5/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 108248 Here's a complaint of fire alarm system down temporarily during generator installation. Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	On 12/5/2023 DSFM Jason Van Gorkum entered Mountlake Terrace Plaza located at 23303 58th Ave W, Mountlake Terrace, WA 98043, Investigate complaint ref # 108248 On the 29th of November 2023, at approximately 10:00 AM Staff put the fire alarm into test, then disconnected power to the fire alarm to replace and setup new generator to the building. Durring this time the fire Alarm was using battery back up to stay active. Staff also performed Fire watch during this time. The power was restored at 3:30pm and system was restored back to regular power. The fire alarm did not activate No injuries where reports. Sprinklers where not activated No evacuation was performed Local fire department had been contacted by facility with fire department not needing to come to the facility. No IFC violations observed
--	--

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Mountlake Terrace Plaza	Provider Number	2373
Address	23303 58th AVE ,	Approval Status	Approved
City, State, Zip	Mountlake Terrace, WA 98043	Facility Type	Residential Care

On 12/5/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum
2803 156 AVE SE
Bellevue WA 98007
(509) 406-7209

Jason E Van Gorkum
Signature

This document was prepared by Residential Care Services for the Locator website.