Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Valley Residential Care Inc.	***Provider Number***	2379
Address	14106 E 3RD AVE ,	***Approval Status***	Approved
City, State, Zip	Spokane Valley, WA 99216	***Facility Type***	Residential Care

On 06/12/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin - (ITM) Inspection, Testing, & Maintenance

Any citation that requires inspection, testing, or maintenance (ITM) is required to have the testing completed, paper results delivered, and any deficiencies found during the ITM corrected before the citation is cleared."	For your information.

2 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	For your information: The following are due in 2026, last completed into 10/07/21 5 Year Internal Pipe Testing 5 Year Fire Department Connection Hydrand Testing

Next inspection scheduled on or after: 08/31/2027

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Levi Loetscher Director Maintenance
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746

Barbara McMullen
Signature

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.