Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Villager LLC, The	***Provider Number***	2380
Address	420 1st ,	***Approval Status***	Disapproved
City, State, Zip	Castle Rock, WA 98611	***Facility Type***	Residential Care

On 07/17/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
1 Inspection and Maintenance	
Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified. (IFC 705.2 2021)	Facility failed to repair fire doors found with excessive gaps
2 Testing and Maintenance	
Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Corrected

Next inspection scheduled on or after: 08/16/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Mindy J Kleine
Signature

Mindy J Kleine RN, Owner
Print Name and Title

Deputy State Fire Marshal Nicholas Wolden
1823 BAKER WAY
Kelso WA 98626
(360) 852-0966

Nicholas D. Wolden
Signature

Initials of Authorized Facility Representative:_____

This document was prepared by Residential Care Services for the Locator website.

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Villager LLC, The	***Provider Number***	2380
Address	420 1st ,	***Approval Status***	Disapproved
City, State, Zip	Castle Rock, WA 98611	***Facility Type***	Residential Care

On 05/28/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

1 Inspection and Maintenance

Code Requirement	Statement of Violation
Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified. (IFC 705.2 2021)	Fire doors found to have excessive gap at bottom of door

2 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Facility failed to provide annual forward flow test of backflow

Next inspection scheduled on or after: 06/27/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Mindy J Kleine
Signature

Mindy J Kleine RN, Owner
Print Name and Title

Deputy State Fire Marshal Nicholas Wolden
1823 BAKER WAY
Kelso WA 98626
(360) 852-0966

Nicholas D. Wolden
Signature

Initials of Authorized Facility Representative:_____

This document was prepared by Residential Care Services for the Locator website.