Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Port Townsend Senior Living	***Provider Number***	2408
Address	1201 HANCOCK ST ,	***Approval Status***	Approved
City, State, Zip	Port Townsend, WA 98368	***Facility Type***	Residential Care

On 06/23/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin Complaint

COMPLAINT # 227820 Here's a complaint of Propane Containers Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	COMPLAINT # 227820 On 6/23/26 a complaint investigation was conducted at Avamere at Port Townsed, previously Port Townsend Senior Living located at 1202 Hancock Street, Port Townsend, WA 98368. An interview was conducted with facility staff. Compressed gas container were found chained to wall upon inspection and coversation was had with facility staff about securing all containers. There was no fire, the fire alarm and fire sprinkler system were not activated, there were no injuries, there was no evacuation and the fire department did not respond.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Peder Berg
Signature

Peder Berg Executive Director
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

Signature

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.