Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Avamere at Wenatchee	***Provider Number***	2415
Address	1550 CHERRY ST ,	***Approval Status***	Approved
City, State, Zip	Wenatchee, WA 98801	***Facility Type***	Residential Care

On 09/30/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin Complaint

COMPLAINT # 239965 Here's a complaint of Compressor Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	On September 30, 2026 an inspection was completed at Avamere at Wenatchee Senior Living located at 1550 Cherry Street in Wenatchee, Washington for complaint #239965 regarding and air compressor leak to the fire suppression system. On September 9, 2026 the fire suppression system technicians on site accidentally tripped dry system #3 and #4, allowing water into the sprinkler piping. The system did not activate to any areas of the building, but required to be fully drained and reset by certified contractors on site. The facility began fire watch on September 9, 2026 and was in active fire watch upon the site inspection conducted on September 30, 2026, even though the system was fully repaired on September 10, 2026. The facility was released from fire watch duties immediately, and no staff or residents were evacuated, relocated, or injured within this incident. The fire department did not respond, and the fire alarm annunciator stated all systems normal upon site inspection.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Maggie
Signature

Maggie Mikesell, Executive Director
Print Name and Title

Deputy State Fire Marshal Andrea Ely
2715 RUDKIN RD
Union Gap WA
(509) 531-3384

Andrea Ely
Digitally signed by Andrea Ely
Date: 2026.09.30 14:02:38 -07'00'
Adobe Acrobat Reader version: 2026.002.21931
Signature

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Avamere at Wenatchee	***Provider Number***	2415
Address	1550 CHERRY ST ,	***Approval Status***	Approved
City, State, Zip	Wenatchee, WA 98801	***Facility Type***	Residential Care

On 09/30/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____