Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Avamere at Wenatchee	***Provider Number***	2415
Address	1550 CHERRY ST ,	***Approval Status***	Approved
City, State, Zip	Wenatchee, WA 98801	***Facility Type***	Residential Care

On 08/06/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin Complaint

COMPLAINT # 233307 Here's a complaint of Fire Panel Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	On August 6, 2026 an inspection was completed for complaint #233307 at Avamere at Wenatchee (Wenatchee Senior Living) at 1550 Cherry Street in Wenatchee, Washington. This inspection is in response to complaint for a fire alarm panel trouble signal. The fire alarm system for the facility was noted in trouble status on July 22, 2026, and the facility was informed at their annual inspection that notification to the licensing agency, the WSFMO, and local Fire Department was required when a system is out of service. A fire watch was issued at that time, and documentation of the fire watch logs and associated fire alarm service reports of repairs was required to be submitted to our office for review. The system was noted as back in service on July 30, 2026 and documentation was approved upon review. Per staff interviews, there was no fire, no fire and life safety systems activated, and no occupants were injured, relocated, or evacuated. The fire department did not respond, and the panel was in normal status upon site inspection; no violations were observed.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Avamere at Wenatchee	***Provider Number***	2415
Address	1550 CHERRY ST ,	***Approval Status***	Approved
City, State, Zip	Wenatchee, WA 98801	***Facility Type***	Residential Care

On 08/06/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner ~~or Authorized~~ Representative

Maggie Milesell

Signature

Maggie Milesell, Executive Director

Print Name and Title

Deputy State Fire Marshal Andrea Ely
2715 RUDKIN RD
Union Gap WA
(509) 531-3384

Andrea Ely

Signature

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____