Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	The Gardens at Marysville, Independent Living & AL	***Provider Number***	2476
Address	9802 48th ,	***Approval Status***	Approved
City, State, Zip	Marysville, WA 98270	***Facility Type***	Residential Care

On 09/03/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Signature

Dustin Watzsteon M D
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

Signature

This document was prepared by Residential Care Services for the Locator website.

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	The Gardens at Marysville, Independent Living & AL	***Provider Number***	2476
Address	9802 48th ,	***Approval Status***	Disapproved
City, State, Zip	Marysville, WA 98270	***Facility Type***	Residential Care

On 07/30/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Extension Cords

Extension cords. Extension cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.. (IFC 603.6 2021)	1. There was an extension cord utilized as permanent wiring in 319 2. There was an extension cord utilized as permanent wiring in 207

2 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified. (IFC 705.2 2021)	The following resident room fire door that opens to the corridor was blocked open using various items, preventing it from closing and latching: a. 115 (repeat from 2025 and 2024) b. 121 (repeat from 2024) c. 319 (repeat from 2025) d. 317 e. 301 (repeat from 2025) f. Laundry room door near 112 g. double doors to the dining room blocked by a sign and trash can

3 Door Operation

Swinging fire doors shall close from the full-open position and latch automatically. (IFC 705.2.4 2021)	1. The fire rated cross corridor door near room 208 would not close and latch from the fully open position. 2. Resident room 215 fire door would not close and latch from the fully open position. 3. The fire rated cross corridor door near room 115 would not close and latch from the fully open position.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	The Gardens at Marysville, Independent Living & AL	***Provider Number***	2476
Address	9802 48th ,	***Approval Status***	Disapproved
City, State, Zip	Marysville, WA 98270	***Facility Type***	Residential Care

On 07/30/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
4 Testing and Maintenance	
Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Facility is unable to provide documentation for the annual forward flow test in accordance with NFPA 25.

Next inspection scheduled on or after: 08/29/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Falon Messer Executive Directo

Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

Signature

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____