



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Cordata Court, Assisted Living & Memory Care **Provider Number** 2481
Address 4415 COLUMBINE RD , **Approval Status** Approved
City, State, Zip Bellingham, WA **Facility Type** Residential Care
On 10/06/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 196517

Here's a complaint of

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

Complaint ref # 196517

At 0830 on the 10/06/2025, DSFM Brown entered Cordata Court Assisted Living and Memory Care located at 4415 Columbine Dr, Bellingham, WA 98226 to investigate complaint ref# 196517. Reporter states that on the evening of 9/28/2025 while the lead server was closing in the kitchen, there was a small grease fire on the flat top. She was not able to extinguish it with baking soda. She engaged the fire alarm, the fire department did respond and was able to extinguish the small fire. Gas was turned off at stove. There was no impact to resident service. Facility is equipment with a non UL 300 water system that did not activate.


No injuries were reported.

No violations observed.

Next inspection scheduled on or after:


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

MAX ZOVET MAINT S/H/MT
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037


Signature

