



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cordata Court, Assisted Living & Memory Care	Provider Number	2481
Address	4415 COLUMBINE RD ,	Approval Status	Approved
City, State, Zip	Bellingham, WA 98226	Facility Type	Residential Care

On 02/20/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 166746

Here's a complaint of monthly smoke alarm and CO testing

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

Complaint ref # 166746

At 0845 on the 02/20/2025, DSFM Brown entered Cordata Court Assisted Living and Memory Care located at 4415 Columbine Dr, Bellingham, WA 98226 to investigate complaint ref# 166746. Reporter state that their family member resides in the independent living cottages and that the facility is not maintaining the smoke and carbon monoxide alarms. They also claim that the facility buys the cheapest units and batteries.

The independent living is not licensed by DSHS and is not inspected by the State Fire Marshal's Office. The assisted living section is inspected annual and the testing of the smoke and carbon monoxide alarms are review annual for compliance with Washington State adopted fire codes and NFPA standards. I have reviewed the records today to verify that the facility has been conducting testing on installed smoke and carbon monoxide alarms. There is no code requirement of the price of a unit. The units must be UL listed for the purpose that it's being used for. The installed unit observed in the assisted living are UL listed. There are also no requirements for the price or quality of the batteries that are installed.

No violations observed.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cordata Court, Assisted Living & Memory Care	Provider Number	2481
Address	4415 COLUMBINE RD ,	Approval Status	Approved
City, State, Zip	Bellingham, WA 98226	Facility Type	Residential Care

On 02/20/2025 the Office of the State Fire Marshal conducted an inspection at your facility.


Code Requirement

Statement of Violation

Next inspection scheduled on or after:


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Isaac Simurdo - MD
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037


Signature

This document was prepared by Residential Care Services for the Locator website.