



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	The Rivers at Puyallup, Independent Living & AL (B)	Provider Number	2483
Address	123 4TH AVE NW,	Approval Status	Approved
City, State, Zip	Puyallup, WA 98371	Facility Type	Residential Care

On 04/08/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Danial Syed
Signature

Danial Syed Head
Print Name and Title

Deputy State Fire Marshal Lysandra Davis
2502 112 ST
Tacoma WA 984455104
(360) 890-1622

[Signature]
Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	The Rivers at Puyallup, Independent Living & AL	Provider Number	2483
Address	123 4TH AVE NW,	Approval Status	Disapproved
City, State, Zip	Puyallup, WA 98371	Facility Type	Residential Care

On 03/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 168084 Here's a complaint of grease fire Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	On March 3rd, 2025, an investigation for complaint ID #168084 was performed at The Rivers at Puyallup. The complaint was in regards to a kitchen grease fire. Based on observations, the facility failed to maintain cooking equipment in accordance with NFPA 96, 11.7. Both the range and griddle had excessive grease accumulation and scorch marks on, within, and below the cooking surfaces. Staff stated that the griddle was no longer in use, and that the floors had been recently cleaned to remove drops of grease. All violations must be corrected upon the next re-inspection.
--	---

2 Grease Accumulation

If during the inspection it is found that hoods, grease-removal devices, fans, ducts or other appurtenances have an accumulation of grease, such components shall be cleaned in accordance with ANSI/KECA C10. (IFC 606.3.3.2 2021)	Findings during the inspection were: 1) Excessive grease build-up and scorch marks observed on, within, and below the cooking surfaces of the range, griddle and backsplashes. 2) Unable to produce documentation showing that cooking equipment has received annual professional cleaning in accordance with ANSI/KECA C10-2021.
--	---

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	The Rivers at Puyallup, Independent Living & AL	Provider Number	2483
Address	123 14TH AVE NW,	Approval Status	Disapproved
City, State, Zip	Puyallup, WA 98371	Facility Type	Residential Care

On 03/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on **or after:** 04/02/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Danial Syed
Signature

Danial Syed Executive Director
Print Name and Title

Deputy State Fire Marshal Lysandra Davis
2502 112 ST
Tacoma WA 984455104
(360) 890-1622

L Davis
Signature