Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Walla Walla	***Provider Number***	2498
Address	1460 DALLES MILITARY RD ,	***Approval Status***	Approved
City, State, Zip	Walla Walla, WA 99362	***Facility Type***	Residential Care

On 06/17/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin Complaint

COMPLAINT # 227640 Here's a complaint of Fire Panel Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? N/A 2. If the sprinklers were activated? N/A 3. If there was an evacuation / how many were evacuated? N/A 4. If there were injuries / how many? N/A 5. Did the fire department respond? No	Complaint ref # 227640 At 1100 on 06/17/2026, DSFM Harlan entered Brookdale Walla Walla located at 1460 Dalles Military Rd, Walla Walla, WA 99362 to investigate complaint ref # 227640. I interviewed the Facility Maintenance Director. On 06/07/2026 approximately 1730,Business Office Manager Business Office Manager Ann Ingersol was completing a community orientation walkthrough with a new associate and noticed the fire panel was not working. Called Maintenance Director,Frank, who called JCI to have them come look at the panel as a new condenser was just installed and possibly messed with the lines. Fire watch was immediately implemented. JCI was able to fix the fire panel issue, fire panel went back online at 11:55pm and fire watch was stopped. Upon interview with the Maintenance Director the issue stemmed from the air compressor on the dry side of sprinkler system dropped below sprinkler system design which caused fire alarm to go into trouble. The facility hired a electrician to replace air compressor and system is holding air. The fire alarm did not activate and the fire department did not respond. No IFC violations observed.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Walla Walla	***Provider Number***	2498
Address	1460 DALLES MILITARY RD ,	***Approval Status***	Approved
City, State, Zip	Walla Walla, WA 99362	***Facility Type***	Residential Care

On 06/17/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

_____ _____
Signature Print Name and Title

Deputy State Fire Marshal Alan Harlan
2803 156TH AVE SE
Bellevue WA 98007
(425) 495-7121

Alan Harlan Digitally signed by Alan Harlan
Date: 2026.06.17 14:45:43 -07'00'
_____
Signature

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____