Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone on Clear Creek	***Provider Number***	2606
Address	11353 NW Clear Creek RD NW,	***Approval Status***	Approved
City, State, Zip	Silverdale, WA 98383	***Facility Type***	Residential Care

On 06/03/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
1 Admin Complaint	
COMPLAINT # 222025 Here's a complaint of Fire Hazard Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	COMPLAINT # 222025 On 6/3/2026 a complaint investigation was conducted at Fieldstone on Clear Creek located at 11353 Clear Creek Road NW, Silverdale, WA 98383. An interview was conducted with facility staff. Portable fire extinguishers were being inspected by facility. Various resident bathroom fans were inspected to include room 115 and 123 with no lint overload. Resident laundry vents were inspected on all floors with no excessive load of lint. Industrial dryer was also inspected and no excessive lint was found. Discussion was had with maintenance director on importance of keeping all dryers and bathroom fans free of debris. Facility was aware of leaks in resident rooms which had nothing to do with the fire sprinkler system, and were being addressed There were no sings of a fire, the sprinkler system was not activated, there were no evacuations, there were no injuries and the fire department did not respond.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fieldstone on Clear Creek	***Provider Number***	2606
Address	11353 NW Clear Creek RD NW,	***Approval Status***	Approved
City, State, Zip	Silverdale, WA 98383	***Facility Type***	Residential Care

On 06/03/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement | Statement of Violation

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Stephanie Perry
Signature

Stephanie Perry, Campus Executive Director
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

Signature

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____