Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Village at the Harbor	***Provider Number***	2608
Address	543 SPRING ST ,	***Approval Status***	Approved
City, State, Zip	Friday Harbor, WA 982508057	***Facility Type***	Residential Care

On 06/09/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Tina Levasheff — *Signature*

Tina Levasheff — *Print Name and Title*

Executive Director

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

Brandon Brown Digitally signed by Brandon Brown
Date: 2026.06.09 16:48:54 -07'00'

Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Village at the Harbor	***Provider Number***	2608
Address	543 SPRING ST ,	***Approval Status***	Disapproved
City, State, Zip	Friday Harbor, WA	***Facility Type***	Residential Care

On 03/09/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
1 Appliance Connection to Building Piping	
Gas-fired commercial cooking appliances installed on casters and appliances that are moved for cleaning and sanitation purposes shall be connected to the piping system with an appliance connector listed as complying with ANSI Z21.69/CSA 6.16. The commercial cooking appliance connector installation shall be configured in accordance with the manufacturer's installation instructions. Movement of appliances with casters shall be limited by a restraining device installed in accordance with the connector and appliance manufacturer's instructions. (IFC 606.4 2021)	The gas appliances on casters in the kitchen are not limited by a restraining device.
2 Testing and Maintenance	
Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Facility is unable to provide documentation for the 5 year internal piping inspection.
3 Inspection and Maintenance	
Fire department connections shall be periodically inspected, tested and maintained in accordance with NFPA 25. Records of inspection, testing and maintenance shall be maintained. (IFC 912.7 2021)	Facility was unable to provide documentation that the Fire Department Connection has been hydrostatically tested in accordance with NFPA 25.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Village at the Harbor	***Provider Number***	2608
Address	543 SPRING ST ,	***Approval Status***	Disapproved
City, State, Zip	Friday Harbor, WA	***Facility Type***	Residential Care

On 03/09/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

Next inspection scheduled on or after: 04/08/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Josh Blain 3-10-2026

Signature *Print Name and Title*

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

Brandon Brown Digitally signed by Brandon Brown
Date: 2026.03.09 12:09:08 -07'00'

Signature

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____