



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Renton Assisted Living	Provider Number	2614
Address	71 VICTORIA ,	Approval Status	Approved
City, State, Zip	Renton, WA 98055	Facility Type	Residential Care

On 07/18/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 138642

Here's a complaint of stove fire

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

On July 18, 2024, DSFM Christian entered Renton Assisted Living in regard to a complaint about a stove fire. The facility stated on July 15 a fire started in the kitchen from the grease trap. The facility stated the staff grabbed the wrong extinguisher to put the fire out. They have since done an in service on steps to take to put out a fire. Upon inspection everything is cleaned there is not grease in the grease trap and facility stated they will be cleaning the grease trap nightly. They stated they had a turn over in staff and the trap had gone uncleaned.

No violations at this time.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Virginia Kunde
Signature

Virginia M Kunde Executive
Print Name and Title

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 984455104
(360) 584-5796

Cozetta Christian
Signature

Initials of Authorized Facility Representative: _____