




Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Renton Assisted Living	Provider Number	2614
Address	71 VICTORIA ,	Approval Status	Approved
City, State, Zip	Renton, WA 98055	Facility Type	Residential Care

On 12/23/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

MARK MYLER, PALOMER
Print Name and Title

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 98445104
(360) 584-5796


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Renton Assisted Living	Provider Number	2614
Address	71 VICTORIA ,	Approval Status	Disapproved
City, State, Zip	Renton, WA 98055	Facility Type	Residential Care

On 12/02/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT #156554 and 156628 Here's a complaint of a power outage Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? N/A 2. If the sprinklers were activated? No 3. If there was an evacuation / how many were evacuated? 0 4. If there were injuries / how many? 0 5. Did the fire department respond? No	On December 2, 2024 CDSFM entered Renton Assisted Living due to complaint # 156628 and complaint # 156554 in regards to a wide spread power outage. The facility had a small generator running to help with lighting in the hall ways and medical receptacles for people with oxygen. They also offered blankets, flash lights, heaters, extra socks, hand warmers. Fire alarm went into trouble status when the power was lost. It is unknown if the fire panel can call out at this time. The facility is unsure if the sprinkler was working or not.
--	--

2 Systems Out of Service

Where a required fire protection system is out of service, the fire department and the fire code official shall be notified immediately and, where required by the fire code official, the building shall either be evacuated or an approved fire watch shall be provided for all occupants left unprotected by the shut down until the fire protection system has been returned to service. Where utilized, fire watches shall be provided with at least one approved means for notification of the fire department and their only duty shall be to perform constant patrols of the protected premises and keep watch for fires. Exception: Facilities with an approved notification and impairment management program. The notification and impairment program for water-based fire protection systems shall comply with NFPA 25. (IFC 901.7 2021)	The following violation was observed at the time of inspection: The facility did not conduct a fire watch while their sprinkler system was down.
--	--

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Renton Assisted Living	Provider Number	2614
Address	71 VICTORIA ,	Approval Status	Disapproved
City, State, Zip	Renton, WA 98055	Facility Type	Residential Care

On 12/02/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

3 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

The following violation was observed at the time of inspection:

The fire alarm is in trouble status. It is unknown if it calls out.
The facility is being put on fire watch.

Next inspection scheduled on or after: 01/01/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 984455104
(360) 584-5796


Signature

This document was prepared by Residential Care Services for the Locator website.