Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cogir of Bothell	***Provider Number***	2623
Address	10605 NE 185TH ST ,	***Approval Status***	Approved
City, State, Zip	Bothell, WA 98011	***Facility Type***	Residential Care

On 08/25/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

_____ _____
Signature *Print Name and Title*

Deputy State Fire Marshal Kimberly Bloor
PO Box 42600
Olympia WA 985042600
(360) 596-3922

Kimberly Bloor
_____
Signature

Digitally signed by Kimberly Bloor
Date: 2026.08.26 09:52:40 -07'00'

This document was prepared by Residential Care Services for the Locator website.

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cogir of Bothell	***Provider Number***	2623
Address	10605 NE 185TH ST ,	***Approval Status***	Disapproved
City, State, Zip	Bothell, WA 98011	***Facility Type***	Residential Care

On 07/08/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Administration

This report is for the annual inspection for fire and life safety at Cogir of Bothell.	Re-inspection conducted at Cogir of Bothell.

2 Means of Egress - Storage in Buildings

Combustible materials shall not be stored in exits or enclosures for stairways and ramps. Combustible materials in the means of egress during construction, demolition, remodeling or alterations shall comply with Section 3311.3. (IFC 315.3.2 2021)	Corrected

3 Group R-2 assisted living and residential care facilites

3.9.2.4 Group R-2 assisted living and residential care facilities. Assisted living and residential care facilities licensed by the state of Washington shall comply with Section 403.7.1 as required for Group I-1 Condition 2 occupancies. (IFC 403.9.2.4 2021 WAC 51-54A)	The facility could not produce a fire safety plan.

4 General - Electrical

603.1 General. Electrical equipment, wiring and systems required by this code or the International Building Code shall be installed, used and maintained in accordance with NFPA 70 and Sections 603.2 through 603.10. (IFC 603.1 2021)	Corrected

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Business Name	Cogir of Bothell	***Provider Number***	2623
Address	10605 NE 185TH ST ,	***Approval Status***	Disapproved
City, State, Zip	Bothell, WA 98011	***Facility Type***	Residential Care

On 07/08/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

5 Working Space and Clearance

Working space and clearances. Working space around electrical equipment shall be provided in accordance with Section 110.26 of NFPA 70 for electrical equipment rated 1,000 volts or less, and Section 110.32 of NFPA 70 for electrical equipment rated over 1,000 volts. The minimum required working space shall be not less than 30 inches (762 mm) in width, 36 inches (914 mm) in depth and 78 inches (1981 mm) in height in front of electrical service equipment. Where the electrical service equipment is wider than 30 inches (762 mm), the minimum working space shall be not less than the width of the equipment. Storage of materials shall not be located within the designated working space. (IFC 603.4, 2021)	The following area had items within 36 inches of the electrical panels. Electrical room by staff lounge.

6 Relocatable power taps and current taps

Relocatable power taps and current taps. The construction and use of current taps and relocatable power taps shall be in accordance with NFPA 70 and this code. (IFC 603.5, 2021)	Corrected

7 Extension Cords

Extension cords. Extension cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.. (IFC 603.6 2021)	Corrected

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Business Name	Cogir of Bothell	***Provider Number***	2623
Address	10605 NE 185TH ST ,	***Approval Status***	Disapproved
City, State, Zip	Bothell, WA 98011	***Facility Type***	Residential Care

On 07/08/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

8 Appliance Connection to Building Piping

Gas-fired commercial cooking appliances installed on casters and appliances that are moved for cleaning and sanitation purposes shall be connected to the piping system with an appliance connector listed as complying with ANSI Z21.69/CSA 6.16. The commercial cooking appliance connector installation shall be configured in accordance with the manufacturer's installation instructions. Movement of appliances with casters shall be limited by a restraining device installed in accordance with the connector and appliance manufacturer's instructions. (IFC 606.4 2021)	The kitchen gas fed appliances are not tethered to the wall.

9 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified. (IFC 705.2 2021)	Corrected

10 Duct and Air Transfer Openings - Maintaining Protection

Dampers protecting ducts and air transfer openings shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Other products or materials used to protect the openings for ducts and air transfer openings shall be securely attached to or bonded to the construction containing the duct or air transfer opening, without visible openings through or into the cavity of the construction. Any damaged products or materials protecting duct and air transfer openings shall be repaired, restored or replaced. (IFC 706.1 2018)	The facility could not produce documentation of dampers corrections to the following from the report dated 4/2024. FD-1-A-3 FD-1-D-3 FD-1-D-10 FD-1-K-4 FD-1-L-

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Business Name	Cogir of Bothell	***Provider Number***	2623
Address	10605 NE 185TH ST ,	***Approval Status***	Disapproved
City, State, Zip	Bothell, WA 98011	***Facility Type***	Residential Care

On 07/08/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

11 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Corrected

12 Wet-Chemical Systems

Wet-chemical extinguishing systems shall be installed, maintained, periodically inspected and tested in accordance with NFPA 17A and their listing. Records of inspection and testing shall be maintained. (IFC 904.5 2021)	Corrected

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Business Name	Cogir of Bothell	***Provider Number***	2623
Address	10605 NE 185TH ST ,	***Approval Status***	Disapproved
City, State, Zip	Bothell, WA 98011	***Facility Type***	Residential Care

On 07/08/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

13 Portable Fire Extinguishers - General Requirements

Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10. Exceptions: 1. The distance of travel to reach an extinguisher shall not apply The travel distance to reach an extinguisher shall not apply to the spectator seating portions of Group A-5 occupancies. 2. Thirty-day inspections shall not be required and maintenance shall be allowed to be once every three years for dry-chemical or halogenated agent portable fire extinguishers that are supervised by a listed and approved electronic monitoring device, provided that all of the following conditions are met: 2.1. Electronic monitoring shall confirm that extinguishers are properly positioned, properly charged and unobstructed. 2.2. Loss of power or circuit continuity to the electronic monitoring device shall initiate a trouble signal. 2.3. The extinguishers shall be installed inside of a building or cabinet in a noncorrosive environment. 2.4. Electronic monitoring devices and supervisory circuits shall be tested every 3 years when extinguisher maintenance is performed. 2.5. A written log of required hydrostatic test dates for extinguishers shall be maintained by the owner to verify that hydrostatic tests are conducted at the frequency required by NFPA 10. 3. In Group I-3, portable fire extinguishers shall be permitted to be located at staff locations. (IFC 906.2 2021)	Corrected

14 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2021)	The fire alarm report dated 4/30/25 had deficiencies without documentation of correction: 2nd floor dialer battery failed 1st floor NAC panel next to FACP failed.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Business Name	Cogir of Bothell	***Provider Number***	2623
Address	10605 NE 185TH ST ,	***Approval Status***	Disapproved
City, State, Zip	Bothell, WA 98011	***Facility Type***	Residential Care

On 07/08/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

15 General

Carbon monoxide detection systems shall comply with NFPA 720. Carbon monoxide detectors shall be listed in accordance with UL 2075. (IFC 0915.5.1 2021)	Corrected

16 Exit Signs - Where Required

Exits and exit access doors shall be marked by an approved exit sign readily visible from any direction of egress travel. The path of egress travel to exits and within exits shall be marked by readily visible exit signs to clearly indicate the direction of egress travel in cases where the exit or the path of egress travel is not immediately visible to the occupants. Intervening means of egress doors within exits shall be marked by exit signs. Exit sign placement shall be such that any point in an exit access corridor or exit passageway is within 100 feet (30 480 mm) or the listed viewing distance of the sign, whichever is less, from the nearest visible exit sign. Exceptions: 1. Exit signs are not required in rooms or areas that require only one exit or exit access. 2. Main exterior exit doors or gates that are obviously and clearly identifiable as exits need not have exit signs where approved by the fire code official. 3. Exit signs are not required in occupancies in Group U and individual sleeping units or dwelling units in Group R-1, R-2 or R-3. 4. Exit signs are not required in dayrooms, sleeping rooms or dormitories in occupancies in Group I-3. 5. In occupancies in Groups A-4 and A-5, exit signs are not required on the seating side of vomitories or openings into seating areas where exit signs are provided in the concourse that are readily apparent from the vomitories. Egress lighting is provided to identify each vomitory or opening within the seating area in an emergency. (IFC 1013.1 2021)	Corrected

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Business Name	Cogir of Bothell	***Provider Number***	2623
Address	10605 NE 185TH ST ,	***Approval Status***	Disapproved
City, State, Zip	Bothell, WA 98011	***Facility Type***	Residential Care

On 07/08/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

17 Activation Test

Emergency lighting equipment shall be tested monthly for a duration of not less than 30 seconds. The test shall be performed manually or by an automated self-testing and self-diagnostic routine. Where testing is performed by self-testing and self-diagnostics, a visual inspection of the emergency lighting equipment shall be conducted monthly to identify any equipment displaying a trouble indicator or that has become damaged or otherwise impaired. (IFC 1032.10.1 2021)	Corrected

18 Power Test

Battery-powered emergency lighting equipment shall be tested annually by operating the equipment on battery power for not less than 90 minutes. (IFC 1031.10.2 2021)	The facility could not produce a 90 minute test for the annual testing of emergency lights and exit signs.

19 Fire Drills

In all Group I, Group E, and Group R2 Occupancies licensed by the state, at least twelve planned and unannounced fire drills shall be held every year. Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. A detailed written record of all fire drills shall be maintained and available for inspection at all times. When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms. Fire drills shall include the transmission of a fire alarm signal and simulation of emergency conditions. The fire alarm monitoring company shall be notified prior to the activation of the fire alarm system for drill purposes and again at the conclusion of the transmission and restoration of the fire alarm system to normal mode. (WAC 212-12-044)	The facility could not produce any fire drills that include the activation of alarms.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cogir of Bothell	***Provider Number***	2623
Address	10605 NE 185TH ST ,	***Approval Status***	Disapproved
City, State, Zip	Bothell, WA 98011	***Facility Type***	Residential Care

On 07/08/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement — Statement of Violation

Next inspection scheduled on or after: 08/07/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

_____ _____
Signature Print Name and Title

Deputy State Fire Marshal Kimberly Bloor
PO Box 42600
Olympia WA 985042600
(360) 596-3922

Kimberly Bloor
Digitally signed by Kimberly Bloor
Date: 2026.07.08 16:02:33 -07'00'
Signature

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____