Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Aspen Quality Care	***Provider Number***	2636
Address	9626 N COLFAX RD ,	***Approval Status***	Approved
City, State, Zip	Spokane, WA 99218	***Facility Type***	Residential Care

On 09/29/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Relocatable power taps and current taps

Relocatable power taps and current taps. The construction and use of current taps and relocatable power taps shall be in accordance with NFPA 70 and this code. (IFC 603.5, 2021)	Removed.

2 Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion. (IFC 904.13.5.2 2021)	Acknowledged.

3 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2021)	All devices connected to the addressible fire alarm panel

Initials of Authorized Facility Representative: IE

This document was prepared by Residential Care Services for the Locator website.

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Aspen Quality Care	***Provider Number***	2636
Address	9626 N COLFAX RD ,	***Approval Status***	Approved
City, State, Zip	Spokane, WA 99218	***Facility Type***	Residential Care

On 09/29/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement — Statement of Violation

Next inspection scheduled on or after: 09/30/2027

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature — Jason Selby Maintenance
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746

Signature

Initials of Authorized Facility Representative: JS

This document was prepared by Residential Care Services for the Locator website.

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Aspen Quality Care	***Provider Number***	2636
Address	9626 N COLFAX RD ,	***Approval Status***	Disapproved
City, State, Zip	Spokane, WA 99218	***Facility Type***	Residential Care

On 08/14/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin - (ITM) Inspection, Testing, & Maintenance

Any citation that requires inspection, testing, or maintenance (ITM) is required to have the testing completed, paper results delivered, and any deficiencies found during the ITM corrected before the citation is cleared."	For your information.

2 Relocatable power taps and current taps

Relocatable power taps and current taps. The construction and use of current taps and relocatable power taps shall be in accordance with NFPA 70 and this code. (IFC 603.5, 2021)	The following violations were observed: In the basement back office there is a refrigerator and microwave plugged into a powerstrip.

3 Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion. (IFC 904.13.5.2 2021)	The following violations were observed: Facility is unable to provide documentation the most recent June/July 2026 report for the semi-annual kitchen suppression system servicing.

4 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2021)	The following violations were observed: SIngle station smoke detectors may be greater than 10 years from manufacturer's date in the facility. NFPA 72 14.4.5.4.1 Smoke alarms shall not remain in service longer than 10 years from the date of manufacture, unless otherwise provided by the manufacturer's published instructions.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative:_____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Aspen Quality Care	***Provider Number***	2636
Address	9626 N COLFAX RD ,	***Approval Status***	Disapproved
City, State, Zip	Spokane, WA 99218	***Facility Type***	Residential Care

On 08/14/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement — Statement of Violation

Next inspection scheduled on or after: 09/13/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Sheri Flavel Manager

Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746

Barbara D

Signature

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative:_____