Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Rivers Walk Assisted Living	***Provider Number***	2647
Address	912 S 3rd ST ,	***Approval Status***	Approved
City, State, Zip	Dayton, WA 99328	***Facility Type***	Residential Care

On 06/30/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Signature

Shadow Kubrick Manager of Emergency management
Print Name and Title

Deputy State Fire Marshal Alan Harlan
2803 156TH AVE SE
Bellevue WA 98007
(425) 495-7121

Alan Harlan Digitally signed by Alan Harlan Date: 2026.06.30 16:12:42 -07'00'

Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Rivers Walk Assisted Living	***Provider Number***	2647
Address	912 S 3rd ST ,	***Approval Status***	Disapproved
City, State, Zip	Dayton, WA 99328	***Facility Type***	Residential Care

On 06/24/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Equipment Access

Approved access shall be providedand maintained for all fire protection system equipment to permit immediate safe operation and maintenance of such equipment. Storage, trash and other materials or objects shall not be placed or kept in such a manner that would prevent such equipment from being readily accessible. (IFC 509.2, 2021)	Corrected

2 Application and Use

603.5.2 Application and use. Relocatable power taps and current taps shall be directly connected to a permanently installed receptacle. Exceptions: 1. Where approved for use in a Group A occupancy or in a meeting room in a Group B occupancy, not more than five relocatable power taps shall be permitted to be connected together or connected to an extension cord for temporary use to supply power to electronic equipment. 2. Current taps and relocatable power taps shall not be required to connect directly to a permanently installed receptacle outlet where used for 90 days or less for the purpose of testing the performance of such devices. (IFC 603.5.2, 2021)	Corrected

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Rivers Walk Assisted Living	***Provider Number***	2647
Address	912 S 3rd ST ,	***Approval Status***	Disapproved
City, State, Zip	Dayton, WA 99328	***Facility Type***	Residential Care

On 06/24/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

3 Owner's Responsibility

The owner shall maintain an inventory of all required fire-resistance-rated construction, construction installed to resist the passage of smoke and the construction included in Sections 703 through 707 and Sections 602.4.1 and 602.4.2 of the International Building Code. Such construction shall be visually inspected by the owner annually and properly repaired, restored or replaced where damaged, altered, breached or penetrated. Records of inspections and repairs shall be maintained. Where concealed, such elements shall not be required to be visually inspected by the owner unless the concealed space is accessible by the removal or movement of a panel, access door, ceiling tile or similar movable entry to the space. (IFC 701.6 2021)	The following violation was observed: Facility was unable to provide evidence of annual inspection and maintenance of fire resistive walls.

4 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified. (IFC 705.2 2021)	Corrected

5 Hold-Open Devices and Closers

Hold-open devices and automatic door closers, where provided, shall be maintained. During the period that such device is out of service for repairs, the door it operates shall remain in the closed position. (IFC 705.2.3 2021)	Corrected

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Rivers Walk Assisted Living	***Provider Number***	2647
Address	912 S 3rd ST ,	***Approval Status***	Disapproved
City, State, Zip	Dayton, WA 99328	***Facility Type***	Residential Care

On 06/24/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
6 Door Operation	
Swinging fire doors shall close from the full-open position and latch automatically. (IFC 705.2.4 2021)	Corrected
7 Testing and Maintenance	
Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	The following violations were observed: Facility was unable to provide evidence that annual forward flow testing was performed within the past twelve months.
8 Unobstructed and Unobscured	
Manual fire alarm boxes shall be provided with ready access, unobstructed, unobscured and visible at all times. (IFC 907.4.2.6 2021)	Corrected
9 Maintenance	
Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required. (IFC 1203.4 2021)	Corrected

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Rivers Walk Assisted Living	***Provider Number***	2647
Address	912 S 3rd ST ,	***Approval Status***	Disapproved
City, State, Zip	Dayton, WA 99328	***Facility Type***	Residential Care

On 06/24/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

Next inspection scheduled on or after: 07/24/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Alan Harlan
2803 156TH AVE SE
Bellevue WA 98007
(425) 495-7121

Signature

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____