Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Maple Glen Assisted Living	***Provider Number***	2655
Address	1700 N 13TH LOOP RD ,	***Approval Status***	Approved
City, State, Zip	Shelton, WA 98584	***Facility Type***	Residential Care

On 07/29/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin Complaint

COMPLAINT # 234079 Here's a complaint of Fire alarm Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	COMPLAINT # 234079 On 7/29/26 a complaint investigation was conduced for Maple Glen Assisted Living located at 1700 N 13th Loop Road, Shelton, WA 98584. An interview was conducted with facility staff. Faulty smoke detector in mechanical room was setting off the fire alarm in the building.. Facility had repairs made on smoke detector and is in normal status. There was no sign of a fire, the sprinkler system was not activated. there were no evacuations, there were no injuries, fire department did respond.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

NOT AVAILABLE
Signature

Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

Signature

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.